

ZAVITINSK, Russian Federation

WMO: 315270

Lat: 50.117N

Lon: 129.467E

Elev: 240

StdP: 98.48

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -33.7	(c) -31.8	(d) -36.6	(e) 0.1	(f) -33.0	(g) -34.9	(h) 0.1	(i) -31.3	(j) 6.5	(k) -20.3	(l) 5.6	(m) -18.7	(n) 0.6	(o) 250	(p) 0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.3	(c) 29.4	(d) 20.9	(e) 27.8	(f) 20.2	(g) 26.3	(h) 19.5	(i) 22.7	(j) 26.9	(k) 21.7	(l) 25.9	(m) 20.8	(n) 24.9	(o) 2.1	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.5	16.6	24.9	20.3	15.4	23.9	19.3	14.4	23.1	68.7	26.9	64.7	25.8	61.4	25.1	32.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.1	(b) 6.0	(c) 5.1	(e) -36.3	(f) 32.3	(g) 2.6	(h) 1.6	(i) -38.2	(j) 33.4	(k) -39.7	(l) 34.3	(m) -41.1	(n) 35.2	(o) -43.0	(p) 36.3		
(a) 7.1	(b) 6.0	(c) 5.1	(e) -36.4	(f) 24.9	(g) 2.5	(h) 2.5	(i) -38.2	(j) 26.7	(k) -39.6	(l) 28.2	(m) -41.0	(n) 29.6	(o) -42.8	(p) 31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-23.0	-18.1	-8.5	3.6	12.0	18.1	21.0	18.8	12.0	2.2	-11.5	-22.0		
	DBStd	16.41	4.28	4.89	6.10	4.88	4.25	3.35	2.38	3.00	4.11	5.09	6.72	4.86		
	HDD10.0	4519	1022	787	574	201	27	0	0	1	26	245	645	993		
	HDD18.3	6694	1280	1020	832	443	202	44	6	30	193	499	895	1252		
	CDD10.0	1043	0	0	0	8	88	243	342	272	86	4	0	0		
	CDD18.3	177	0	0	0	0	4	37	89	44	3	0	0	0		
	CDH23.3	1301	0	0	0	6	75	339	581	278	22	1	0	0		
	CDH26.7	269	0	0	0	1	13	89	124	41	1	0	0	0		
	WSAvg	1.9	1.4	1.6	2.2	2.5	2.4	1.7	1.6	1.5	1.9	2.2	1.9	1.4		
	PrecAvg	594	8	8	15	30	58	88	125	122	75	37	20	16		
(15) Precipitation	PrecMax	888	21	27	38	94	123	213	229	294	125	96	45	42		
	PrecMin	476	1	0	0	0	20	12	30	43	17	6	6	4		
	PrecStd	103	6	7	12	22	31	40	53	50	33	23	10	10		
	PrecStd	103	6	7	12	22	31	40	53	50	33	23	10	10		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.3	-1.4	8.7	23.6	28.4	32.0	31.3	29.5	25.8	19.7	7.1	-5.7		
		MCWB	-10.2	-4.0	2.8	11.0	15.1	21.1	22.2	21.8	18.7	10.9	3.2	-7.0		
	2%	DB	-12.4	-4.4	5.3	17.7	25.5	29.1	29.6	27.8	23.4	15.7	3.4	-10.1		
		MCWB	-13.2	-6.2	0.6	8.3	14.1	19.6	21.9	21.1	16.7	9.1	0.5	-10.9		
	5%	DB	-14.5	-7.4	3.0	14.6	22.8	27.0	28.0	26.2	21.5	12.7	0.7	-12.8		
		MCWB	-15.3	-8.9	-0.6	6.8	12.8	18.7	21.2	20.2	15.4	6.7	-1.3	-13.6		
	10%	DB	-16.3	-10.2	0.8	11.9	20.2	25.0	26.5	24.7	19.3	10.2	-1.4	-14.8		
		MCWB	-17.0	-11.4	-2.0	5.1	11.7	18.1	20.6	19.5	14.1	5.5	-3.1	-15.4		
	0.4%	WB	-9.9	-3.8	3.4	11.7	16.9	23.0	25.6	23.9	19.8	11.9	3.8	-6.8		
		MCDB	-9.5	-1.8	8.2	22.1	24.3	30.0	28.0	27.2	23.8	17.5	6.5	-5.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-13.2	-6.3	1.1	8.9	15.2	20.9	23.0	22.4	17.8	9.9	0.6	-10.9		
		MCDB	-12.4	-4.5	4.4	16.2	22.3	27.0	27.1	25.8	22.2	14.6	2.7	-10.2		
	5%	WB	-15.2	-9.0	-0.4	7.2	14.0	19.7	22.0	21.2	16.5	7.6	-1.0	-13.5		
		MCDB	-14.6	-7.6	2.6	13.7	20.4	25.1	26.3	24.7	20.2	11.6	0.8	-12.8		
	10%	WB	-16.9	-11.4	-1.9	5.6	12.8	18.7	21.2	20.2	15.1	5.8	-3.1	-15.4		
		MCDB	-16.3	-10.3	0.9	11.5	19.2	23.9	25.6	23.7	18.0	9.8	-1.5	-14.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	10.7	10.6	10.5	11.3	10.3	9.3	9.6	10.8	10.0	9.1	8.9		
		MCDBR	9.9	11.8	10.8	14.5	15.5	13.7	11.7	11.7	13.7	14.0	10.0	9.2		
	5% WB	MCWBR	9.3	10.4	7.5	8.2	7.1	6.3	5.7	5.9	7.4	8.4	7.6	8.6		
		MCWBR	10.0	11.8	10.1	13.4	12.8	11.7	9.6	10.0	11.5	12.1	9.3	9.2		
	5% WB	MCWBR	9.4	10.4	7.1	8.0	7.0	6.2	5.6	6.0	7.1	8.0	7.2	8.6		
		MCWBR	9.4	10.4	7.1	8.0	7.0	6.2	5.6	6.0	7.1	8.0	7.2	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.303	0.382	0.536	0.588	0.499	0.480	0.431	0.402	0.416	0.338	0.279		
	taud		2.134	2.054	1.888	1.705	1.684	1.995	2.104	2.233	2.221	2.005	2.074	2.091		
	Ebn at Noon		748	812	795	706	692	769	779	802	781	660	637	666		
	Edh at Noon		78	111	159	216	230	170	150	126	114	118	85	71		
(44) All-Sky Solar Radiation	RadAvg		1.72	2.95	4.47	4.97	5.43	5.88	5.49	4.82	3.85	2.51	1.64	1.33		
	RadStd		0.04	0.06	0.27	0.54	0.43	0.72	0.41	0.32	0.35	0.14	0.10	0.07		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (13 neighbors)	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A

Nomenclature: See separate page