

SEKTAGLI, Russian Federation

WMO: 315340

Lat: 50.433N

Lon: 131.017E

Elev: 896

StdP: 14.23

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.4	-32.7	-40.4	0.6	-35.9	-36.9	0.7	-32.4	9.3	-2.1	7.3	-3.4	0.0	150	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	85.4	69.9	82.2	68.8	79.1	66.9	72.8	80.6	71.0	78.6	69.4	76.6	3.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.4	115.7	76.5	68.6	108.4	74.8	66.9	102.5	73.1	37.1	80.7	35.6	78.3	34.1	76.8	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	10.5	8.4	DB	-40.3	91.4	4.5	2.8	-43.6	93.4	-46.2	95.0	-48.8	96.6	-52.0	98.6	(4)
(5)			WB	-40.3	76.5	4.3	2.3	-43.4	78.2	-46.0	79.6	-48.4	80.9	-51.5	82.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.1	-14.8	-4.6	14.6	36.5	51.7	63.3	69.0	65.6	53.0	35.6	11.0	-10.6
	DBStd	30.70	8.42	9.42	11.68	8.34	7.01	6.08	4.35	5.48	7.20	8.83	12.46	9.85
	HDD50	8662	2007	1530	1097	411	63	1	0	1	51	453	1169	1879
	HDD65	12661	2472	1950	1562	854	414	101	13	58	362	912	1619	2344
	CDD50	1747	0	0	0	7	117	401	590	484	142	6	0	0
	CDD65	270	0	0	0	0	2	51	138	76	3	0	0	0
	CDH74	2169	0	0	0	8	114	597	967	462	21	0	0	0
	CDH80	518	0	0	0	0	18	169	256	74	1	0	0	0
Wind	WSAvg	2.1	0.6	1.3	2.4	3.1	3.2	2.5	2.3	2.0	2.3	2.5	1.9	0.9
Precipitation	PrecAvg	27.8	0.3	0.3	0.5	1.2	3.1	4.0	5.3	5.7	3.9	1.7	0.9	0.5
	PrecMax	39.4	0.9	1.0	1.4	3.3	6.9	11.2	12.2	9.9	10.1	4.1	1.7	1.3
	PrecMin	15.0	0.0	0.0	0.0	0.1	0.7	0.7	0.9	1.9	0.6	0.3	0.1	0.1
	PrecStd	5.6	0.2	0.2	0.3	0.8	1.7	2.2	2.6	2.2	2.0	0.9	0.5	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	29.0	47.1	73.3	82.4	89.9	90.3	85.1	76.9	66.4	42.1	23.6
		MCWB	14.2	24.0	37.2	52.3	62.1	70.4	71.3	71.6	63.2	52.9	36.4	22.2
	2%	DB	8.5	22.9	41.8	63.2	77.2	84.8	86.3	82.2	72.3	57.8	36.8	15.1
		MCWB	7.4	19.5	33.4	47.2	58.5	68.3	70.9	70.7	61.9	47.3	32.6	13.7
	5%	DB	3.6	17.4	37.9	57.4	72.3	80.6	82.9	78.9	68.5	53.0	33.3	9.7
		MCWB	2.6	14.7	31.0	43.7	55.5	65.7	70.2	68.3	59.6	44.2	30.4	8.8
	10%	DB	-0.8	12.4	34.0	52.4	67.7	76.8	79.6	76.1	65.1	48.9	29.7	4.2
		MCWB	-1.7	10.2	28.8	41.2	53.0	63.8	68.8	66.9	57.8	41.9	27.0	3.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	24.8	37.8	53.9	63.1	74.3	75.3	75.0	66.8	53.1	37.6	21.9
		MCDB	15.1	27.9	46.1	71.8	79.6	85.2	84.0	81.8	72.8	62.4	41.3	24.3
	2%	WB	7.3	19.5	34.2	48.0	59.7	70.3	73.1	72.1	63.8	49.3	33.1	13.9
		MCDB	8.4	23.0	40.3	61.5	72.8	80.6	81.4	78.7	70.0	55.7	35.9	15.1
	5%	WB	2.5	14.8	31.6	44.7	56.9	67.6	71.6	70.3	61.4	45.7	30.7	8.8
		MCDB	3.4	17.4	37.4	55.6	68.5	78.3	79.5	76.7	66.2	51.5	33.5	9.7
	10%	WB	-1.7	10.3	28.8	41.8	54.5	65.4	70.1	68.4	58.9	42.4	27.1	3.4
		MCDB	-0.8	12.3	34.1	51.2	64.6	74.1	77.7	73.8	64.1	47.7	29.8	4.1
Mean Daily Temperature Range	5% DB	MDBR	22.5	28.8	27.8	23.3	23.8	21.1	18.4	18.0	19.5	17.8	16.5	17.8
		MCDBR	22.8	29.9	26.5	32.7	34.3	29.5	24.7	22.6	25.0	25.5	16.7	16.3
		MCWBR	21.1	26.1	18.7	18.2	17.5	14.2	11.5	11.8	13.9	15.0	12.7	15.2
	5% WB	MCDBR	22.5	29.1	23.9	30.1	28.4	24.9	20.4	19.3	20.0	22.9	16.1	16.1
		MCWBR	21.0	25.5	16.6	17.4	15.6	13.2	11.0	11.2	12.4	14.9	12.5	15.1
Clear-Sky Solar Irradiance	taub	0.275	0.310	0.385	0.536	0.597	0.516	0.494	0.434	0.405	0.424	0.344	0.282	
	taud	2.132	2.034	1.884	1.703	1.674	1.964	2.081	2.250	2.227	1.994	2.052	2.086	
	Ebn at Noon	234	253	250	223	217	239	243	253	246	205	196	207	
	Edh at Noon	25	36	50	68	74	56	49	39	36	38	27	22	
All-Sky Solar Radiation	RadAvg	531	910	1397	1591	1620	1773	1656	1472	1156	753	509	414	
	RadStd	15	21	69	163	149	221	135	109	123	51	33	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page