

SEKTAGLI, Russian Federation

WMO: 315340

Lat: 50.433N

Lon: 131.017E

Elev: 273

StdP: 98.09

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -38.0	(c) -35.9	(d) -40.2	(e) 0.1	(f) -37.7	(g) -38.3	(h) 0.1	(i) -35.8	(j) 4.2	(k) -18.9	(l) 3.3	(m) -19.7	(n) 0.0	(o) 150	(p) 0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.2	(c) 29.7	(d) 21.0	(e) 27.9	(f) 20.5	(g) 26.2	(h) 19.4	(i) 22.6	(j) 27.0	(k) 21.7	(l) 25.9	(m) 20.8	(n) 24.8	(o) 1.7	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.3	16.5	24.7	20.3	15.5	23.8	19.4	14.6	22.8	68.5	27.0	65.0	25.7	61.5	24.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.7	(b) 4.7	(c) 3.7	(e) -40.2	(f) 33.0	(g) 2.5	(h) 1.5	(i) -42.0	(j) 34.1	(k) -43.5	(l) 35.0	(m) -44.9	(n) 35.9	(o) -46.7	(p) 37.0		
(a) 5.7	(b) 4.7	(c) 3.7	(e) -40.2	(f) 24.7	(g) 2.4	(h) 1.3	(i) -41.9	(j) 25.7	(k) -43.3	(l) 26.4	(m) -44.7	(n) 27.2	(o) -46.4	(p) 28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.5	-26.0	-20.4	-9.7	2.5	11.0	17.4	20.6	18.7	11.7	2.0	-11.6	-23.7		
	DBStd	17.06	4.68	5.23	6.49	4.63	3.89	3.38	2.42	3.05	4.00	4.91	6.92	5.47		
	HDD10.0	4812	1115	850	609	228	35	1	0	1	28	252	649	1044		
	HDD18.3	7034	1373	1083	868	474	230	56	7	32	201	507	899	1302		
	CDD10.0	971	0	0	0	4	65	223	328	269	79	3	0	0		
	CDD18.3	150	0	0	0	0	1	28	77	42	2	0	0	0		
	CDH23.3	1205	0	0	0	4	63	332	537	257	12	0	0	0		
	CDH26.7	288	0	0	0	0	10	94	142	41	1	0	0	0		
	WSAvg	0.9	0.3	0.6	1.1	1.4	1.4	1.1	1.0	0.9	1.0	1.1	0.8	0.4		
	PrecAvg	705	7	7	12	31	79	101	135	144	100	42	23	13		
(15) Precipitation	PrecMax	1000	23	25	35	85	175	284	311	252	256	104	43	32		
	PrecMin	381	1	0	1	2	17	17	24	48	16	8	2	3		
	PrecStd	143	5	6	8	21	43	56	65	57	51	23	12	8		
	PrecStd	143	5	6	8	21	43	56	65	57	51	23	12	8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.1	-1.7	8.4	22.9	28.0	32.2	32.4	29.5	25.0	19.1	5.6	-4.7		
		MCWB	-9.9	-4.5	2.9	11.3	16.7	21.3	21.9	22.0	17.3	11.6	2.4	-5.4		
	2%	DB	-13.0	-5.1	5.5	17.3	25.1	29.3	30.2	27.9	22.4	14.3	2.6	-9.4		
		MCWB	-13.6	-6.9	0.8	8.5	14.7	20.2	21.6	21.5	16.6	8.5	0.3	-10.2		
	5%	DB	-15.8	-8.1	3.3	14.1	22.4	27.0	28.3	26.0	20.3	11.7	0.7	-12.4		
		MCWB	-16.4	-9.6	-0.6	6.5	13.0	18.7	21.2	20.2	15.3	6.8	-0.9	-12.9		
	10%	DB	-18.2	-10.9	1.1	11.3	19.8	24.9	26.5	24.5	18.4	9.4	-1.3	-15.4		
		MCWB	-18.7	-12.1	-1.8	5.1	11.7	17.7	20.5	19.4	14.3	5.5	-2.8	-15.9		
	0.4%	WB	-10.1	-4.0	3.2	12.2	17.3	23.5	24.1	23.9	19.3	11.7	3.1	-5.6		
		MCDB	-9.4	-2.3	7.8	22.1	26.4	29.6	28.9	27.7	22.6	16.9	5.1	-4.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-13.7	-6.9	1.2	8.9	15.4	21.3	22.8	22.3	17.7	9.6	0.6	-10.1		
		MCDB	-13.1	-5.0	4.6	16.4	22.7	27.0	27.4	25.9	21.1	13.1	2.2	-9.4		
	5%	WB	-16.4	-9.6	-0.2	7.0	13.8	19.8	22.0	21.3	16.3	7.6	-0.7	-12.9		
		MCDB	-15.9	-8.1	3.0	13.1	20.3	25.7	26.4	24.8	19.0	10.8	0.9	-12.4		
	10%	WB	-18.7	-12.1	-1.8	5.4	12.5	18.5	21.2	20.2	14.9	5.8	-2.7	-15.9		
		MCDB	-18.2	-10.9	1.2	10.7	18.1	23.4	25.4	23.2	17.8	8.7	-1.2	-15.5		
	5% DB	MDBR	12.5	16.0	15.4	13.0	13.2	11.7	10.2	10.0	10.9	9.9	9.2	9.9		
		MCDBR	12.7	16.6	14.7	18.2	19.1	16.4	13.7	12.6	13.9	14.2	9.3	9.1		
		MCWBR	11.7	14.5	10.4	10.1	9.7	7.9	6.4	6.5	7.7	8.3	7.1	8.5		
		MCWBR	12.5	16.2	13.3	16.7	15.8	13.8	11.3	10.7	11.1	12.7	8.9	8.9		
(35) Mean Daily Temperature Range	5% WB	MCWBR	11.7	14.1	9.2	9.7	8.6	7.3	6.1	6.2	6.9	8.3	6.9	8.4		
		taub	0.275	0.310	0.385	0.536	0.597	0.516	0.494	0.434	0.405	0.424	0.344	0.282		
		taud	2.132	2.034	1.884	1.703	1.674	1.964	2.081	2.250	2.227	1.994	2.052	2.086		
		Ebn at Noon	737	798	789	704	683	755	766	798	776	647	619	652		
(42) Clear-Sky Solar Irradiance	Edn at Noon		78	113	159	215	232	175	153	123	113	119	86	70		
(44) All-Sky Solar Radiation	RadAvg		1.67	2.87	4.40	5.02	5.11	5.59	5.22	4.64	3.64	2.37	1.60	1.30		
		RadStd	0.05	0.07	0.22	0.52	0.47	0.70	0.43	0.34	0.39	0.16	0.10	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page