

KOMSOMOLSK-ON-AMUR, Russian Federation

WMO: 315610

Lat: 50.533N

Lon: 137.033E

Elev: 72

StdP: 14.66

Time Zone: 10.00 (E10)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.3	-30.2	-39.6	0.6	-34.3	-35.0	0.8	-30.0	19.8	4.8	17.7	4.0	1.2	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	83.6	71.8	81.1	70.3	78.7	68.5	73.9	80.5	72.3	78.5	70.7	76.5	8.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.8	117.8	78.2	70.1	111.2	75.9	68.6	105.3	74.4	37.7	80.9	36.1	78.2	34.8	76.8	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.7	15.4	13.6	DB	-38.7	87.4	5.0	1.9	-42.3	88.8	-45.2	90.0	-48.0	91.1	-51.6	92.5	
			WB	-38.5	76.2	4.7	1.4	-41.9	77.2	-44.6	78.0	-47.3	78.8	-50.7	79.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.2	-10.9	-3.8	15.9	37.7	53.4	63.7	70.1	67.6	55.7	38.1	14.9	-6.4
	DBStd	30.15	11.02	10.27	10.69	8.44	7.94	7.10	5.57	5.17	6.68	7.74	12.67	10.70
	HDD50	8095	1888	1507	1056	382	58	1	0	0	25	375	1054	1749
	HDD65	11982	2353	1927	1521	819	366	108	22	31	284	833	1504	2214
	CDD50	1958	0	0	0	13	162	411	622	547	196	7	0	0
	CDD65	371	0	0	0	0	5	69	180	113	4	0	0	0
	CDH74	1964	0	0	0	1	66	466	949	468	14	0	0	0
	CDH80	333	0	0	0	0	6	91	183	52	1	0	0	0
Wind	WSAvg	6.2	5.3	5.1	6.3	6.9	7.3	6.4	5.9	5.8	6.5	6.3	6.6	6.1
Precipitation	PrecAvg	31.3	1.3	0.9	1.5	1.9	3.1	3.2	4.5	4.8	3.3	2.8	2.2	1.9
	PrecMax	40.0	3.4	3.5	3.3	4.2	7.1	5.0	8.0	8.6	6.1	6.7	5.0	4.8
	PrecMin	20.8	0.1	0.2	0.1	0.6	0.9	0.9	0.2	1.8	0.9	0.9	0.4	0.1
	PrecStd	4.8	0.8	0.7	0.9	0.9	1.3	1.0	1.8	1.9	1.3	1.5	1.3	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.6	25.0	42.6	69.8	80.3	86.7	87.3	84.3	75.9	63.8	41.7	25.0
		MCWB	25.8	21.9	34.8	52.5	63.1	73.0	75.2	72.3	66.3	54.0	36.8	23.1
	2%	DB	20.1	20.2	39.2	62.0	75.2	82.6	84.3	81.2	71.5	57.9	38.1	18.4
		MCWB	18.4	17.5	33.0	49.5	58.0	70.4	72.6	70.7	63.7	50.0	35.0	16.6
	5%	DB	11.3	16.5	35.6	56.1	71.1	79.4	81.9	78.8	68.3	53.5	35.5	14.0
		MCWB	9.8	14.6	30.5	45.7	56.1	67.5	71.4	68.9	61.6	46.4	32.8	12.7
	10%	DB	6.3	11.9	32.2	50.8	67.3	76.0	79.4	76.5	65.8	50.1	32.3	10.2
		MCWB	5.2	10.3	28.3	42.0	54.3	65.7	70.2	68.5	60.0	44.0	30.1	8.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	22.0	36.2	54.8	63.8	74.2	76.8	74.6	67.8	54.2	38.0	23.0
		MCDB	27.4	24.9	41.7	68.1	78.2	84.5	85.2	81.3	72.6	61.9	41.2	24.7
	2%	WB	18.0	17.9	33.2	50.6	61.1	71.6	74.9	72.7	65.1	51.2	35.6	16.8
		MCDB	19.8	20.1	38.0	59.6	71.9	81.0	81.4	78.9	69.9	56.5	37.5	18.3
	5%	WB	10.1	14.5	31.0	46.4	58.2	69.5	73.2	71.2	62.8	47.6	33.0	12.9
		MCDB	11.3	16.4	35.2	56.8	67.0	77.7	78.9	76.5	67.1	53.0	35.0	14.0
	10%	WB	5.1	10.4	28.4	42.5	55.8	67.3	71.6	69.8	61.0	44.6	30.3	9.0
		MCDB	6.1	11.8	32.2	49.6	63.8	74.2	77.3	74.4	65.1	49.3	32.4	10.3
Mean Daily Temperature Range	5% DB	MDBR	17.6	21.5	20.2	16.5	18.3	16.7	13.4	13.4	15.4	15.1	13.6	15.8
		MCDBR	10.7	21.2	20.9	26.2	26.3	21.6	17.1	17.4	18.0	20.3	12.0	15.4
		MCWBR	9.9	18.9	15.3	14.1	12.5	10.5	7.6	8.1	10.0	12.7	9.3	14.6
	5% WB	MCDBR	10.6	20.5	18.0	25.5	22.0	18.7	14.3	14.2	16.2	18.2	10.3	15.3
MCWBR		9.8	18.3	13.5	13.6	11.8	9.5	7.4	7.5	9.8	12.3	8.6	14.6	
Clear-Sky Solar Irradiance	taub	0.280	0.319	0.394	0.511	0.577	0.508	0.506	0.433	0.394	0.416	0.355	0.285	
	taud	2.088	1.996	1.851	1.768	1.737	2.004	2.058	2.281	2.311	2.053	2.019	2.075	
	Ebn at Noon	229	248	246	230	222	241	239	253	251	209	190	204	
	Edh at Noon	26	37	52	64	69	53	50	38	33	36	28	23	
All-Sky Solar Radiation	RadAvg	503	891	1381	1589	1625	1775	1631	1409	1104	704	439	383	
	RadStd	19	30	63	131	134	170	154	116	85	51	38	29	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page