

POYARKOVO, Russian Federation

WMO: 315870

Lat: 49.617N

Lon: 128.650E

Elev: 115

StdP: 99.96

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.7	-33.5	-38.2	0.1	-35.5	-36.0	0.1	-33.2	6.3	-14.7	5.5	-16.5	0.4	290	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	30.8	21.1	29.1	20.7	27.5	20.1	23.4	28.0	22.3	27.0	21.5	25.8	2.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.8	25.9	20.9	15.7	24.7	20.0	14.9	23.9	70.5	28.1	66.6	27.1	63.3	25.7	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.8	5.8	5.0	DB	-38.5	34.0	2.5	1.8	-40.3	35.3	-41.8	36.4	-43.2	37.4	-45.0	38.8	
			WB	-38.6	25.0	2.5	1.1	-40.3	25.8	-41.8	26.5	-43.2	27.1	-45.0	27.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.0	-23.6	-18.5	-8.0	4.4	12.8	18.9	21.8	19.7	13.0	3.2	-10.5	-22.0	(6)
(7)		DBStd	16.81	4.75	5.22	6.58	4.55	4.12	3.40	2.44	2.92	3.93	4.83	6.71	4.98	(7)
(8)		HDD10.0	4428	1040	798	558	176	18	0	0	16	215	616	991		(8)
(9)		HDD18.3	6545	1298	1032	816	417	179	33	3	19	166	468	866	1249	(9)
(10)		CDD10.0	1154	0	0	0	9	104	266	365	299	105	6	0	0	(10)
(11)		CDD18.3	229	0	0	0	0	6	49	109	60	4	0	0	0	(11)
(12)		CDH23.3	1901	0	0	0	8	141	488	792	414	56	2	0	0	(12)
(13)		CDH26.7	521	0	0	0	1	36	164	227	86	7	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.3	1.5	2.1	2.5	2.3	1.9	1.6	1.5	1.8	2.0	1.8	1.4	(14)
(15)	Precipitation	PrecAvg	541	9	7	12	26	51	79	126	108	62	29	15	12	(15)
(16)		PrecMax	896	34	29	40	112	117	165	226	401	126	64	31	40	(16)
(17)		PrecMin	399	0	0	1	0	13	17	49	28	8	4	2	2	(17)
(18)		PrecStd	106	7	6	10	22	27	39	53	75	34	18	8	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.9	-0.2	10.6	24.4	30.2	33.8	33.2	30.6	27.6	20.8	8.4	-5.3	(19)
(20)			MCWB	-9.8	-3.0	3.8	11.4	15.5	20.4	22.4	22.8	18.4	11.4	3.8	-6.4	(20)
(21)		2%	DB	-12.0	-3.7	7.3	19.1	27.2	30.8	31.1	28.9	24.8	16.6	4.2	-9.8	(21)
(22)			MCWB	-13.1	-5.7	2.1	8.8	14.7	19.7	22.5	22.0	16.7	9.2	0.8	-10.7	(22)
(23)		5%	DB	-14.1	-6.8	4.5	15.9	24.2	28.3	29.2	27.4	22.8	13.5	1.5	-12.1	(23)
(24)			MCWB	-14.9	-8.4	0.3	7.2	13.2	19.0	22.0	20.9	15.9	7.4	-1.0	-12.9	(24)
(25)		10%	DB	-16.1	-9.7	2.0	13.0	21.4	26.1	27.5	25.7	20.5	11.0	-0.6	-14.4	(25)
(26)			MCWB	-16.7	-11.0	-1.0	5.6	12.2	18.3	21.4	20.0	14.6	6.1	-2.4	-15.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.5	-2.5	4.4	12.1	17.1	23.0	25.1	24.5	20.4	12.4	4.2	-6.4	(27)
(28)			MCDWB	-8.7	-0.1	9.7	22.8	25.7	29.4	29.8	28.5	24.8	19.4	8.3	-5.2	(28)
(29)		2%	WB	-13.0	-5.5	2.4	9.4	15.7	21.3	23.7	23.1	18.2	10.1	1.0	-10.7	(29)
(30)			MCDWB	-12.0	-3.8	6.5	17.8	23.7	27.5	28.3	27.5	22.8	14.7	3.7	-9.9	(30)
(31)		5%	WB	-14.9	-8.4	0.7	7.6	14.5	20.2	22.8	21.9	17.0	8.3	-0.7	-12.9	(31)
(32)			MCDWB	-14.2	-6.9	3.9	14.6	22.0	25.9	27.5	25.8	21.2	12.7	1.3	-12.1	(32)
(33)		10%	WB	-16.7	-10.9	-0.9	6.2	13.2	19.2	22.0	20.9	15.6	6.6	-2.5	-15.0	(33)
(34)			MCDWB	-16.1	-9.8	2.0	12.2	20.2	24.5	26.5	24.5	19.3	10.5	-0.6	-14.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.3	13.3	12.4	11.9	12.6	11.2	9.7	10.0	12.1	11.1	10.3	10.2	(35)
(36)			MCDBR	12.1	15.0	13.2	17.3	18.0	15.5	12.9	12.6	15.8	15.9	11.8	11.0	(36)
(37)			MCWBR	11.3	13.0	8.5	9.0	7.8	6.3	5.4	6.2	8.1	9.1	8.7	10.0	(37)
(38)		5% WB	MCDBR	12.0	14.8	12.2	15.6	15.0	12.5	10.7	10.6	13.0	13.7	11.0	10.7	(38)
(39)			MCWBR	11.2	12.9	8.1	8.5	7.1	5.9	5.4	5.7	7.2	8.5	8.2	9.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.312	0.389	0.525	0.578	0.515	0.496	0.444	0.408	0.410	0.338	0.289	(40)	
(41)		taud	2.118	2.041	1.897	1.749	1.711	1.967	2.071	2.200	2.209	2.040	2.096	2.085	(41)	
(42)		Ebn at Noon	739	806	791	718	701	757	766	791	777	675	649	660	(42)	
(43)		Edh at Noon	82	114	159	207	224	175	155	131	116	115	84	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.77	3.00	4.49	4.91	5.40	5.81	5.43	4.82	3.87	2.53	1.66	1.37	(44)	
(45)		RadStd	0.05	0.07	0.28	0.52	0.43	0.72	0.41	0.33	0.35	0.16	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page