

URMI, Russian Federation

WMO: 316240

Lat: 49.400N

Lon: 133.233E

Elev: 660

StdP: 14.35

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.1	-30.0	-38.3	0.6	-33.5	-34.6	0.8	-29.3	12.0	-3.1	11.4	-1.2	0.1	340	0.560

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	85.4	70.7	81.9	68.9	79.0	67.1	73.6	81.6	71.6	78.4	69.8	76.5	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.1	117.7	77.7	69.3	110.2	75.6	67.5	103.4	73.7	37.8	81.8	36.0	78.6	34.4	76.4	91.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.6	7.6	-37.6	92.9	3.6	4.7	-40.2	96.3	-42.3	99.0	-44.3	101.6	-47.0	105.0		
(5)			-38.2	78.4	4.1	4.6	-41.2	81.8	-43.6	84.5	-45.9	87.1	-48.9	90.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	31.8	-8.5	-0.7	17.3	36.0	50.5	61.3	67.7	64.8	52.4	35.1	11.3	-7.3		
	DBStd	28.37	8.68	8.32	10.46	7.27	6.75	5.87	4.51	5.25	6.95	7.67	11.39	9.07		
	HDD50	8203	1813	1420	1013	424	77	1	0	1	52	464	1162	1776		
	HDD65	12309	2278	1840	1478	870	450	140	25	67	380	928	1612	2241		
	CDD50	1575	0	0	0	4	93	340	550	461	125	2	0	0		
	CDD65	204	0	0	0	0	1	29	109	62	3	0	0	0		
	CDH74	2144	0	0	0	7	140	534	930	489	44	0	0	0		
	CDH80	536	0	0	0	0	25	156	269	81	5	0	0	0		
(14) Wind	WSAvg	2.0	1.6	2.1	2.7	2.5	2.3	1.6	1.4	1.3	1.8	2.4	2.1	1.7		
(15) Precipitation	PrecAvg	32.2	0.3	0.3	0.8	1.6	3.4	4.4	6.7	6.6	4.1	1.8	0.8	0.5		
	PrecMax	41.9	1.3	1.4	2.4	4.8	7.6	9.1	12.4	9.9	9.7	4.6	2.9	1.5		
	PrecMin	23.0	0.0	0.0	0.1	0.2	0.5	1.0	1.1	1.5	0.7	0.2	0.0	0.0		
	PrecStd	5.5	0.3	0.3	0.6	1.2	1.8	2.3	2.7	2.2	1.9	1.2	0.7	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.3	29.5	51.2	73.8	83.3	90.6	91.7	86.0	78.8	65.9	41.2	23.3		
		MCWB	18.7	23.8	38.7	53.7	60.9	71.8	73.1	73.4	67.0	53.5	35.3	21.9		
	2%	DB	15.2	24.5	44.4	63.4	78.3	84.2	86.3	82.2	73.8	58.9	35.9	17.1		
		MCWB	13.0	20.2	34.6	47.6	57.7	68.5	72.0	71.3	62.7	47.4	32.0	15.3		
	5%	DB	10.7	20.2	40.3	57.3	73.0	80.0	82.5	79.2	70.0	53.4	32.6	12.6		
		MCWB	9.0	16.9	32.1	44.3	55.0	65.9	70.8	69.2	60.1	44.1	30.1	10.9		
	10%	DB	6.6	16.2	35.8	52.1	68.1	76.1	79.2	76.3	66.1	49.0	29.3	8.1		
		MCWB	5.2	13.5	29.7	40.8	53.4	64.4	69.3	67.7	58.3	41.9	26.3	6.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	24.5	39.1	55.5	63.1	75.5	76.5	76.0	69.3	54.4	35.6	22.0		
		MCDB	21.0	29.2	50.3	71.6	79.0	87.8	85.1	82.8	77.3	63.4	38.8	23.3		
	2%	WB	13.2	20.4	35.2	48.7	59.9	70.6	73.8	73.3	65.5	49.4	33.0	15.6		
		MCDB	15.3	24.3	43.0	60.9	72.8	79.7	82.3	80.0	71.3	55.6	35.4	17.1		
	5%	WB	9.0	17.0	32.8	45.2	57.4	67.9	72.0	71.1	62.3	45.6	30.3	10.9		
		MCDB	10.7	20.2	39.1	56.3	69.0	76.9	79.4	76.7	66.8	51.4	32.8	12.5		
	10%	WB	5.2	13.5	30.2	41.7	54.8	65.6	70.4	69.1	59.4	42.8	26.2	6.7		
		MCDB	6.5	16.2	35.9	50.4	65.2	74.2	77.6	74.4	64.5	48.2	29.1	8.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	27.4	31.7	30.1	25.7	27.1	24.8	20.6	21.1	25.8	23.7	22.1	24.2		
		MCDBR	29.0	33.5	31.1	27.3	40.1	34.6	29.2	27.1	32.7	33.1	23.0	24.5		
		MCWBR	26.7	29.4	21.9	23.0	21.6	19.6	16.6	16.7	21.0	21.9	18.8	22.5		
	5% WB	MCDBR	28.8	32.9	29.2	34.3	33.7	28.2	24.4	21.7	25.8	29.3	22.0	24.2		
		MCWBR	26.7	28.8	20.9	22.0	19.6	17.5	15.1	14.6	18.1	20.5	18.4	22.2		
(40) Clear-Sky Solar Irradiance	taub		0.275	0.312	0.384	0.519	0.559	0.509	0.495	0.433	0.397	0.407	0.339	0.282		
	taud		2.186	2.065	1.924	1.754	1.774	2.001	2.094	2.272	2.287	2.070	2.111	2.152		
	Ebn at Noon		242	257	254	230	228	242	244	255	252	217	207	218		
	Edh at Noon		24	36	49	65	67	54	48	39	34	36	27	22		
(44) All-Sky Solar Radiation	RadAvg		566	950	1394	1474	1574	1698	1557	1430	1167	787	526	437		
	RadStd		13	23	102	157	157	246	149	126	121	67	43	23		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page