

KUR, Russian Federation

WMO: 316320

Lat: 49.933N

Lon: 134.633E

Elev: 283

StdP: 97.97

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.1	-35.1	-39.8	0.1	-36.9	-37.7	0.1	-34.7	6.5	-15.1	4.7	-12.9	0.1	20	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	29.8	20.5	27.6	19.7	25.8	18.7	22.2	26.9	21.1	25.6	20.1	24.1	1.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	15.9	24.2	19.7	14.9	23.1	18.8	14.1	22.0	66.9	27.0	62.9	25.5	59.4	24.2	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.7	3.6	3.1	-39.7	33.1	2.1	1.9	-41.2	34.5	-42.4	35.7	-43.6	36.8	-45.1	38.2
			-39.8	24.6	2.0	1.7	-41.3	25.8	-42.5	26.8	-43.7	27.8	-45.1	29.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.2	-23.0	-17.8	-7.9	1.9	10.2	16.1	19.7	17.9	11.6	1.8	-12.0	-22.4
	DBStd	15.87	5.35	5.20	5.24	3.98	4.01	3.42	2.69	2.85	3.77	4.40	6.76	5.73
	HDD10.0	4598	1022	778	555	245	48	1	0	1	27	257	661	1003
	HDD18.3	6884	1280	1012	813	493	254	83	16	41	204	514	911	1262
	CDD10.0	861	0	0	0	2	53	184	301	246	73	2	0	0
	CDD18.3	104	0	0	0	0	1	17	58	28	1	0	0	0
	CDH23.3	1096	0	0	0	1	59	269	508	237	22	0	0	0
	CDH26.7	291	0	0	0	0	10	77	158	44	2	0	0	0
Wind	WSAvg	0.9	0.6	0.9	1.2	1.1	1.1	1.1	1.0	0.9	0.9	1.0	0.9	0.6
Precipitation	PrecAvg	704	9	9	16	36	72	105	151	135	71	42	23	14
	PrecMax	985	29	39	46	122	120	240	338	246	152	90	63	46
	PrecMin	539	1	1	1	6	33	5	23	33	9	4	3	2
	PrecStd	132	8	9	12	28	29	57	71	52	37	22	18	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-5.4	-0.7	9.1	21.7	27.8	32.0	33.5	30.1	25.7	18.6	5.0	-2.7
		MCWB	-6.8	-4.2	3.0	10.8	15.0	21.1	21.9	21.6	18.1	10.7	1.2	-4.7
	2%	DB	-8.8	-3.7	5.5	16.4	24.9	28.8	30.5	27.8	23.1	14.0	2.0	-7.5
		MCWB	-10.0	-6.4	0.4	7.7	14.1	19.4	21.3	20.7	16.2	8.2	-0.4	-8.6
	5%	DB	-11.6	-6.3	3.1	12.8	22.1	26.3	28.2	25.9	21.0	11.3	0.2	-10.7
		MCWB	-12.5	-8.2	-0.8	5.6	12.5	17.8	20.7	19.4	15.0	6.5	-1.4	-11.4
	10%	DB	-14.3	-8.6	1.0	9.9	19.3	24.0	26.1	24.2	18.8	8.9	-1.7	-13.2
		MCWB	-15.1	-10.2	-2.2	4.0	11.6	16.9	19.9	18.9	14.0	5.2	-3.3	-13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.8	-3.9	3.2	11.4	17.0	23.9	24.0	23.4	19.6	11.8	1.7	-4.6
		MCDB	-5.5	-0.8	8.5	20.4	25.5	29.1	30.0	27.8	24.4	15.8	4.0	-2.5
	2%	WB	-9.9	-6.2	0.7	8.2	15.0	20.7	22.4	21.8	17.6	9.2	0.2	-8.6
		MCDB	-8.8	-3.9	4.5	15.2	22.0	25.9	27.4	25.8	21.0	13.3	1.5	-7.6
	5%	WB	-12.6	-8.2	-0.6	6.2	13.6	19.1	21.4	20.7	16.0	7.3	-1.3	-11.4
		MCDB	-11.7	-6.2	2.8	11.8	20.4	24.5	26.2	24.3	19.3	10.2	0.3	-10.7
	10%	WB	-15.0	-10.2	-2.1	4.4	12.1	17.8	20.6	19.6	14.7	5.5	-3.3	-13.9
		MCDB	-14.3	-8.7	0.8	9.2	17.9	22.6	25.0	22.9	18.0	8.4	-1.8	-13.2
Mean Daily Temperature Range	5% DB	MDBR	14.4	16.3	14.6	12.6	13.6	12.6	10.8	10.9	12.6	11.9	12.5	12.8
		MCDBR	14.1	17.6	15.6	18.8	19.8	17.7	15.7	14.7	16.8	15.8	11.9	11.5
		MCWBR	12.9	15.2	11.0	11.0	10.0	8.9	7.5	8.0	9.7	9.7	9.2	10.5
	5% WB	MCDBR	13.9	17.3	14.6	17.2	16.8	14.4	12.6	11.9	13.5	14.6	11.1	11.1
		MCWBR	12.8	14.8	10.2	10.4	9.3	8.1	6.9	7.2	8.5	9.7	8.5	10.2
Clear-Sky Solar Irradiance	taub	0.273	0.314	0.389	0.517	0.570	0.510	0.501	0.431	0.392	0.403	0.335	0.278	
	taud	2.125	2.010	1.855	1.722	1.740	1.990	2.067	2.273	2.295	2.068	2.067	2.105	
	Ebn at Noon	749	796	787	723	707	761	761	803	795	682	643	673	
	Edh at Noon	80	117	165	212	217	171	156	121	107	111	85	71	
All-Sky Solar Radiation	RadAvg	1.69	2.91	4.39	4.85	5.04	5.42	4.96	4.48	3.62	2.42	1.59	1.30	
	RadStd	0.05	0.09	0.25	0.50	0.48	0.68	0.48	0.37	0.34	0.17	0.11	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page