

AGZU, Russian Federation

WMO: 318250

Lat: 47.5957N

Lon: 138.3894E

Elev: 540

StdP: 14.41

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.6	-20.4	-29.7	1.1	-22.7	-25.9	1.3	-18.2	11.7	3.8	10.0	3.6	0.2	290	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	84.9	68.2	81.1	66.9	77.6	65.3	71.1	80.7	69.2	77.8	67.3	74.6	5.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	106.0	74.7	66.3	98.7	73.0	64.5	92.7	71.0	35.5	80.9	33.8	78.0	32.2	74.7	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.2	8.9	DB	-31.7	93.6	4.3	3.6	-34.8	96.2	-37.3	98.3	-39.7	100.4	-42.8	103.0	(4)
(5)			WB	-31.9	75.4	4.3	2.4	-35.0	77.1	-37.5	78.6	-39.9	79.9	-43.0	81.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.1	-0.6	6.4	21.0	37.3	48.7	58.3	65.7	65.3	54.7	39.8	19.5	2.5		
	DBStd	24.63	8.55	9.00	8.87	6.73	6.81	6.29	5.42	5.22	6.60	6.59	10.56	8.17		
	HDD50	6923	1568	1221	898	384	108	6	0	0	30	322	914	1472		
	HDD65	11098	2033	1641	1363	830	505	215	57	61	310	782	1364	1937		
	CDD50	1469	0	0	0	4	69	257	488	474	172	5	0	0		
	CDD65	169	0	0	0	0	1	16	80	69	3	0	0	0		
	CDH74	1650	0	0	0	3	76	312	709	489	61	0	0	0		
	CDH80	442	0	0	0	0	19	90	213	114	6	0	0	0		
	WSAvg	3.0	2.2	2.6	3.2	3.5	3.8	3.4	3.2	2.6	2.5	2.9	3.2	2.6		
	PrecAvg	24.6	0.8	0.5	1.2	1.5	2.6	2.6	3.9	3.8	3.2	2.3	1.2	1.0		
	PrecMax	35.2	2.0	1.5	3.3	5.4	5.1	6.3	6.9	9.2	8.0	10.0	3.2	3.9		
(15) Precipitation	PrecMin	16.6	0.0	0.0	0.1	0.3	0.2	0.3	0.1	1.2	0.8	0.3	0.0	0.0		
	PrecStd	4.9	0.6	0.4	0.9	1.1	1.1	1.4	1.9	2.2	1.8	1.9	0.9	0.9		
	DB	27.2	37.6	51.3	71.3	83.3	88.1	90.5	88.3	80.2	66.9	47.4	29.8			
	MCWB	23.7	29.3	38.7	51.1	59.7	67.8	71.3	70.7	64.4	52.0	37.3	27.0			
	2% DB	21.8	31.7	44.8	63.0	75.3	82.2	85.5	82.9	75.0	60.7	42.1	24.3			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	19.0	25.6	34.6	46.8	55.9	65.1	69.7	68.4	61.6	48.4	35.9	21.4			
	5% DB	17.5	27.1	40.1	56.8	69.5	77.1	81.4	79.3	71.2	56.3	38.5	20.0			
	MCWB	14.9	22.6	31.9	43.3	53.4	62.7	68.5	67.3	59.8	45.9	32.5	17.4			
	10% DB	13.8	22.8	36.0	51.2	64.4	72.5	77.5	75.9	67.5	52.3	34.5	16.0			
	MCWB	11.6	19.2	29.7	40.3	51.2	61.0	66.8	66.2	58.3	44.2	30.4	13.5			
	0.4% WB	24.1	29.6	39.2	51.7	61.5	70.1	74.7	74.4	66.9	54.4	40.1	27.9			
	MCDB	26.7	36.1	49.9	68.8	77.4	83.8	83.5	81.8	74.8	63.3	44.2	29.1			
	2% WB	19.3	26.1	35.0	47.7	57.9	66.9	71.6	71.2	63.9	50.8	36.4	21.5			
(30) Mean Coincident Dry Bulb Temperatures	MCDB	21.7	31.2	43.1	61.9	72.0	78.5	82.4	79.2	71.6	57.2	41.4	23.7			
	5% WB	15.2	22.7	32.5	43.9	54.7	64.5	69.7	69.3	61.9	48.2	33.4	17.4			
	MCDB	17.4	26.9	38.7	54.6	67.0	74.3	79.2	76.4	68.4	53.4	37.4	19.9			
	10% WB	11.5	19.2	30.3	40.9	52.2	62.0	67.7	67.3	59.9	45.4	30.5	13.6			
	MCDB	13.8	22.8	35.4	50.1	62.3	70.5	75.6	73.3	65.6	51.2	34.4	15.8			
(35) Mean Daily Temperature Range	MDBR	24.3	28.8	26.0	23.2	24.1	22.1	19.4	18.7	24.2	22.8	19.7	21.5			
	5% DB	24.8	31.7	30.1	35.2	36.8	33.6	28.9	26.4	29.6	31.4	21.8	22.2			
	MCWBR	21.8	25.5	20.6	20.0	19.0	16.9	14.1	12.8	16.2	19.0	15.1	19.3			
	5% WB	24.3	30.6	27.5	32.9	32.4	29.1	25.2	21.3	24.0	26.8	20.0	21.2			
	MCWBR	21.4	24.6	18.9	19.3	17.7	16.1	13.4	11.4	14.2	17.6	14.4	18.5			
(40) Clear-Sky Solar Irradiance	taub	0.284	0.329	0.401	0.493	0.527	0.503	0.468	0.433	0.391	0.390	0.340	0.293			
	taud	2.198	2.045	1.891	1.808	1.857	2.032	2.196	2.304	2.336	2.170	2.182	2.178			
	Ebn at Noon	247	255	252	240	238	245	253	257	258	232	219	225			
	Edh at Noon	26	38	52	63	62	52	44	38	33	34	27	23			
(44) All-Sky Solar Radiation	RadAvg	535	868	1208	1413	1537	1575	1479	1377	1204	825	539	421			
	RadStd	40	42	113	161	121	212	149	121	110	71	53	34			

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page