

AGZU, Russian Federation

WMO: 318250

Lat: 47.5957N

Lon: 138.3894E

Elev: 165

StdP: 99.36

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-29.1	-34.3	0.2	-30.4	-32.2	0.2	-27.9	5.2	-15.7	4.5	-15.8	0.1	290	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	29.4	20.1	27.3	19.4	25.3	18.5	21.7	27.0	20.7	25.4	19.6	23.7	2.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	15.1	23.7	19.0	14.1	22.8	18.1	13.2	21.7	64.6	27.2	60.7	25.6	57.0	23.7	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	4.6	4.0	-35.4	34.2	2.4	2.0	-37.1	35.7	-38.5	36.9	-39.8	38.0	-41.6	39.4
			-35.5	24.1	2.4	1.4	-37.2	25.1	-38.6	25.9	-39.9	26.6	-41.7	27.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.7	-18.1	-14.2	-6.1	3.0	9.3	14.6	18.7	18.5	12.6	4.3	-6.9	-16.4	(6)
(7)		DBStd	13.68	4.75	5.00	4.93	3.74	3.78	3.50	3.01	2.90	3.67	3.66	5.86	4.54	(7)
(8)		HDD10.0	3846	871	678	499	213	60	3	0	0	17	179	508	818	(8)
(9)		HDD18.3	6166	1129	912	757	461	281	119	32	34	172	434	758	1076	(9)
(10)		CDD10.0	816	0	0	0	2	38	143	271	263	96	3	0	0	(10)
(11)		CDD18.3	94	0	0	0	0	1	9	44	38	2	0	0	0	(11)
(12)		CDH23.3	917	0	0	0	2	42	173	394	272	34	0	0	0	(12)
(13)		CDH26.7	246	0	0	0	0	11	50	118	63	3	0	0	0	(13)
(14)	Wind	WSAvg	1.3	1.0	1.1	1.4	1.6	1.7	1.5	1.4	1.2	1.1	1.3	1.4	1.1	(14)
(15)	Precipitation	PrecAvg	626	20	13	30	39	67	66	99	96	81	58	31	26	(15)
(16)		PrecMax	893	50	39	83	138	130	161	176	234	202	253	82	99	(16)
(17)		PrecMin	421	0	0	3	8	6	7	3	31	20	8	0	0	(17)
(18)		PrecStd	124	14	10	24	27	28	35	49	55	46	47	24	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.7	3.1	10.7	21.8	28.5	31.1	32.5	31.3	26.8	19.4	8.6	-1.2	(19)
(20)			MCWB	-4.6	-1.5	3.7	10.6	15.4	19.9	21.9	21.5	18.0	11.1	3.0	-2.8	(20)
(21)		2%	DB	-5.7	-0.2	7.1	17.2	24.0	27.9	29.7	28.3	23.9	16.0	5.6	-4.3	(21)
(22)			MCWB	-7.2	-3.6	1.4	8.2	13.3	18.4	21.0	20.2	16.5	9.1	2.2	-5.9	(22)
(23)		5%	DB	-8.1	-2.7	4.5	13.8	20.8	25.1	27.5	26.3	21.8	13.5	3.6	-6.7	(23)
(24)			MCWB	-9.5	-5.2	-0.1	6.3	11.9	17.1	20.3	19.6	15.5	7.7	0.3	-8.1	(24)
(25)		10%	DB	-10.1	-5.1	2.2	10.7	18.0	22.5	25.3	24.4	19.7	11.3	1.4	-8.9	(25)
(26)			MCWB	-11.3	-7.1	-1.3	4.6	10.7	16.1	19.3	19.0	14.6	6.8	-0.9	-10.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.4	-1.3	4.0	11.0	16.4	21.2	23.7	23.5	19.4	12.4	4.5	-2.3	(27)
(28)			MCDWB	-3.0	2.3	10.0	20.4	25.2	28.8	28.6	27.6	23.8	17.4	6.8	-1.6	(28)
(29)		2%	WB	-7.1	-3.3	1.7	8.7	14.4	19.4	22.0	21.8	17.7	10.4	2.5	-5.9	(29)
(30)			MCDWB	-5.7	-0.4	6.2	16.6	22.2	25.8	28.0	26.2	22.0	14.0	5.2	-4.6	(30)
(31)		5%	WB	-9.3	-5.2	0.3	6.6	12.6	18.1	20.9	20.7	16.6	9.0	0.8	-8.1	(31)
(32)			MCDWB	-8.1	-2.8	3.7	12.6	19.5	23.5	26.2	24.7	20.2	11.9	3.0	-6.7	(32)
(33)		10%	WB	-11.4	-7.1	-1.0	4.9	11.2	16.7	19.8	19.6	15.5	7.4	-0.9	-10.2	(33)
(34)			MCDWB	-10.1	-5.1	1.9	10.0	16.9	21.4	24.2	23.0	18.7	10.7	1.3	-9.0	(34)
(35)	Mean Daily Temperature Range	MDBR		13.5	16.0	14.4	12.9	13.4	12.3	10.8	10.4	13.4	12.6	10.9	11.9	(35)
(36)		5% DB	MCDBR	13.8	17.6	16.7	19.6	20.4	18.6	16.1	14.6	16.5	17.5	12.1	12.3	(36)
(37)			MCWBR	12.1	14.2	11.4	11.1	10.6	9.4	7.8	7.1	9.0	10.6	8.4	10.7	(37)
(38)		5% WB	MCDBR	13.5	17.0	15.3	18.3	18.0	16.2	14.0	11.8	13.3	14.9	11.1	11.8	(38)
(39)			MCWBR	11.9	13.7	10.5	10.7	9.8	8.9	7.5	6.3	7.9	9.8	8.0	10.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.284	0.329	0.401	0.493	0.527	0.503	0.468	0.433	0.391	0.390	0.340	0.293	(40)
(41)		taud		2.198	2.045	1.891	1.808	1.857	2.032	2.196	2.304	2.336	2.170	2.182	2.178	(41)
(42)		Ebn at Noon		780	805	793	757	749	773	797	811	812	730	691	708	(42)
(43)		Edh at Noon		81	119	164	198	196	165	139	120	105	106	84	74	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.69	2.73	3.81	4.45	4.84	4.97	4.66	4.34	3.80	2.60	1.70	1.33	(44)
(45)		RadStd		0.13	0.13	0.36	0.51	0.38	0.67	0.47	0.38	0.35	0.23	0.17	0.11	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page