

MYS ZOLOTOTY, Russian Federation

WMO: 318290

Lat: 47.3191N

Lon: 138.9900E

Elev: 84

StdP: 14.65

Time Zone: 10.00 (E10)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.5	-0.7	-24.5	1.4	-3.4	-20.8	1.8	0.8	53.1	21.1	45.5	20.6	12.1	290	0.740

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	72.7	64.3	69.8	63.6	67.3	62.7	67.3	70.3	65.2	68.1	63.6	66.1	9.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	96.0	69.1	64.0	89.4	66.6	62.7	85.4	64.9	31.9	70.4	30.2	68.2	29.1	66.1	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
37.6	30.3	24.5	DB	-9.8	79.3	7.3	4.3	-15.1	82.4	-19.4	84.9	-23.5	87.3	-28.8	90.4
			WB	-10.5	69.7	6.9	3.9	-15.4	72.5	-19.4	74.7	-23.3	76.9	-28.2	79.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.6	13.4	16.0	24.9	34.7	42.4	50.1	58.1	62.9	57.5	45.4	28.6	15.9
	DBStd	18.05	7.62	7.10	5.78	4.72	5.07	4.63	4.03	3.92	4.99	5.97	8.61	7.74
	HDD50	5491	1135	951	778	461	245	53	0	0	5	163	641	1059
	HDD65	10032	1600	1371	1243	910	701	447	217	90	230	608	1091	1524
	CDD50	967	0	0	0	1	9	56	252	400	229	20	0	0
	CDD65	33	0	0	0	0	0	0	4	26	3	0	0	0
	CDH74	67	0	0	0	0	1	5	9	45	7	0	0	0
	CDH80	6	0	0	0	0	0	0	1	5	0	0	0	0
	WSAvg	10.7	11.9	10.3	11.2	10.8	11.3	10.5	9.8	9.6	9.7	10.6	10.6	11.8
	PrecAvg	35.9	0.6	1.1	1.9	2.8	3.5	4.6	4.1	5.2	5.3	3.1	2.1	0.9
(15) Precipitation	PrecMax	52.4	1.9	4.7	6.6	8.3	13.1	13.9	11.7	15.8	15.7	10.1	10.9	3.9
	PrecMin	22.7	0.0	0.0	0.6	0.1	1.3	0.9	0.7	0.9	1.2	0.2	0.0	0.0
	PrecStd	8.6	0.6	1.3	1.3	2.1	2.4	3.1	2.7	3.0	3.3	2.3	2.6	0.9
	PrecStd	8.6	0.6	1.3	1.3	2.1	2.4	3.1	2.7	3.0	3.3	2.3	2.6	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	34.7	41.2	57.5	66.6	70.7	74.3	78.3	72.8	62.3	49.7	37.6
		MCWB	28.4	28.6	32.6	44.8	50.5	57.9	66.8	67.8	61.2	51.5	44.1	35.3
	2%	DB	29.0	31.0	37.3	49.0	58.4	64.1	68.3	74.3	69.1	58.5	45.7	33.2
		MCWB	25.8	27.3	30.2	39.3	47.4	57.3	63.8	66.0	60.6	51.6	40.1	29.9
	5%	DB	26.5	28.6	34.6	44.4	53.3	60.1	65.2	71.5	66.7	56.5	43.2	30.0
		MCWB	24.1	25.3	29.6	37.1	45.6	54.5	62.2	65.0	60.1	50.2	38.2	26.1
	10%	DB	24.2	26.6	32.6	40.9	49.3	56.2	63.3	69.0	64.8	54.3	40.7	27.5
		MCWB	21.6	23.8	28.9	35.7	44.2	52.7	61.4	64.6	59.6	48.6	35.6	23.8
	0.4%	WB	29.3	30.1	34.7	45.1	52.9	61.6	67.1	71.0	65.2	56.7	46.3	35.7
		MCDB	31.3	33.0	38.3	55.7	63.9	65.6	72.2	75.7	68.2	59.0	48.5	37.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.5	28.0	32.1	40.5	49.4	58.0	64.6	68.4	63.4	54.3	41.8	30.9
		MCDB	28.1	30.6	34.5	46.5	55.8	63.4	67.0	71.1	66.3	56.9	44.4	32.9
	5%	WB	24.6	26.0	30.9	38.3	46.8	55.0	63.0	66.9	62.4	51.8	39.1	26.8
		MCDB	26.5	28.1	33.2	42.6	51.0	58.3	64.7	69.6	65.0	54.5	42.9	29.5
	10%	WB	21.8	23.9	29.7	36.5	45.0	53.2	61.7	65.2	61.1	49.8	35.8	23.7
		MCDB	24.1	26.3	32.0	39.7	47.9	55.2	63.2	67.9	63.9	53.1	40.3	27.3
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	11.7	10.0	8.5	8.9	7.5	5.8	7.5	10.7	11.6	11.5	11.3
		MCDBR	12.2	11.7	12.5	15.9	19.4	16.3	10.0	12.8	12.1	13.6	13.0	12.2
		MCWBR	11.1	10.1	9.3	8.8	10.2	10.0	6.6	7.2	8.4	10.4	11.2	11.1
	5% WB	MCDBR	11.9	10.6	10.1	13.9	15.5	13.3	8.9	9.4	8.9	10.5	12.6	10.7
		MCWBR	11.7	9.6	8.5	8.7	9.5	9.1	6.3	6.6	7.3	10.0	12.0	11.0
(40) Clear-Sky Solar Irradiance	taub		0.297	0.340	0.408	0.494	0.528	0.506	0.470	0.438	0.395	0.395	0.349	0.308
	taud		2.249	2.118	1.980	1.859	1.870	2.041	2.214	2.313	2.353	2.181	2.196	2.198
	Ebn at Noon		244	254	251	240	238	245	252	256	257	231	218	220
	Edh at Noon		25	36	48	60	61	52	43	38	33	33	27	23
	RadAvg		519	843	1193	1425	1523	1550	1447	1381	1230	848	551	418
(45) All-Sky Solar Radiation	RadStd		42	45	115	167	127	212	148	127	114	71	54	36

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page