

MYS ZOLOTOTY, Russian Federation

WMO: 318290

Lat: 47.3191N

Lon: 138.9900E

Elev: 26

StdP: 101.02

Time Zone: 10.00 (E10)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.3	-18.2	-31.4	0.2	-19.7	-29.4	0.3	-17.3	23.7	-6.0	20.4	-6.3	5.4	290	0.740

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	22.6	17.9	21.0	17.5	19.6	17.0	19.6	21.3	18.4	20.1	17.6	18.9	4.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	13.7	20.6	17.8	12.8	19.2	17.0	12.2	18.3	56.4	21.3	52.4	20.1	49.8	18.9	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	13.5	11.0	-23.2	26.3	4.1	2.4	-26.2	28.0	-28.5	29.4	-30.8	30.7	-33.8	32.4		
(5)			-23.6	20.9	3.8	2.2	-26.3	22.5	-28.6	23.7	-30.7	25.0	-33.5	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-10.3	-8.9	-3.9	1.5	5.8	10.1	14.5	17.2	14.1	7.4	-1.9	-9.0	(6)
(7)		DBStd	10.03	4.23	3.95	3.21	2.62	2.81	2.57	2.24	2.18	2.77	3.32	4.78	4.30	(7)
(8)		HDD10.0	3051	631	528	432	256	136	29	0	0	3	91	356	588	(8)
(9)		HDD18.3	5573	889	762	691	506	389	248	121	50	128	338	606	847	(9)
(10)		CDD10.0	537	0	0	0	1	5	31	140	222	127	11	0	0	(10)
(11)		CDD18.3	18	0	0	0	0	0	0	2	14	2	0	0	0	(11)
(12)		CDH23.3	37	0	0	0	0	1	3	5	25	4	0	0	0	(12)
(13)		CDH26.7	3	0	0	0	0	0	0	1	3	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	5.3	4.6	5.0	4.8	5.1	4.7	4.4	4.3	4.7	4.7	5.3	(14)	
(15)	Precipitation	PrecAvg	912	14	28	48	71	89	116	105	131	135	80	54	23	(15)
(16)		PrecMax	1332	48	119	167	210	332	353	297	401	399	257	277	98	(16)
(17)		PrecMin	577	0	0	14	2	33	23	17	23	30	6	1	1	(17)
(18)		PrecStd	218	14	33	34	53	60	80	69	77	85	59	66	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.4	1.5	5.1	14.2	19.2	21.5	23.5	25.7	22.7	16.8	9.9	3.1	(19)
(20)			MCWB	-2.0	-1.9	0.3	7.1	10.3	14.4	19.3	19.9	16.2	10.9	6.7	1.8	(20)
(21)		2%	DB	-1.7	-0.5	2.9	9.5	14.7	17.8	20.2	23.5	20.6	14.7	7.6	0.7	(21)
(22)			MCWB	-3.5	-2.6	-1.0	4.1	8.6	14.1	17.7	18.9	15.9	10.9	4.5	-1.2	(22)
(23)		5%	DB	-3.0	-1.9	1.4	6.9	11.8	15.6	18.4	22.0	19.3	13.6	6.2	-1.1	(23)
(24)			MCWB	-4.4	-3.7	-1.3	2.8	7.6	12.5	16.8	18.4	15.6	10.1	3.4	-3.3	(24)
(25)		10%	DB	-4.3	-3.0	0.3	4.9	9.6	13.4	17.4	20.6	18.2	12.4	4.8	-2.5	(25)
(26)			MCWB	-5.8	-4.6	-1.7	2.1	6.8	11.5	16.3	18.1	15.3	9.2	2.0	-4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.5	-1.0	1.5	7.3	11.6	16.5	19.5	21.6	18.4	13.7	8.0	2.1	(27)
(28)			MCDWB	-0.4	0.5	3.5	13.1	17.7	18.6	22.4	24.3	20.1	15.0	9.2	2.9	(28)
(29)		2%	WB	-3.1	-2.2	0.1	4.7	9.7	14.5	18.1	20.2	17.5	12.4	5.5	-0.6	(29)
(30)			MCDWB	-2.2	-0.8	1.4	8.1	13.2	17.4	19.5	21.7	19.0	13.8	6.9	0.5	(30)
(31)		5%	WB	-4.1	-3.3	-0.6	3.5	8.2	12.8	17.2	19.4	16.9	11.0	3.9	-2.9	(31)
(32)			MCDWB	-3.1	-2.2	0.7	5.9	10.5	14.6	18.2	20.9	18.3	12.5	6.1	-1.4	(32)
(33)		10%	WB	-5.7	-4.5	-1.3	2.5	7.2	11.8	16.5	18.4	16.1	9.9	2.1	-4.6	(33)
(34)			MCDWB	-4.4	-3.1	0.0	4.3	8.8	12.9	17.3	20.0	17.7	11.7	4.6	-2.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.5	5.6	4.7	4.9	4.2	3.2	4.2	6.0	6.4	6.4	6.3	(35)
(36)			MCDBR	6.8	6.5	6.9	8.8	10.8	9.0	5.6	7.1	6.7	7.5	7.2	6.8	(36)
(37)			MCWBR	6.2	5.6	5.2	4.9	5.6	5.5	3.7	4.0	4.7	5.8	6.2	6.2	(37)
(38)		5% WB	MCDBR	6.6	5.9	5.6	7.7	8.6	7.4	5.0	5.2	4.9	5.8	7.0	5.9	(38)
(39)			MCWBR	6.5	5.3	4.7	4.8	5.3	5.0	3.5	3.6	4.0	5.6	6.7	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.340	0.408	0.494	0.528	0.506	0.470	0.438	0.395	0.395	0.349	0.308	(40)	
(41)		taud	2.249	2.118	1.980	1.859	1.870	2.041	2.214	2.313	2.353	2.181	2.196	2.198	(41)	
(42)		Ebn at Noon	770	800	792	758	749	771	796	807	811	728	687	695	(42)	
(43)		Edh at Noon	79	112	151	188	193	164	136	119	104	105	84	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.64	2.66	3.76	4.49	4.80	4.88	4.56	4.36	3.88	2.67	1.74	1.32	(44)	
(45)		RadStd	0.13	0.14	0.36	0.53	0.40	0.67	0.47	0.40	0.36	0.23	0.17	0.11	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page