

KIROVSKII, Russian Federation

WMO: 318780

Lat: 45.100N

Lon: 133.500E

Elev: 98

StdP: 100.16

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.6	-28.4	-33.5	0.2	-30.3	-31.1	0.2	-28.0	6.4	-13.1	5.5	-13.2	0.4	180	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	30.0	22.6	28.6	21.7	27.2	21.0	24.1	28.1	23.1	26.9	22.2	25.7	2.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	17.8	26.5	21.9	16.7	25.5	21.0	15.8	24.5	73.2	28.1	69.6	27.0	65.9	25.7	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	5.3	4.5	DB	-33.0	32.7	3.1	1.3	-35.2	33.6	-37.0	34.4	-38.8	35.2	-41.0	36.1	(4)
(5)			WB	-33.1	25.5	3.1	0.9	-35.3	26.1	-37.1	26.7	-38.8	27.2	-41.1	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.1	-18.5	-13.8	-4.4	6.4	13.8	18.7	22.2	21.3	15.3	6.8	-4.8	-15.4	(6)	
	DBStd	14.97	4.92	5.46	5.92	4.62	3.77	3.11	2.46	2.73	3.56	4.76	6.76	5.53	(7)	
	HDD10.0	3491	884	666	448	129	9	0	0	0	4	121	444	786	(8)	
	HDD18.3	5494	1142	899	706	359	149	32	2	7	103	357	694	1044	(9)	
	CDD10.0	1321	0	0	0	20	126	262	378	351	161	22	1	0	(10)	
	CDD18.3	284	0	0	0	1	7	44	122	99	11	0	0	0	(11)	
	CDH23.3	1859	0	0	0	10	98	332	782	568	67	2	0	0	(12)	
	CDH26.7	418	0	0	0	1	19	73	203	115	7	0	0	0	(13)	
(14) Wind	WSAvg	1.8	1.3	1.6	2.1	2.4	2.2	1.8	1.6	1.6	1.7	2.0	2.0	1.6	(14)	
(15) Precipitation	PrecAvg	665	14	14	29	38	79	80	118	99	79	60	32	24	(15)	
	PrecMax	885	36	35	77	108	178	160	271	169	183	127	68	58	(16)	
	PrecMin	407	1	0	1	3	15	29	38	40	16	27	4	2	(17)	
	PrecStd	120	8	10	19	25	34	30	52	38	45	25	16	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.6	4.7	12.9	24.6	29.0	31.0	32.5	31.1	27.5	22.4	14.0	3.9	(19)	
		MCWB	-2.6	0.7	5.7	12.9	17.1	21.5	24.0	24.1	20.1	14.0	8.0	2.2	(20)	
	2%	DB	-4.5	1.9	9.1	20.6	26.1	28.7	30.5	29.3	25.2	19.5	10.2	-0.1	(21)	
		MCWB	-6.0	-1.0	3.6	10.8	15.6	20.3	23.2	23.0	18.5	12.4	5.9	-1.7	(22)	
	5%	DB	-7.8	-1.1	6.5	17.5	23.6	26.9	28.9	27.9	23.5	16.7	7.5	-3.4	(23)	
		MCWB	-9.1	-3.3	2.1	9.2	14.5	19.8	22.6	22.2	17.6	10.8	4.1	-4.8	(24)	
	10%	DB	-10.4	-4.3	4.1	14.6	21.2	25.1	27.4	26.5	21.7	14.5	4.7	-6.5	(25)	
		MCWB	-11.5	-6.2	0.8	7.6	13.3	18.7	21.9	21.4	16.6	9.8	1.9	-7.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.4	1.5	6.3	13.5	18.0	22.7	25.6	25.2	21.7	15.3	8.7	2.1	(27)	
		MCDB	-0.8	3.9	11.4	23.6	26.0	28.5	30.2	29.4	25.1	20.2	13.1	3.8	(28)	
	2%	WB	-6.0	-0.9	4.1	11.2	16.5	21.5	24.4	24.0	20.0	13.4	6.4	-1.6	(29)	
		MCDB	-4.6	1.7	8.2	19.2	24.3	27.0	28.6	27.8	23.4	17.7	9.7	-0.1	(30)	
	5%	WB	-9.1	-3.4	2.4	9.7	15.3	20.4	23.4	23.2	18.6	12.0	4.2	-4.8	(31)	
		MCDB	-7.9	-1.1	6.0	16.6	22.1	25.4	27.5	26.5	22.2	16.0	7.3	-3.4	(32)	
	10%	WB	-11.4	-6.1	1.0	8.1	14.1	19.4	22.5	22.3	17.4	10.4	2.1	-7.8	(33)	
		MCDB	-10.4	-4.3	3.9	13.9	19.6	24.1	26.2	25.3	20.6	13.9	4.6	-6.5	(34)	
(35) Mean Daily Temperature Range	MDBR		12.3	12.9	10.6	10.8	10.9	9.9	8.4	8.5	10.9	11.2	9.9	10.8	(35)	
	5% DB	MCDBR	14.5	14.1	12.3	15.8	15.3	12.9	11.0	10.6	12.8	14.8	12.4	12.3	(36)	
		MCWBR	12.9	11.6	7.9	8.3	7.1	6.1	4.9	5.0	6.7	8.3	8.6	10.9	(37)	
	5% WB	MCDBR	14.0	13.2	11.2	14.7	13.3	11.5	9.6	8.8	10.5	12.6	12.0	12.2	(38)	
		MCWBR	12.7	11.0	7.5	8.0	6.6	5.9	4.7	4.6	5.9	7.8	8.8	11.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.375	0.456	0.565	0.577	0.554	0.512	0.474	0.432	0.453	0.394	0.340	(40)	
	taud		2.039	1.879	1.789	1.695	1.735	1.873	2.042	2.145	2.170	1.962	2.008	2.006	(41)	
	Ebn at Noon		748	763	751	705	716	737	765	780	779	674	644	666	(42)	
	Edh at Noon		104	149	188	226	224	196	164	142	128	136	108	98	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.11	3.18	4.26	4.65	5.21	5.61	5.04	4.66	4.08	2.87	1.97	1.66	(44)	
	RadStd		0.11	0.14	0.27	0.45	0.40	0.61	0.49	0.37	0.34	0.24	0.15	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page