

RUDNAYA PRISTAN, Russian Federation

WMO: 319590

Lat: 44.3690N

Lon: 135.8344E

Elev: 111

StdP: 14.64

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-0.5	-22.6	1.6	0.6	-19.5	1.9	2.9	25.8	5.8	23.8	6.3	9.6	270	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	79.7	67.5	75.8	66.4	72.6	65.0	70.5	75.2	68.7	73.1	67.1	71.0	5.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	106.9	72.5	67.2	100.4	70.7	65.6	95.0	69.1	34.6	75.5	33.1	73.4	31.8	71.1	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	16.8	14.4	DB	-10.5	87.7	4.3	3.6	-13.6	90.3	-16.1	92.3	-18.5	94.3	-21.6	96.9	(4)
(5)			WB	-11.2	73.6	4.1	2.1	-14.1	75.2	-16.5	76.4	-18.8	77.6	-21.8	79.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.2	13.3	18.4	28.6	39.2	46.9	53.9	62.3	66.4	59.2	46.2	30.0	16.6	(6)	
	DBStd	18.91	7.09	7.21	6.61	5.31	6.02	5.24	4.86	4.57	5.42	6.37	8.96	7.71	(7)	
	HDD50	4959	1137	884	665	329	137	16	0	0	3	153	601	1034	(8)	
	HDD65	9178	1602	1304	1130	775	562	338	112	36	185	584	1051	1499	(9)	
	CDD50	1380	0	0	0	4	40	132	382	508	280	34	0	0	(10)	
	CDD65	126	0	0	0	0	1	4	29	80	12	0	0	0	(11)	
	CDH74	530	0	0	0	0	16	43	137	281	51	2	0	0	(12)	
	CDH80	101	0	0	0	0	4	13	28	49	7	0	0	0	(13)	
(14) Wind	WSAvg	5.9	9.1	7.5	6.4	5.5	5.1	4.2	3.8	4.0	4.9	5.8	6.9	8.1	(14)	
(15) Precipitation	PrecAvg	30.2	0.7	0.6	1.1	2.0	3.3	3.6	4.9	4.7	4.3	2.7	1.5	0.9	(15)	
	PrecMax	46.1	3.1	1.9	3.5	5.9	7.1	12.8	20.8	8.6	11.7	10.7	4.7	2.5	(16)	
	PrecMin	16.8	0.0	0.0	0.0	0.1	0.1	1.1	1.2	1.7	0.4	0.2	0.1	0.0	(17)	
	PrecStd	6.6	0.7	0.6	0.9	1.4	1.7	2.6	3.6	1.9	3.2	2.0	1.1	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	42.6	52.8	64.8	75.2	80.0	84.0	85.2	79.7	68.3	55.7	40.6	(19)	
		MCWB	27.8	33.3	39.9	47.9	54.6	63.4	69.6	69.6	64.8	54.6	44.6	34.8	(20)	
	2%	DB	30.9	36.6	46.1	57.2	67.4	70.5	77.7	80.4	74.4	63.1	50.9	35.6	(21)	
		MCWB	26.6	29.5	36.1	44.1	52.3	60.5	67.5	69.1	62.4	52.7	42.9	30.4	(22)	
	5%	DB	28.0	33.1	41.8	52.4	61.7	64.8	72.7	76.9	71.2	60.1	47.4	32.5	(23)	
		MCWB	23.7	27.8	33.6	41.7	49.7	58.2	66.1	68.1	61.0	51.4	41.1	28.0	(24)	
	10%	DB	25.1	30.3	38.3	48.5	56.5	61.0	68.9	73.8	68.5	57.3	44.1	29.1	(25)	
		MCWB	21.1	25.9	31.7	39.5	48.1	56.6	64.9	67.3	60.3	49.9	38.9	24.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.1	33.8	41.3	49.3	57.5	65.4	71.3	73.5	68.9	58.3	48.2	36.0	(27)	
		MCDB	32.0	39.5	50.7	61.6	72.5	75.6	79.3	79.6	74.3	63.0	51.7	39.1	(28)	
	2%	WB	27.0	30.8	37.0	44.9	53.5	61.8	68.6	71.4	66.1	55.8	44.7	31.3	(29)	
		MCDB	30.5	34.8	44.7	54.7	63.2	68.5	74.4	75.6	70.3	60.5	49.0	34.9	(30)	
	5%	WB	23.8	28.5	34.6	42.7	51.2	59.2	66.9	70.0	64.2	53.6	42.0	28.0	(31)	
		MCDB	27.8	32.7	39.8	50.3	58.7	63.8	70.9	74.2	68.0	57.7	47.0	32.5	(32)	
	10%	WB	21.0	25.9	32.8	40.8	49.2	56.9	65.4	68.6	62.6	51.3	38.7	24.9	(33)	
		MCDB	25.1	30.3	37.0	46.4	55.1	60.3	68.5	72.4	66.8	55.8	44.1	29.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	17.0	15.4	14.5	12.3	9.7	8.6	10.8	16.9	18.1	16.3	15.1	(35)	
		MCDBR	19.2	20.1	20.8	22.6	23.6	19.3	17.5	16.7	20.3	22.1	21.0	19.3	(36)	
		MCWBR	16.1	15.8	13.6	12.7	11.0	10.4	8.7	8.1	10.5	14.1	15.3	15.9	(37)	
	5% WB	MCDBR	19.1	19.8	18.5	20.2	19.4	16.2	13.7	12.7	14.8	18.8	20.0	19.3	(38)	
		MCWBR	16.6	16.3	13.0	12.1	10.3	9.8	7.7	7.3	9.8	14.0	15.7	16.3	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.310	0.372	0.445	0.539	0.566	0.542	0.503	0.465	0.413	0.418	0.370	0.328	(40)	
	taud		2.224	2.037	1.895	1.757	1.776	1.924	2.106	2.219	2.281	2.104	2.147	2.155	(41)	
	Ebn at Noon		250	249	245	232	231	237	246	251	255	230	221	226	(42)	
	Edh at Noon		28	41	54	68	68	59	49	42	36	38	30	27	(43)	
(44) All-Sky Solar Radiation	RadAvg		666	980	1309	1467	1546	1561	1442	1419	1306	970	666	540	(44)	
	RadStd		43	61	92	144	154	211	163	118	115	79	56	35	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page