

POS'ET, Russian Federation

WMO: 319690

Lat: 42.6511N

Lon: 130.8040E

Elev: 128

StdP: 14.63

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.0	3.9	-18.7	2.0	5.8	-14.9	2.5	7.2	37.3	12.5	34.8	8.0	16.6	270	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	81.8	71.9	79.2	71.0	76.8	69.9	74.8	78.7	73.4	76.7	71.9	75.0	6.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.7	126.2	76.9	72.2	119.8	75.4	70.8	113.9	74.0	38.6	78.7	37.2	77.0	35.8	75.0	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.0	24.4	21.1	-3.0	87.8	3.7	3.0	-5.7	90.0	-7.9	91.7	-10.0	93.4	-12.7	95.6
			-4.2	77.1	3.6	1.6	-6.8	78.2	-9.0	79.1	-11.0	79.9	-13.6	81.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	16.1	21.9	32.5	44.6	53.0	60.4	68.2	71.0	63.7	51.0	34.3	19.7
	DBStd	19.73	6.51	7.27	6.72	5.81	5.75	5.81	5.43	4.21	4.86	6.44	8.71	7.32
	HDD50	4075	1052	788	542	180	33	1	0	0	0	66	473	940
	HDD65	7749	1517	1208	1007	611	372	161	30	3	80	433	922	1405
	CDD50	2185	0	0	0	19	128	313	563	652	410	99	1	0
	CDD65	383	0	0	0	0	1	23	128	191	40	0	0	0
	CDH74	1254	0	0	0	1	7	98	432	632	84	0	0	0
	CDH80	180	0	0	0	0	0	16	68	88	8	0	0	0
(14) Wind	WSAvg	7.9	11.6	9.5	8.8	7.9	6.8	5.8	5.4	5.7	6.1	7.6	9.2	11.0
(15) Precipitation	PrecAvg	30.9	0.4	0.4	0.7	1.9	3.5	4.2	6.5	5.8	3.7	2.1	1.1	0.6
	PrecMax	43.5	3.3	1.7	3.1	4.9	8.0	8.9	14.8	17.4	11.9	7.0	3.6	2.4
	PrecMin	19.0	0.0	0.0	0.0	0.1	0.2	1.2	1.4	0.5	0.2	0.1	0.0	0.0
	PrecStd	6.6	0.7	0.5	0.7	1.2	2.0	2.0	3.5	3.4	3.1	1.7	0.9	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	43.6	54.0	68.8	74.0	81.9	86.0	86.4	80.9	69.9	57.2	39.8
		MCWB	30.5	35.0	41.7	51.6	57.9	68.3	75.0	74.0	68.6	57.2	47.7	33.9
	2%	DB	31.3	38.8	48.9	61.9	69.1	76.4	81.5	82.2	76.1	66.0	53.0	36.4
		MCWB	27.3	32.3	38.6	48.2	56.1	65.3	73.5	71.6	65.5	56.8	46.0	31.9
	5%	DB	28.5	35.6	45.2	57.5	65.5	72.3	78.6	79.7	73.5	63.0	49.6	33.2
		MCWB	24.3	30.7	36.5	46.2	54.5	63.7	72.1	71.3	64.8	55.8	43.1	28.9
	10%	DB	25.8	32.8	42.1	53.9	62.1	68.6	75.7	77.4	71.2	60.7	46.3	30.1
		MCWB	22.1	28.7	35.0	44.2	53.0	62.8	71.0	70.9	63.9	54.4	41.0	26.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.0	36.7	43.0	54.0	61.4	70.2	77.2	77.1	72.0	62.9	51.6	36.4
		MCDB	33.4	40.6	52.1	64.2	70.2	78.9	82.6	81.5	76.4	66.0	53.8	38.0
	2%	WB	27.7	33.7	39.6	50.5	58.1	67.4	74.9	75.2	69.4	60.0	47.3	32.1
		MCDB	30.9	37.3	46.0	58.4	65.5	73.0	79.3	78.8	72.7	62.9	51.7	35.1
	5%	WB	24.6	31.3	37.9	47.8	56.1	65.3	73.3	73.8	67.6	58.0	44.1	29.2
		MCDB	28.0	35.1	43.1	55.0	62.4	70.1	77.1	77.0	71.0	61.4	48.6	32.8
	10%	WB	22.1	28.9	36.0	45.6	54.5	63.6	71.7	72.6	66.0	55.7	41.2	26.4
		MCDB	25.8	32.8	40.5	51.8	59.8	67.5	74.9	75.5	69.5	59.3	45.7	30.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	14.2	13.8	13.8	12.3	10.1	8.3	9.7	13.5	14.3	12.7	11.5
		MCDBR	15.3	16.5	17.5	20.4	19.6	18.3	13.6	13.7	15.3	16.2	16.6	14.4
		MCWBR	12.9	12.2	10.6	10.4	9.3	9.1	7.1	6.6	7.9	10.0	12.0	11.7
	5% WB	MCDBR	15.3	15.5	15.5	18.2	16.7	15.2	12.0	10.3	10.9	13.3	15.7	13.9
		MCWBR	13.3	11.9	10.4	10.7	9.1	8.4	6.8	6.0	7.2	10.0	12.5	12.1
(40) Clear-Sky Solar Irradiance	taub		0.337	0.395	0.471	0.561	0.592	0.582	0.545	0.493	0.438	0.446	0.398	0.350
	taud		2.146	1.997	1.862	1.718	1.726	1.833	1.997	2.138	2.204	2.035	2.067	2.113
	Ebn at Noon		244	245	239	228	226	229	236	245	250	225	215	224
	Edh at Noon		32	44	57	71	72	65	55	46	40	42	35	30
(44) All-Sky Solar Radiation	RadAvg		707	999	1353	1524	1560	1521	1381	1423	1353	1034	704	589
	RadStd		53	64	83	127	168	248	192	125	118	70	66	49

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-4.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page