

POS'ET, Russian Federation

WMO: 319690

Lat: 42.6511N

Lon: 130.8040E

Elev: 39

StdP: 100.86

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -17.2	(c) -15.6	(d) -28.2	(e) 0.3	(f) -14.5	(g) -26.0	(h) 0.4	(i) -13.8	(j) 16.7	(k) -10.8	(l) 15.6	(m) -13.3	(n) 7.4	(o) 270	(p) 0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.4	(c) 27.7	(d) 22.2	(e) 26.2	(f) 21.7	(g) 24.9	(h) 21.0	(i) 23.8	(j) 25.9	(k) 23.0	(l) 24.9	(m) 22.1	(n) 23.9	(o) 2.8	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.0	25.0	22.3	17.1	24.1	21.5	16.3	23.4	71.9	26.0	68.6	25.0	65.5	23.9	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.0	(b) 10.9	(c) 9.4	(e) -19.4	(f) 31.0	(g) 2.1	(h) 1.7	(i) -20.9	(j) 32.2	(k) -22.1	(l) 33.2	(m) -23.3	(n) 34.1	(o) -24.8	(p) 35.3		
(a) 13.0	(b) 10.9	(c) 9.4	(e) -20.1	(f) 25.0	(g) 2.0	(h) 0.9	(i) -21.6	(j) 25.6	(k) -22.8	(l) 26.2	(m) -23.9	(n) 26.6	(o) -25.3	(p) 27.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-8.8	-5.6	0.3	7.0	11.7	15.8	20.1	21.7	17.6	10.6	1.3	-6.8
	DBStd	10.96	3.62	4.04	3.74	3.23	3.19	3.23	3.02	2.34	2.70	3.58	4.84	4.07
	HDD10.0	2264	584	438	301	100	18	1	0	0	0	37	263	522
	HDD18.3	4305	843	671	559	339	207	89	17	2	44	241	512	781
	CDD10.0	1214	0	0	0	11	71	174	313	362	228	55	1	0
	CDD18.3	213	0	0	0	0	1	13	71	106	22	0	0	0
	CDH23.3	697	0	0	0	1	4	54	240	351	47	0	0	0
	CDH26.7	100	0	0	0	0	0	9	38	49	4	0	0	0
Wind	WSAvg	3.5	5.2	4.2	4.0	3.5	3.0	2.6	2.4	2.6	2.7	3.4	4.1	4.9
Precipitation	PrecAvg	786	11	11	17	47	90	107	165	147	94	54	29	14
	PrecMax	1105	83	42	79	124	204	227	376	442	302	177	92	62
	PrecMin	483	0	0	0	3	4	30	35	12	4	2	0	0
	PrecStd	168	19	12	19	30	50	52	88	87	79	44	24	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.8	6.5	12.2	20.5	23.3	27.7	30.0	30.2	27.2	21.0	14.0	4.4
		MCWB	-0.8	1.7	5.4	10.9	14.4	20.2	23.9	23.3	20.3	14.0	8.7	1.0
	2%	DB	-0.4	3.8	9.4	16.6	20.6	24.7	27.5	27.9	24.5	18.9	11.7	2.5
		MCWB	-2.6	0.2	3.7	9.0	13.4	18.5	23.1	22.0	18.6	13.8	7.8	-0.1
	5%	DB	-1.9	2.0	7.3	14.2	18.6	22.4	25.9	26.5	23.1	17.2	9.8	0.7
		MCWB	-4.3	-0.7	2.5	7.9	12.5	17.6	22.3	21.8	18.2	13.2	6.2	-1.7
	10%	DB	-3.4	0.5	5.6	12.2	16.7	20.3	24.3	25.2	21.8	16.0	7.9	-1.0
		MCWB	-5.5	-1.8	1.7	6.8	11.7	17.1	21.6	21.6	17.7	12.5	5.0	-3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.0	2.6	6.1	12.2	16.3	21.2	25.1	25.0	22.2	17.2	10.9	2.4
		MCDB	0.8	4.8	11.1	17.9	21.2	26.1	28.1	27.5	24.7	18.9	12.1	3.3
	2%	WB	-2.4	0.9	4.2	10.3	14.5	19.7	23.9	24.0	20.8	15.5	8.5	0.0
		MCDB	-0.6	2.9	7.8	14.7	18.6	22.8	26.3	26.0	22.6	17.2	11.0	1.7
	5%	WB	-4.1	-0.4	3.3	8.8	13.4	18.5	22.9	23.2	19.8	14.5	6.7	-1.6
		MCDB	-2.2	1.7	6.2	12.8	16.9	21.2	25.1	25.0	21.7	16.3	9.2	0.4
	10%	WB	-5.5	-1.7	2.2	7.6	12.5	17.6	22.1	22.6	18.9	13.2	5.1	-3.1
		MCDB	-3.5	0.5	4.7	11.0	15.5	19.7	23.8	24.2	20.8	15.2	7.6	-1.1
Mean Daily Temperature Range	5% DB	MDBR	7.1	7.9	7.7	7.6	6.8	5.6	4.6	5.4	7.5	8.0	7.1	6.4
		MCDBR	8.5	9.2	9.7	11.3	10.9	10.1	7.6	7.6	8.5	9.0	9.2	8.0
		MCWBR	7.2	6.8	5.9	5.8	5.2	5.1	3.9	3.7	4.4	5.5	6.7	6.5
	5% WB	MCDBR	8.5	8.6	8.6	10.1	9.3	8.4	6.7	5.7	6.1	7.4	8.7	7.7
		MCWBR	7.4	6.6	5.8	5.9	5.0	4.7	3.8	3.3	4.0	5.5	7.0	6.7
Clear-Sky Solar Irradiance	taub	0.337	0.395	0.471	0.561	0.592	0.582	0.545	0.493	0.438	0.446	0.398	0.350	
	taud	2.146	1.997	1.862	1.718	1.726	1.833	1.997	2.138	2.204	2.035	2.067	2.113	
	Ebn at Noon	768	771	755	719	711	721	744	772	787	708	679	705	
	Edh at Noon	100	138	180	224	228	205	173	146	127	132	109	96	
All-Sky Solar Radiation	RadAvg	2.23	3.15	4.26	4.80	4.92	4.79	4.35	4.49	4.27	3.26	2.22	1.86	
	RadStd	0.17	0.20	0.26	0.40	0.53	0.78	0.60	0.39	0.37	0.22	0.21	0.15	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-2.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page