

PARTIZANSK, Russian Federation

WMO: 319870

Lat: 43.1296N

Lon: 133.1090E

Elev: 681

StdP: 14.34

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.4	-2.4	-22.2	1.7	-1.8	-19.2	2.0	0.4	25.6	4.3	23.5	5.3	12.0	0	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	84.1	71.6	81.0	70.1	78.1	68.3	74.3	81.4	72.5	78.1	70.7	75.5	8.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	121.4	78.3	70.6	115.4	76.2	69.0	109.4	74.1	38.4	81.3	36.8	78.4	35.1	75.6	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.5	19.1	17.2	DB	-9.1	89.2	3.6	2.8	-11.7	91.3	-13.8	92.9	-15.9	94.5	-18.5	96.6	(4)
			WB	-10.6	77.0	4.3	2.0	-13.7	78.4	-16.3	79.6	-18.7	80.7	-21.9	82.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	11.5	17.7	29.5	43.9	54.1	61.9	68.9	69.7	60.5	47.3	29.7	14.9	(6)
		DBStd	21.56	7.48	8.03	8.25	6.99	5.97	5.43	4.89	4.61	5.39	7.27	10.04	8.46	(7)
		HDD50	4807	1194	903	637	209	28	0	0	2	137	610	1087		(8)
		HDD65	8517	1659	1323	1101	634	339	122	17	10	153	548	1059	1552	(9)
		CDD50	2107	0	0	0	25	155	358	586	612	316	54	1	0	(10)
		CDD65	345	0	0	0	0	2	30	139	157	17	0	0	0	(11)
		CDH74	1760	0	0	0	4	38	220	713	718	67	0	0	0	(12)
		CDH80	369	0	0	0	0	3	39	177	146	4	0	0	0	(13)
(14)	Wind	WSAvg	7.5	10.2	9.1	8.1	7.9	7.1	6.0	5.6	5.5	5.7	7.0	8.2	9.5	(14)
(15)	Precipitation	PrecAvg	31.5	0.4	0.7	1.3	1.6	3.2	3.0	5.2	5.9	4.6	2.9	1.6	1.1	(15)
(16)		PrecMax	46.6	1.3	2.7	3.0	4.6	6.1	7.1	13.1	11.2	12.1	6.1	3.6	3.1	(16)
(17)		PrecMin	16.0	0.0	0.0	0.0	0.4	0.1	0.7	1.4	0.1	0.7	0.9	0.4	0.2	(17)
(18)		PrecStd	6.4	0.3	0.7	0.8	1.0	1.5	1.7	2.5	2.7	3.1	1.3	0.9	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	33.8	41.4	56.9	72.9	78.0	84.6	89.4	87.9	79.2	70.0	57.6	41.0		(19)
(20)		0.4% MCWB	30.2	33.2	43.3	52.6	59.3	67.4	75.3	74.2	67.7	57.1	48.4	38.4		(20)
(21)		2% DB	29.6	37.0	49.8	66.2	73.6	79.8	84.6	83.8	75.7	65.6	52.5	36.0		(21)
(22)		2% MCWB	25.7	31.6	38.5	49.7	57.0	65.6	72.8	72.3	64.6	54.2	45.2	31.9		(22)
(23)		5% DB	26.5	33.9	45.0	61.1	69.7	75.9	81.2	80.9	72.9	62.2	48.3	31.7		(23)
(24)		5% MCWB	22.5	28.9	36.0	46.8	55.1	64.3	71.1	71.1	63.2	52.6	42.7	27.5		(24)
(25)		10% DB	23.1	30.6	41.0	56.3	66.0	72.2	77.8	78.0	70.2	58.9	44.1	28.1		(25)
(26)		10% MCWB	19.6	26.1	33.7	44.3	53.4	62.7	69.4	69.6	61.5	51.3	38.7	24.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	31.2	36.3	44.0	54.9	61.9	70.8	76.5	76.5	71.0	60.7	50.8	39.0		(27)
(28)		0.4% MCDB	33.4	38.7	55.1	68.1	74.5	80.6	86.3	84.4	76.8	66.1	54.5	40.2		(28)
(29)		2% WB	26.5	32.5	39.9	51.2	59.1	68.0	74.3	74.8	67.9	57.8	47.0	32.6		(29)
(30)		2% MCDB	29.1	35.7	47.2	64.1	70.0	76.2	82.6	81.4	72.2	62.3	50.8	35.0		(30)
(31)		5% WB	22.7	29.4	37.1	48.2	57.0	65.9	72.5	73.1	65.5	55.4	43.0	27.9		(31)
(32)		5% MCDB	26.2	33.6	43.2	59.2	66.5	73.4	79.1	78.1	70.2	59.7	47.7	31.4		(32)
(33)		10% WB	19.5	26.1	34.7	45.5	54.8	63.9	70.5	71.5	63.4	52.8	38.9	24.5		(33)
(34)		10% MCDB	23.1	30.5	40.2	54.3	62.9	70.3	75.7	75.7	68.3	57.3	43.8	28.1		(34)
(35)	Mean Daily Temperature Range	MDBR	15.1	16.4	16.2	18.4	18.5	16.4	13.7	13.8	18.1	18.0	15.1	14.4		(35)
(36)		5% DB MCDBR	18.9	18.5	21.0	26.9	25.6	23.2	20.2	18.1	20.4	21.9	19.9	17.2		(36)
(37)		5% DB MCWBR	15.9	14.0	12.8	14.1	12.2	11.5	10.2	8.5	10.6	13.0	14.3	14.4		(37)
(38)		5% WB MCDBR	18.6	17.6	19.3	24.8	22.5	19.6	17.5	14.7	15.8	18.0	18.6	17.0		(38)
(39)		5% WB MCWBR	16.2	14.1	12.9	14.0	11.9	10.9	9.5	8.0	9.9	12.7	15.0	15.1		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.315	0.378	0.460	0.554	0.573	0.547	0.515	0.471	0.419	0.424	0.377	0.333		(40)
(41)		taud	2.154	1.968	1.832	1.718	1.748	1.897	2.055	2.181	2.247	2.084	2.109	2.100		(41)
(42)		Ebn at Noon	251	248	241	229	230	237	243	251	255	231	222	228		(42)
(43)		Edh at Noon	31	45	58	71	71	61	52	44	38	40	33	30		(43)
(44)	All-Sky Solar Radiation	RadAvg	690	990	1332	1492	1591	1615	1449	1441	1334	993	683	563		(44)
(45)		RadStd	41	65	88	139	149	200	182	130	118	77	62	39		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page