

PARTIZANSK, Russian Federation

WMO: 319870

Lat: 43.1296N

Lon: 133.1090E

Elev: 208

StdP: 98.86

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -20.8	(c) -19.1	(d) -30.1	(e) 0.2	(f) -18.8	(g) -28.4	(h) 0.3	(i) -17.6	(j) 11.4	(k) -15.4	(l) 10.5	(m) -14.8	(n) 5.4	(o) 0	(p) 0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.7	(c) 28.9	(d) 22.0	(e) 27.2	(f) 21.2	(g) 25.6	(h) 20.2	(i) 23.5	(j) 27.4	(k) 22.5	(l) 25.6	(m) 21.5	(n) 24.2	(o) 3.6	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	17.3	25.7	21.4	16.5	24.5	20.6	15.6	23.4	71.4	27.4	67.7	25.8	63.9	24.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.6	8.5	7.7	-22.8	31.8	2.0	1.6	-24.3	32.9	-25.5	33.8	-26.6	34.7	-28.1	35.9
			-23.7	25.0	2.4	1.1	-25.4	25.8	-26.8	26.4	-28.2	27.1	-29.9	27.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-11.4	-7.9	-1.4	6.6	12.3	16.6	20.5	21.0	15.8	8.5	-1.3	-9.5
	DBStd	11.98	4.16	4.46	4.59	3.88	3.31	3.02	2.71	2.56	3.00	4.04	5.58	4.70
	HDD10.0	2671	663	502	354	116	16	0	0	0	1	76	339	604
	HDD18.3	4732	922	735	612	352	188	68	9	6	85	304	588	862
	CDD10.0	1171	0	0	0	14	86	199	326	340	176	30	1	0
	CDD18.3	192	0	0	0	0	1	17	77	87	9	0	0	0
	CDH23.3	978	0	0	0	2	21	122	396	399	37	0	0	0
	CDH26.7	205	0	0	0	0	2	22	98	81	2	0	0	0
Wind	WSAvg	3.3	4.6	4.1	3.6	3.5	3.2	2.7	2.5	2.5	2.6	3.1	3.7	4.2
Precipitation	PrecAvg	801	11	18	33	41	81	77	131	150	117	73	41	27
	PrecMax	1183	33	68	75	118	156	181	333	285	307	156	92	78
	PrecMin	407	1	0	1	9	3	19	36	3	17	23	9	4
	PrecStd	162	8	18	21	25	37	42	64	69	79	32	23	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.0	5.2	13.9	22.7	25.6	29.2	31.9	31.1	26.2	21.1	14.2	5.0
		MCWB	-1.0	0.6	6.3	11.5	15.2	19.7	24.1	23.5	19.8	13.9	9.1	3.5
	2%	DB	-1.3	2.8	9.9	19.0	23.1	26.5	29.2	28.8	24.3	18.7	11.4	2.2
		MCWB	-3.5	-0.2	3.6	9.8	13.9	18.7	22.7	22.4	18.1	12.3	7.3	0.0
	5%	DB	-3.1	1.0	7.2	16.2	20.9	24.4	27.3	27.2	22.7	16.8	9.1	-0.2
		MCWB	-5.3	-1.7	2.2	8.2	12.8	18.0	21.7	21.7	17.3	11.5	6.0	-2.5
	10%	DB	-4.9	-0.8	5.0	13.5	18.9	22.3	25.4	25.5	21.2	15.0	6.7	-2.2
		MCWB	-6.9	-3.3	0.9	6.9	11.9	17.0	20.8	20.9	16.4	10.7	3.7	-4.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.4	2.4	6.7	12.7	16.6	21.5	24.7	24.7	21.7	15.9	10.4	3.9
		MCDB	0.8	3.7	12.8	20.0	23.6	27.0	30.2	29.1	24.9	18.9	12.5	4.5
	2%	WB	-3.1	0.3	4.4	10.6	15.1	20.0	23.5	23.8	20.0	14.4	8.3	0.3
		MCDB	-1.6	2.1	8.4	17.8	21.1	24.5	28.1	27.4	22.3	16.8	10.4	1.7
	5%	WB	-5.2	-1.5	2.8	9.0	13.9	18.8	22.5	22.8	18.6	13.0	6.1	-2.3
		MCDB	-3.2	0.9	6.2	15.1	19.2	23.0	26.1	25.6	21.2	15.4	8.7	-0.3
	10%	WB	-6.9	-3.3	1.5	7.5	12.7	17.7	21.4	21.9	17.4	11.6	3.9	-4.2
		MCDB	-5.0	-0.8	4.6	12.4	17.2	21.3	24.3	24.3	20.2	14.0	6.6	-2.2
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.1	9.0	10.2	10.3	9.1	7.6	7.7	10.0	10.0	8.4	8.0
		MCDBR	10.5	10.3	11.7	15.0	14.2	12.9	11.2	10.0	11.4	12.2	11.1	9.5
		MCWBR	8.9	7.8	7.1	7.8	6.8	6.4	5.6	4.7	5.9	7.2	8.0	8.0
	5% WB	MCDBR	10.3	9.8	10.7	13.8	12.5	10.9	9.7	8.2	8.8	10.0	10.3	9.4
		MCWBR	9.0	7.8	7.2	7.8	6.6	6.1	5.3	4.4	5.5	7.0	8.4	8.4
Clear-Sky Solar Irradiance	taub		0.315	0.378	0.460	0.554	0.573	0.547	0.515	0.471	0.419	0.424	0.377	0.333
	taud		2.154	1.968	1.832	1.718	1.748	1.897	2.055	2.181	2.247	2.084	2.109	2.100
	Ebn at Noon		791	783	761	723	725	747	767	790	804	729	701	718
	Edh at Noon		98	141	184	223	223	192	163	139	121	125	103	95
All-Sky Solar Radiation	RadAvg		2.18	3.12	4.20	4.71	5.02	5.09	4.57	4.54	4.21	3.13	2.15	1.77
	RadStd		0.13	0.20	0.28	0.44	0.47	0.63	0.57	0.41	0.37	0.24	0.20	0.12

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page