

POGIBI, Russian Federation

WMO: 320270

Lat: 52.2250N

Lon: 141.6470E

Elev: 6

StdP: 101.25

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-29.0	-33.2	0.2	-31.0	-30.8	0.2	-28.8	17.7	-13.1	16.3	-15.1	1.6	0	0.808

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	20.9	18.1	19.7	17.5	18.8	16.9	18.9	20.3	18.0	19.3	17.2	18.5	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.2	19.8	17.4	12.4	18.9	16.5	11.8	18.1	54.0	20.3	51.0	19.3	48.5	18.6	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	12.8	10.5	-35.2	23.9	2.8	1.6	-37.2	25.1	-38.8	26.0	-40.4	26.8	-42.4	28.0		
(5)			-35.3	20.0	2.8	1.2	-37.3	20.9	-38.9	21.6	-40.4	22.2	-42.4	23.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.1	-18.9	-18.5	-11.6	-3.0	3.3	10.3	14.8	16.1	12.4	4.1	-6.8	-15.9		
	DBStd	13.18	5.59	5.12	5.21	3.51	2.65	2.40	1.93	1.95	3.01	3.60	5.61	5.43		
	HDD10.0	4492	896	799	669	389	208	25	0	0	13	186	505	802		
	HDD18.3	7082	1154	1032	927	639	467	242	110	73	179	443	755	1060		
	CDD10.0	456	0	0	0	0	0	33	149	189	84	2	0	0		
	CDD18.3	4	0	0	0	0	0	0	1	3	1	0	0	0		
	CDH23.3	2	0	0	0	0	0	0	1	1	1	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	4.4	4.3	3.8	3.7	4.1	4.1	5.0	4.8	4.7	4.6	4.8	4.4	4.5		
(15) Precipitation	PrecAvg	570	30	26	29	33	50	48	61	75	76	68	30	37		
	PrecMax	874	95	76	105	74	105	184	176	175	192	212	88	100		
	PrecMin	275	0	0	3	8	12	4	1	21	11	8	2	9		
	PrecStd	117	26	22	21	18	23	33	45	36	36	38	19	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.9	-2.8	1.5	6.0	12.7	19.5	22.5	22.6	20.7	14.3	5.4	0.1		
		MCWB	-2.3	-3.3	0.6	4.6	9.7	16.0	18.7	19.0	17.8	12.2	4.3	-0.2		
	2%	DB	-5.2	-5.5	-0.4	3.9	10.2	16.6	20.2	21.4	18.9	12.0	3.2	-2.3		
		MCWB	-5.4	-6.0	-1.2	2.5	8.3	13.9	17.3	18.6	16.5	10.2	2.0	-2.7		
	5%	DB	-8.1	-8.1	-1.9	2.5	8.8	15.2	19.0	20.3	17.9	10.5	1.9	-4.7		
		MCWB	-8.4	-8.6	-2.5	1.4	7.2	13.1	16.7	18.1	15.9	8.9	0.9	-5.2		
	10%	DB	-10.8	-10.5	-3.3	1.5	7.5	14.1	18.0	19.4	17.0	9.3	0.6	-7.7		
		MCWB	-11.2	-11.0	-4.0	0.6	6.2	12.4	16.2	17.6	15.3	7.9	-0.3	-8.2		
	0.4%	WB	-2.2	-3.2	0.9	5.1	10.3	16.6	19.2	20.2	18.7	12.4	4.5	-0.2		
		MCDB	-1.9	-2.9	1.3	5.9	11.8	18.8	21.3	21.4	20.2	13.6	5.3	0.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-5.4	-5.9	-1.1	2.7	8.6	14.4	17.8	19.4	17.0	10.6	2.2	-2.6		
		MCDB	-5.2	-5.5	-0.5	3.5	10.1	16.1	19.4	20.6	18.3	11.6	2.9	-2.3		
	5%	WB	-8.4	-8.5	-2.5	1.6	7.4	13.4	17.1	18.6	16.3	9.2	1.0	-5.1		
		MCDB	-8.1	-8.0	-1.9	2.3	8.5	14.9	18.5	19.8	17.6	10.3	1.7	-4.7		
	10%	WB	-11.2	-10.9	-3.9	0.7	6.3	12.6	16.4	17.8	15.5	8.0	-0.2	-8.1		
		MCDB	-10.8	-10.5	-3.3	1.4	7.2	13.9	17.7	19.1	16.9	9.1	0.6	-7.7		
	5% DB	MDBR	7.8	9.7	10.1	7.1	5.0	5.4	4.9	5.2	5.9	5.2	5.6	7.1		
		MCDBR	7.9	10.3	10.4	8.2	7.3	7.8	7.5	6.7	6.7	6.9	5.3	8.0		
		MCWBR	7.9	9.9	9.9	7.5	5.5	5.8	5.3	4.7	5.1	5.6	4.7	7.7		
		MCWBR	8.0	10.0	10.0	7.8	6.7	6.7	6.2	5.6	6.0	6.5	5.2	7.8		
(35) Mean Daily Temperature Range	5% WB	MCWBR	7.9	9.7	9.6	7.2	5.4	5.3	4.8	4.4	4.9	5.7	5.0	7.7		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.307	0.376	0.481	0.527	0.491	0.490	0.438	0.384	0.386	0.337	0.288		
	taud		2.042	2.004	1.852	1.712	1.798	2.023	2.097	2.272	2.358	2.144	2.082	2.027		
	Ebn at Noon		681	778	782	742	733	770	764	788	792	680	596	587		
	Edh at Noon		79	111	160	210	202	163	149	119	97	98	77	68		
(44) All-Sky Solar Radiation	RadAvg		1.23	2.40	3.77	4.57	4.82	5.36	4.80	4.04	3.26	1.99	1.17	0.89		
	RadStd		0.11	0.14	0.27	0.41	0.51	0.58	0.58	0.38	0.28	0.17	0.14	0.11		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+52	N/A

Nomenclature: See separate page