

ALEKSANDROVSK-SAKHALINSKIY, Russian Federation

WMO: 320610

Lat: 50.900N

Lon: 142.167E

Elev: 102

StdP: 14.64

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-11.5	-19.9	1.9	-13.7	-16.5	2.2	-10.8	32.4	13.8	29.0	15.3	6.9	130	0.704

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	73.5	65.0	71.1	63.6	69.0	62.5	67.0	71.1	65.3	69.2	63.7	67.7	10.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.4	94.0	69.6	63.6	88.4	68.0	62.0	83.4	66.4	31.7	71.4	30.4	69.4	29.2	67.8	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.3	22.9	19.6	-20.0	78.7	4.0	2.4	-22.9	80.5	-25.2	81.9	-27.5	83.2	-30.3	84.9		
(5)			-20.3	69.3	4.0	2.4	-23.2	71.0	-25.5	72.4	-27.7	73.8	-30.6	75.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.3	3.8	5.9	17.8	32.0	43.5	52.7	60.1	62.2	55.0	41.5	24.7	10.2		
	DBStd	21.68	9.29	8.55	8.46	6.61	6.12	5.30	4.51	4.48	5.88	6.50	8.71	9.35		
	HDD50	6745	1432	1235	999	540	218	31	0	0	22	275	760	1233		
	HDD65	11255	1897	1655	1464	989	666	369	163	111	303	730	1210	1698		
	CDD50	1001	0	0	0	1	17	112	312	379	170	10	0	0		
	CDD65	37	0	0	0	0	0	0	10	25	2	0	0	0		
	CDH74	54	0	0	0	0	1	2	16	34	1	0	0	0		
	CDH80	1	0	0	0	0	0	0	0	1	0	0	0	0		
	WSAvg	8.7	9.1	8.6	8.9	8.8	7.9	7.0	6.4	7.2	8.8	10.4	11.3	10.3		
	PrecAvg	24.5	1.2	1.1	0.9	1.2	1.9	1.5	2.3	3.2	3.7	3.5	1.9	2.2		
(15) Precipitation	PrecMax	30.2	2.8	2.8	3.0	3.5	3.9	3.2	6.0	8.1	7.8	8.8	3.8	3.7		
	PrecMin	18.9	0.1	0.2	0.2	0.2	0.4	0.1	0.0	0.2	0.9	1.3	0.3	0.7		
	PrecStd	3.1	0.7	0.6	0.6	0.7	0.9	0.8	1.2	1.9	1.3	1.7	0.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	31.8	32.4	39.2	57.5	66.3	72.4	76.2	77.4	72.3	62.3	48.8	36.0			
	0.4% MCWB	29.6	29.3	32.6	45.2	52.0	59.0	64.7	67.9	62.5	53.5	42.8	33.1			
	2% DB	27.5	26.7	35.7	50.4	61.4	68.2	72.6	74.4	69.2	58.1	43.9	31.6			
	2% MCWB	25.9	24.6	31.3	40.5	49.5	57.7	64.2	66.3	60.8	51.4	40.0	30.1			
	5% DB	22.9	23.4	33.0	45.4	57.3	64.8	69.9	72.0	66.9	54.6	39.8	28.3			
	5% MCWB	21.6	21.5	29.4	38.2	47.8	56.1	63.2	65.1	59.8	48.7	36.3	26.7			
	10% DB	17.9	19.6	30.5	41.5	53.8	61.8	67.7	69.8	64.6	51.8	36.5	24.5			
	10% MCWB	16.8	17.9	27.6	36.0	46.4	55.2	62.1	64.1	58.6	46.8	33.4	22.8			
	0.4% WB	29.8	29.4	34.1	46.7	54.8	61.7	67.8	70.5	64.8	55.6	44.2	33.2			
	0.4% MCDB	31.5	32.3	37.2	55.4	62.9	68.0	73.6	75.0	69.0	59.7	47.2	34.8			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	26.0	24.9	31.7	41.6	51.4	59.4	65.7	68.2	62.8	52.2	40.2	30.2			
	2% MCDB	27.6	26.6	34.8	48.4	58.5	65.2	70.1	72.2	67.0	56.8	43.7	31.4			
	5% WB	21.6	21.6	29.8	38.6	49.3	57.5	64.3	66.5	61.1	49.7	36.5	26.8			
	5% MCDB	22.8	23.2	32.7	44.6	55.5	63.1	68.3	70.2	65.4	53.7	39.4	28.3			
	10% WB	16.9	18.0	27.6	36.4	47.3	55.7	62.8	65.0	59.2	47.2	33.8	22.8			
	10% MCDB	17.9	19.7	30.3	40.9	52.6	60.5	66.7	68.7	64.0	51.2	36.1	24.4			
(35) Mean Daily Temperature Range	MDBR	12.3	14.0	13.5	11.0	12.4	12.1	10.7	10.7	12.8	11.0	9.0	10.3			
	5% DB	12.8	14.2	13.1	17.1	18.9	17.7	14.2	12.9	14.9	14.8	12.1	12.2			
	5% WB	12.3	12.8	10.5	10.1	10.3	9.6	7.9	7.4	9.3	10.6	10.3	11.3			
	MCDBR	12.7	13.6	12.2	15.6	15.8	14.8	11.5	10.5	12.9	13.6	11.8	11.8			
	MCWBR	12.2	12.4	10.2	9.8	9.5	8.8	6.9	6.5	9.0	10.6	10.4	11.1			
(40) Clear-Sky Solar Irradiance	taub	0.297	0.331	0.405	0.511	0.553	0.507	0.485	0.447	0.395	0.413	0.371	0.310			
	taud	2.010	1.928	1.802	1.720	1.773	1.992	2.123	2.254	2.328	2.080	2.033	2.021			
	Ebn at Noon	215	240	241	229	227	241	245	249	250	210	182	187			
	Edh at Noon	28	39	55	67	66	54	47	39	32	34	28	23			
(44) All-Sky Solar Radiation	RadAvg	419	782	1185	1408	1536	1689	1533	1295	1067	649	365	289			
	RadStd	35	49	82	137	140	171	176	110	90	56	41	35			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page