

YUZHNO-KURILSK, Russian Federation

WMO: 321650

Lat: 44.0229N

Lon: 145.8630E

Elev: 161

StdP: 14.61

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.8	14.5	1.8	6.1	14.4	4.6	7.0	16.3	38.3	24.1	34.8	24.4	10.1	320	0.684

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	70.3	65.8	68.0	64.6	66.1	63.5	67.4	69.0	65.6	67.0	64.2	65.7	7.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.7	98.7	68.2	65.1	93.4	66.5	63.5	88.3	65.1	32.0	69.2	30.7	67.2	29.5	65.8	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.3	27.2	23.3	DB	9.8	76.6	3.7	4.3	7.1	79.7	4.9	82.2	2.9	84.6	0.2	87.7
			WB	8.2	69.6	3.6	2.9	5.6	71.7	3.5	73.4	1.4	75.0	-1.2	77.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.9	24.6	22.9	28.4	35.6	42.2	48.2	55.7	61.0	59.9	51.7	40.7	30.1
	DBStd	13.84	4.63	5.25	4.77	4.40	4.82	4.30	4.49	4.38	3.77	4.74	6.09	4.94
	HDD50	3918	786	759	671	432	247	83	5	0	0	36	282	617
	HDD65	8469	1251	1179	1136	882	706	504	291	139	159	411	729	1082
	CDD50	945	0	0	0	0	5	29	180	341	297	90	3	0
	CDD65	22	0	0	0	0	0	0	1	15	6	0	0	0
	CDH74	21	0	0	0	0	0	0	1	17	3	0	0	0
	CDH80	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	9.9	12.3	11.5	10.9	9.7	8.5	7.5	6.8	7.3	9.2	11.2	12.0	12.4
Precipitation	PrecAvg	48.7	2.3	1.7	2.7	3.5	5.1	5.0	4.9	4.8	6.7	5.2	4.0	2.8
	PrecMax	63.9	5.2	3.7	5.1	5.9	13.0	9.9	9.5	8.1	16.0	10.9	7.7	4.9
	PrecMin	36.3	1.0	0.4	0.7	1.2	1.8	1.1	1.5	1.7	3.1	0.5	1.0	0.9
	PrecStd	7.1	1.1	0.9	1.2	1.2	2.6	2.3	2.0	2.2	2.7	2.6	1.7	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	36.3	42.9	53.4	61.1	64.8	71.5	76.2	72.6	64.2	55.7	46.2
		MCWB	35.9	33.6	36.7	44.7	51.0	58.4	65.3	68.4	66.4	57.3	53.2	44.7
	2%	DB	34.9	33.7	38.4	47.9	55.5	59.3	67.5	71.3	69.1	61.7	53.8	43.0
		MCWB	33.0	31.7	34.9	41.6	48.8	55.1	64.0	66.8	65.1	57.5	51.2	40.9
	5%	DB	33.2	32.0	36.0	44.2	51.8	56.5	64.2	68.7	67.1	60.1	52.0	40.4
		MCWB	31.1	30.2	33.1	39.4	46.8	53.6	62.0	65.5	63.5	56.4	49.2	38.0
	10%	DB	31.6	30.7	34.3	41.6	49.0	54.0	61.8	66.8	65.5	58.5	50.1	37.7
		MCWB	29.4	28.9	31.8	38.1	45.6	52.0	60.2	64.6	62.2	55.0	47.1	34.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.4	34.6	38.3	45.5	52.9	59.6	66.9	70.4	69.2	61.2	54.6	45.0
		MCDB	37.0	35.4	40.5	51.7	58.0	64.0	69.5	73.7	70.6	62.2	55.2	46.0
	2%	WB	33.4	32.2	35.6	42.4	49.8	55.9	64.5	68.1	66.8	59.1	52.1	41.4
		MCDB	34.3	33.1	37.6	46.2	53.4	58.0	66.9	70.2	67.6	60.4	53.2	42.7
	5%	WB	31.5	30.6	33.8	40.4	47.8	54.1	62.3	66.4	64.9	57.4	49.7	38.5
		MCDB	32.8	31.7	35.4	43.1	50.5	55.9	63.7	67.8	66.2	59.2	51.4	40.2
	10%	WB	29.6	29.2	32.3	38.8	46.2	52.3	60.4	65.0	63.2	55.7	47.4	35.1
		MCDB	31.4	30.6	33.8	41.0	48.5	53.6	61.7	66.4	64.8	58.0	49.8	37.2
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.8	7.3	7.8	7.9	6.3	6.0	5.6	6.3	7.4	7.7	6.6
		MCDBR	8.2	9.0	9.1	13.3	14.2	11.3	11.1	9.4	8.2	8.3	9.9	9.9
		MCWBR	8.4	8.4	7.6	8.7	8.8	7.8	8.0	6.3	6.4	7.7	10.4	11.1
	5% WB	MCDBR	8.2	8.8	8.6	11.7	12.2	9.9	10.2	8.2	6.6	7.2	9.8	10.0
		MCWBR	9.0	8.8	7.7	8.6	8.5	7.4	8.0	6.2	6.2	7.9	11.3	11.8
Clear-Sky Solar Irradiance	taub	0.338	0.371	0.440	0.501	0.512	0.486	0.467	0.452	0.407	0.399	0.382	0.354	
	taud	2.186	2.043	1.906	1.866	1.936	2.114	2.240	2.301	2.371	2.238	2.179	2.148	
	Ebn at Noon	239	250	246	243	245	252	256	256	259	240	220	217	
	Edh at Noon	30	41	54	61	58	49	43	39	34	34	30	28	
All-Sky Solar Radiation	RadAvg	466	769	1138	1415	1476	1508	1404	1266	1123	838	511	390	
	RadStd	37	62	87	105	128	126	142	129	88	42	46	31	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (3 neighbors)		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	-142	N/A	N/A	

Nomenclature: See separate page