

MYS LOPATKA, Russian Federation

WMO: 322130

Lat: **50.8734N**Lon: **156.6660E**Elev: **154**StdP: **14.61**Time Zone: **12.00 (E12)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.7	17.2	7.5	8.1	17.7	9.7	9.1	18.6	61.4	27.5	57.9	27.4	24.5	320	1.094

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	55.3	53.5	54.0	52.7	53.0	52.0	54.2	54.8	53.1	53.7	52.2	52.8	13.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.8	61.9	54.4	52.8	59.6	53.4	51.9	57.7	52.6	22.8	54.8	22.1	53.9	21.6	52.8	62.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 52.4	46.4	41.9	13.1	59.7	1.8	2.2	11.8	61.2	10.7	62.5	9.7	63.7	8.4	65.3		
(5)			11.8	57.6	1.7	2.8	10.6	59.6	9.6	61.3	8.7	62.8	7.5	64.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.2	25.2	24.1	26.1	30.2	35.2	41.4	47.3	50.7	48.9	42.4	33.9	28.3	(6)
(7)		DBStd	9.83	3.84	4.48	3.58	2.64	2.18	2.40	2.43	2.02	2.17	3.35	4.00	4.19	(7)
(8)		HDD50	5091	768	726	742	595	460	257	89	15	45	236	484	674	(8)
(9)		HDD65	10511	1233	1146	1207	1045	925	707	549	443	482	701	934	1139	(9)
(10)		CDD50	55	0	0	0	0	0	0	5	37	13	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	20.2	23.2	24.9	23.7	21.7	18.9	16.5	15.1	14.9	16.4	20.8	22.4	24.1	(14)
(15)	Precipitation	PrecAvg	34.7	2.8	2.1	2.3	2.1	2.3	1.7	2.6	3.5	3.3	4.3	3.5	3.5	(15)
(16)		PrecMax	47.3	7.3	5.6	6.5	7.3	7.4	4.8	9.8	7.2	8.1	8.3	7.8	6.7	(16)
(17)		PrecMin	19.6	0.5	0.1	0.5	0.2	0.5	0.2	0.3	0.7	0.5	1.8	0.9	1.2	(17)
(18)		PrecStd	6.5	1.7	1.4	1.5	1.4	1.5	1.2	2.0	1.7	1.7	1.7	1.7	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	34.8	34.0	39.6	43.1	49.6	57.2	57.5	56.1	50.1	44.0	39.0	(19)
(20)			MCWB	32.3	33.2	32.8	37.8	40.7	46.5	55.0	55.4	53.7	47.3	43.0	38.3	(20)
(21)		2%	DB	33.0	33.2	32.4	35.0	40.6	47.1	54.3	55.6	54.2	48.7	42.9	37.5	(21)
(22)			MCWB	31.6	32.2	31.5	33.4	38.8	45.2	52.7	54.0	52.3	46.4	42.0	36.3	(22)
(23)		5%	DB	32.0	32.0	31.8	33.9	39.3	45.7	52.2	54.6	53.2	47.6	41.2	35.8	(23)
(24)			MCWB	31.0	31.2	31.0	32.7	38.0	44.2	51.3	53.3	51.6	45.6	40.0	34.4	(24)
(25)		10%	DB	30.8	30.7	31.0	33.1	38.2	44.6	50.9	53.6	52.2	46.6	39.3	34.1	(25)
(26)			MCWB	29.7	29.7	30.1	32.1	37.2	43.6	50.2	52.7	50.8	44.8	38.0	32.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.2	33.4	33.2	38.2	41.5	47.6	55.5	56.5	54.5	48.4	43.7	38.7	(27)
(28)			MCDB	33.5	33.7	33.5	39.7	42.3	48.4	56.8	56.8	55.3	49.2	43.8	38.8	(28)
(29)		2%	WB	32.1	32.6	32.2	34.1	39.4	45.7	53.0	54.6	53.0	47.0	42.1	36.7	(29)
(30)			MCDB	32.5	33.0	32.4	34.5	40.1	46.6	53.7	55.1	53.7	47.8	42.7	37.2	(30)
(31)		5%	WB	31.1	31.5	31.4	33.2	38.3	44.6	51.4	53.7	52.0	46.0	40.4	34.7	(31)
(32)			MCDB	31.8	32.0	31.7	33.6	38.9	45.2	52.0	54.3	52.7	46.9	41.2	35.4	(32)
(33)		10%	WB	29.7	29.8	30.3	32.4	37.4	43.8	50.4	52.9	51.1	45.1	38.3	33.0	(33)
(34)			MCDB	30.7	30.5	30.9	32.8	38.0	44.4	50.8	53.4	51.8	46.1	39.1	33.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	4.2	4.0	3.4	3.8	4.6	4.5	4.4	4.8	4.6	4.4	4.4	(35)
(36)			MCDBR	5.2	4.9	3.9	4.2	5.8	6.4	6.8	5.7	6.1	5.3	6.2	5.7	(36)
(37)			MCWBR	5.4	5.0	4.4	4.2	4.6	4.8	5.6	4.7	5.0	4.7	7.2	5.8	(37)
(38)		5% WB	MCDBR	4.9	4.6	4.1	4.1	5.5	5.6	6.2	5.3	5.9	5.0	6.3	4.6	(38)
(39)			MCWBR	5.4	5.1	4.8	4.1	4.5	4.5	5.4	4.8	5.1	4.8	7.4	5.2	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.332	0.358	0.407	0.458	0.484	0.458	0.454	0.430	0.377	0.392	0.369	0.337	(40)
(41)	taud		2.136	2.096	1.997	1.921	1.942	2.114	2.190	2.265	2.384	2.159	2.094	2.097	(41)	
(42)	Ebn at Noon		206	234	244	246	246	255	254	254	257	219	186	180	(42)	
(43)	Edh at Noon		25	34	45	55	56	48	43	38	31	32	26	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	271	478	826	1171	1343	1490	1366	1208	1000	610	311	210	(44)	
(45)		RadStd	24	58	76	134	148	195	154	114	76	44	28	31	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page