

SEVERO-KURILSK, Russian Federation

WMO: 322150

Lat: 50.6663N

Lon: 156.1189E

Elev: 75

StdP: 14.66

Time Zone: 11.00 (E11)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.9	15.4	2.2	6.2	15.4	5.4	7.3	17.9	39.9	26.8	35.6	27.3	10.0	340	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.8	64.9	54.7	61.7	53.9	59.0	53.1	56.8	61.2	55.3	59.1	54.1	57.4	9.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.8	64.1	58.2	53.5	61.1	56.5	52.3	58.4	55.3	24.4	61.5	23.4	59.2	22.7	57.7	66.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.0	25.6	21.5	DB	11.0	71.6	3.8	2.8	8.2	73.7	6.0	75.3	3.8	76.9	1.1	79.0	(4)
(5)			WB	9.1	60.9	3.3	2.4	6.7	62.7	4.8	64.1	2.9	65.5	0.5	67.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.5	25.3	23.4	26.5	31.5	37.3	44.8	50.5	53.3	51.1	43.1	34.1	27.9	
	DBStd	11.17	4.71	5.47	4.45	3.23	3.76	4.47	3.85	3.05	3.27	3.98	4.42	4.40	
	HDD50	4803	765	744	729	555	393	168	40	5	24	216	478	686	
	HDD65	10045	1230	1164	1194	1005	857	606	450	363	417	680	928	1151	
	CDD50	234	0	0	0	0	1	12	55	108	57	1	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	8.3	10.5	11.4	11.0	9.6	7.0	5.4	4.6	5.2	7.2	8.7	9.5	10.0	
Precipitation	PrecAvg	69.3	4.8	4.9	5.3	4.5	3.9	4.2	6.3	5.7	6.5	8.8	8.7	6.3	
	PrecMax	88.3	8.2	10.6	11.3	17.4	8.5	11.0	14.3	14.3	13.0	14.6	15.4	11.8	
	PrecMin	53.0	2.4	1.7	2.0	1.5	0.6	0.2	0.0	0.9	2.7	4.2	4.1	2.9	
	PrecStd	8.5	1.5	2.4	2.1	3.0	1.9	2.9	4.3	3.6	2.4	2.8	3.0	2.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.6	35.7	37.4	46.7	57.0	68.2	69.6	68.2	65.0	54.8	46.7	40.3	
		MCWB	33.4	32.8	34.1	39.9	45.1	52.7	54.9	56.6	54.3	48.2	43.9	37.8	
	2%	DB	34.9	33.9	34.5	39.1	50.6	61.4	64.1	64.4	61.0	52.4	44.3	38.3	
		MCWB	32.3	31.7	31.7	34.2	42.4	50.3	54.8	55.6	52.9	46.8	41.8	36.0	
	5%	DB	33.3	32.5	33.2	36.7	45.8	56.6	60.0	61.4	58.8	50.7	42.5	36.4	
		MCWB	31.1	30.3	30.9	33.0	40.4	48.0	54.1	55.0	52.3	46.0	40.1	34.0	
	10%	DB	32.1	31.1	32.2	35.2	42.8	52.2	56.6	58.9	56.8	49.1	40.6	34.5	
		MCWB	30.0	28.9	30.3	32.4	38.7	46.2	52.8	54.0	51.2	44.9	37.8	32.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.6	33.8	34.2	40.5	48.0	54.5	59.3	59.9	57.0	50.3	44.7	38.9
			MCDB	35.8	34.7	35.5	46.1	53.4	64.3	65.2	65.1	60.2	52.3	46.0	39.8
2%		WB	32.9	32.2	32.6	35.3	43.1	51.4	56.1	57.4	54.9	48.4	42.4	36.4	
		MCDB	34.2	33.5	33.6	37.4	47.9	60.0	61.0	61.7	58.7	50.9	43.8	38.0	
5%		WB	31.6	30.8	31.7	34.0	41.0	48.9	54.4	55.9	53.5	46.8	40.7	34.3	
		MCDB	33.0	32.2	32.7	35.6	45.2	54.8	58.5	59.4	56.9	49.5	42.3	36.1	
10%		WB	30.2	29.0	30.8	33.1	39.1	47.1	53.0	54.7	52.3	45.4	38.4	32.3	
		MCDB	32.0	30.8	32.1	34.7	42.1	51.2	56.4	57.7	55.4	48.4	40.4	34.1	
Mean Daily Temperature Range		5% DB	MDBR	5.3	5.5	5.8	5.5	7.0	9.7	8.8	8.8	8.8	7.1	5.9	5.4
			MCDBR	5.8	6.0	6.3	8.4	13.8	19.4	16.6	14.7	13.4	9.4	8.5	6.5
	MCWBR		5.6	5.9	6.1	6.1	8.4	10.6	10.0	9.1	8.6	7.1	8.2	6.5	
	5% WB	MCDBR	6.1	6.2	5.7	7.1	12.4	16.0	13.5	11.8	11.4	8.6	8.2	6.4	
		MCWBR	6.4	6.4	5.9	5.8	8.1	9.8	9.1	8.3	8.1	7.5	8.6	6.8	
Clear-Sky Solar Irradiance	taub	0.337	0.364	0.412	0.463	0.488	0.464	0.459	0.435	0.380	0.395	0.375	0.341		
	taud	2.114	2.067	1.972	1.896	1.934	2.099	2.177	2.251	2.376	2.150	2.078	2.076		
	Ebn at Noon	204	232	242	245	245	253	252	252	256	219	184	178		
	Edh at Noon	26	35	46	56	56	48	44	39	31	32	27	23		
All-Sky Solar Radiation	RadAvg	262	468	832	1164	1342	1441	1327	1162	989	611	311	204		
	RadStd	18	48	69	121	148	168	142	111	74	45	24	25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page