

UST'-VOYAMPOLKA, Russian Federation

WMO: 322520

Lat: 58.510N

Lon: 159.175E

Elev: 7

StdP: 101.24

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.9	-30.1	-34.2	0.1	-31.8	-32.4	0.2	-29.9	19.7	-3.4	15.1	-6.0	4.0	140	0.852

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	17.2	14.2	15.7	13.3	14.6	12.7	14.8	16.3	13.8	15.3	12.9	14.2	4.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.1	15.8	13.0	9.3	14.6	12.1	8.8	13.7	41.7	16.3	38.8	15.4	36.5	14.3	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.7	9.9	-33.2	22.0	1.6	2.9	-34.3	24.1	-35.3	25.8	-36.1	27.4	-37.3	29.5		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.0	-16.8	-15.2	-10.9	-4.0	2.4	7.2	10.8	11.6	8.3	1.4	-6.2	-13.4
	DBStd	11.23	8.34	8.15	6.97	4.59	2.68	2.31	2.09	2.11	2.52	3.87	5.63	6.77
	HDD10.0	4491	831	707	647	419	237	89	14	8	62	268	484	725
	HDD18.3	7424	1089	940	906	669	495	335	235	210	301	526	734	983
	CDD10.0	109	0	0	0	0	0	4	38	57	11	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.4	4.8	4.7	4.4	4.2	4.0	3.7	3.4	3.7	4.5	5.0	5.4	5.1
Precipitation	PrecAvg	447	12	10	13	15	19	39	50	77	62	65	53	27
	PrecMax	629	35	28	33	37	56	89	95	175	182	125	120	64
	PrecMin	202	2	0	3	4	1	4	3	12	8	18	21	3
	PrecStd	106	8	8	8	9	14	23	22	47	40	25	24	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	3.6	3.7	5.4	12.9	16.9	20.9	19.5	15.9	11.0	5.1	2.4
		MCWB	0.9	2.4	1.1	2.8	8.9	12.5	15.6	16.5	13.1	6.8	2.2	0.5
	2%	DB	0.8	1.3	1.9	4.0	10.1	13.8	17.2	17.4	13.9	8.6	3.3	0.9
		MCWB	-1.1	-0.4	-0.1	1.8	7.2	10.7	14.2	14.5	12.1	6.5	1.6	-0.6
	5%	DB	-1.1	-0.5	0.6	3.1	8.4	12.2	15.6	16.0	12.9	7.4	2.1	-0.9
		MCWB	-2.7	-1.8	-0.9	1.1	5.8	9.8	13.3	13.6	11.4	5.8	0.9	-2.2
	10%	DB	-3.5	-3.0	-1.2	2.0	6.5	11.1	14.5	15.0	12.1	6.6	0.9	-3.3
		MCWB	-4.7	-3.8	-2.5	0.5	4.5	9.1	12.6	13.2	10.8	5.2	-0.1	-4.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.1	2.9	1.4	3.5	9.6	12.8	16.8	17.4	13.6	8.0	2.8	0.9
		MCDB	2.9	3.5	3.0	4.7	12.3	15.7	19.3	19.1	15.2	9.5	4.7	2.6
	2%	WB	-0.9	-0.3	0.2	2.0	7.6	11.1	14.8	15.2	12.5	6.8	1.8	-0.5
		MCDB	0.5	1.1	1.8	3.5	9.7	13.1	16.4	16.4	13.6	8.2	3.0	0.7
	5%	WB	-2.5	-1.8	-0.9	1.2	5.9	10.1	13.7	14.1	11.7	6.0	1.0	-2.2
		MCDB	-1.0	-0.5	0.7	2.7	7.9	11.9	15.4	15.5	12.7	7.3	2.1	-1.0
	10%	WB	-4.5	-3.7	-2.4	0.5	4.6	9.2	12.7	13.2	10.9	5.2	0.0	-4.2
		MCDB	-3.3	-2.9	-1.2	1.9	6.3	10.8	14.1	14.5	11.9	6.4	0.9	-3.4
Mean Daily Temperature Range	5% DB	MDBR	7.4	7.1	8.2	6.6	5.0	5.2	5.1	5.1	5.4	4.8	5.7	7.4
		MCDBR	8.2	6.7	5.8	6.4	8.9	8.3	7.9	7.6	6.0	5.7	5.8	7.3
		MCWBR	7.3	5.9	5.0	4.9	6.2	5.8	5.5	5.2	4.7	4.6	4.8	6.4
	5% WB	MCDBR	8.1	6.6	6.0	5.6	8.2	7.3	7.1	6.0	5.5	5.1	5.2	7.1
		MCWBR	7.3	5.9	5.5	4.6	6.1	5.4	5.3	4.5	4.5	4.3	4.5	6.5
Clear-Sky Solar Irradiance	taub	0.244	0.282	0.335	0.409	0.458	0.426	0.453	0.427	0.351	0.333	0.286	0.243	
	taud	2.121	2.107	2.008	1.914	1.968	2.203	2.165	2.229	2.437	2.292	2.132	2.052	
	Ebn at Noon	588	733	783	779	769	810	774	766	787	669	507	440	
	Edh at Noon	49	82	122	160	163	131	134	117	81	69	49	37	
All-Sky Solar Radiation	RadAvg	0.46	1.28	2.81	4.14	5.06	5.26	4.88	3.56	2.52	1.26	0.44	0.24	
	RadStd	0.07	0.15	0.24	0.40	0.55	0.59	0.56	0.40	0.23	0.13	0.04	0.02	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page