

MYS MAYACHNNY, Russian Federation

WMO: 325830

Lat: 52.8892N

Lon: 158.7069E

Elev: 367

StdP: 14.50

Time Zone: 12.00 (E12)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.9	7.4	-9.2	3.4	7.7	-4.7	4.3	10.2	35.7	18.2	31.8	21.4	11.4	340	0.741

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	70.2	60.8	67.1	58.9	64.4	57.3	61.8	68.1	59.8	65.8	58.0	63.1	7.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.9	75.3	64.7	57.1	70.4	62.5	55.5	66.4	60.3	27.8	68.1	26.5	66.0	25.3	63.4	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.6	25.3	21.6	DB	-0.7	75.8	5.6	4.1	-4.7	78.7	-8.0	81.1	-11.2	83.3	-15.3	86.3	(4)
(5)			WB	-1.5	64.8	5.6	2.6	-5.5	66.7	-8.8	68.2	-11.9	69.7	-16.0	71.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.8	20.6	20.2	25.8	33.2	40.6	50.4	56.0	57.4	51.9	42.0	30.8	23.2	
	DBStd	14.38	7.67	7.46	5.83	4.01	4.25	5.63	5.29	3.75	4.29	4.53	5.15	6.16	
	HDD50	5043	912	834	751	504	293	61	8	0	28	248	575	829	
	HDD65	9943	1377	1254	1216	954	755	440	285	237	394	712	1025	1294	
	CDD50	580	0	0	0	0	2	72	192	229	84	1	0	0	
	CDD65	7	0	0	0	0	0	1	5	1	0	0	0	0	
	CDH74	20	0	0	0	0	0	2	16	2	0	0	0	0	
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0	
Wind	WSAvg	9.1	10.4	11.4	10.8	9.0	7.1	6.8	6.1	6.7	8.0	9.9	12.0	11.3	
Precipitation	PrecAvg	40.6	3.3	2.6	3.1	3.0	2.1	2.5	2.7	3.6	3.9	5.4	4.8	3.4	
	PrecMax	58.2	6.7	9.3	7.7	7.2	4.4	7.5	7.3	7.6	8.8	15.6	15.4	14.1	
	PrecMin	28.9	0.4	0.4	0.6	0.3	0.5	0.4	0.3	0.7	0.6	0.7	0.7	0.8	
	PrecStd	8.0	1.8	2.0	1.7	1.9	0.9	1.8	1.6	1.9	1.8	3.5	3.3	2.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	37.7	38.4	47.5	59.8	73.2	76.3	72.6	67.0	54.6	44.1	39.2	
		MCWB	32.8	32.6	32.5	38.7	49.4	59.1	63.3	63.3	58.7	48.4	41.4	37.2	
	2%	DB	35.3	34.9	36.0	42.9	54.5	67.2	71.0	69.0	63.0	51.8	41.8	36.4	
		MCWB	31.6	31.3	31.5	36.4	46.2	56.6	61.1	60.9	55.3	45.8	38.8	33.7	
	5%	DB	33.7	32.7	34.5	40.3	50.8	63.1	67.5	66.3	60.6	50.0	39.9	34.5	
		MCWB	30.8	29.8	30.8	34.6	43.9	54.3	59.4	59.1	53.7	45.0	36.8	31.8	
	10%	DB	31.9	30.7	33.2	38.4	47.6	59.7	64.4	63.7	58.2	48.3	38.1	32.5	
		MCWB	29.5	28.1	30.0	33.2	41.7	52.2	57.9	57.6	52.4	43.8	34.8	29.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.1	33.5	33.9	40.6	49.9	60.2	64.8	64.9	60.6	50.2	42.2	38.2
			MCDB	35.6	35.2	35.9	45.4	58.8	70.9	74.4	71.0	64.1	52.5	43.5	39.0
2%		WB	32.4	32.0	32.8	36.9	46.6	57.2	62.0	61.9	56.5	47.6	39.7	34.1	
		MCDB	34.1	34.4	34.8	42.0	53.6	65.1	69.2	67.0	60.9	50.0	41.2	35.6	
5%		WB	31.2	30.3	31.7	35.1	44.1	54.8	60.2	59.9	54.8	46.1	37.4	32.5	
		MCDB	33.4	32.4	33.9	39.1	50.1	62.6	66.7	64.8	58.9	48.6	39.3	34.2	
10%		WB	29.4	28.2	30.5	33.9	42.1	52.7	58.2	58.2	53.3	44.6	35.2	29.9	
		MCDB	32.1	30.7	33.0	37.3	46.8	58.8	63.7	62.6	57.2	47.3	37.7	32.3	
Mean Daily Temperature Range		5% DB	MDBR	7.1	7.8	8.2	8.0	9.4	10.5	9.9	9.2	9.9	7.7	6.6	6.5
			MCDBR	6.7	6.4	7.7	10.7	14.8	16.2	15.3	13.7	12.9	9.7	7.0	7.1
	MCWBR		6.1	5.4	5.6	6.8	8.8	8.7	8.3	7.8	7.4	6.5	6.5	6.7	
	5% WB	MCDBR	6.8	6.7	6.4	9.5	14.1	15.2	14.0	12.5	11.3	8.6	7.2	7.1	
		MCWBR	6.7	6.2	5.6	6.2	8.6	8.6	8.2	7.6	7.0	6.5	7.7	7.3	
Clear-Sky Solar Irradiance	taub	0.304	0.334	0.388	0.440	0.488	0.469	0.471	0.436	0.369	0.358	0.323	0.296		
	taud	2.103	2.070	1.937	1.863	1.870	2.055	2.101	2.210	2.379	2.250	2.156	2.096		
	Ebn at Noon	203	235	244	247	242	250	247	249	255	226	194	180		
	Edh at Noon	23	33	46	57	59	50	47	40	30	27	22	19		
All-Sky Solar Radiation	RadAvg	251	489	867	1314	1500	1603	1524	1295	1041	633	331	207		
	RadStd	32	70	89	149	147	196	142	127	95	63	33	30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+3.10	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page