

MYS MAYACHNNY, Russian Federation

WMO: 325830

Lat: 52.8892N

Lon: 158.7069E

Elev: 112

StdP: 99.99

Time Zone: 12.00 (E12)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.6	-13.6	-22.9	0.5	-13.5	-20.4	0.6	-12.1	16.0	-7.7	14.2	-5.9	5.1	340	0.741

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	21.2	16.0	19.5	15.0	18.0	14.0	16.6	20.1	15.5	18.8	14.5	17.3	3.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.0	10.8	18.2	13.9	10.1	16.9	13.0	9.5	15.7	46.8	20.0	43.7	18.9	41.0	17.5	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.3	9.6	-18.1	24.3	3.1	2.3	-20.4	25.9	-22.2	27.3	-24.0	28.5	-26.3	30.2		
(5)			-18.6	18.2	3.1	1.5	-20.8	19.3	-22.6	20.1	-24.4	21.0	-26.6	22.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-6.3	-6.5	-3.5	0.7	4.8	10.2	13.3	14.1	11.0	5.6	-0.6	-4.9	(6)
(7)		DBStd	7.99	4.26	4.14	3.24	2.23	2.36	3.13	2.94	2.08	2.38	2.52	2.86	3.42	(7)
(8)		HDD10.0	2802	507	463	417	280	163	34	4	0	16	138	319	461	(8)
(9)		HDD18.3	5524	765	697	676	530	419	244	158	132	219	396	569	719	(9)
(10)		CDD10.0	322	0	0	0	0	1	40	107	127	47	1	0	0	(10)
(11)		CDD18.3	4	0	0	0	0	0	1	3	1	0	0	0	0	(11)
(12)		CDH23.3	11	0	0	0	0	0	1	9	1	0	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.1	4.6	5.1	4.8	4.0	3.2	3.0	2.7	3.0	3.6	4.4	5.4	5.1	(14)
(15)	Precipitation	PrecAvg	1030	85	65	79	77	53	64	69	92	100	137	122	87	(15)
(16)		PrecMax	1478	169	236	195	184	112	191	186	194	224	395	392	358	(16)
(17)		PrecMin	733	11	11	15	7	13	10	7	19	14	18	19	20	(17)
(18)		PrecStd	203	45	50	42	47	24	45	40	49	46	89	83	70	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	3.2	3.6	8.6	15.4	22.9	24.6	22.5	19.5	12.6	6.7	4.0	(19)
(20)			MCWB	0.4	0.3	0.3	3.7	9.7	15.1	17.4	17.4	14.8	9.1	5.2	2.9	(20)
(21)		2%	DB	1.8	1.6	2.2	6.0	12.5	19.6	21.7	20.5	17.2	11.0	5.4	2.4	(21)
(22)			MCWB	-0.2	-0.4	-0.3	2.4	7.9	13.7	16.2	16.1	12.9	7.6	3.8	0.9	(22)
(23)		5%	DB	1.0	0.4	1.4	4.6	10.5	17.3	19.7	19.1	15.9	10.0	4.4	1.4	(23)
(24)			MCWB	-0.7	-1.2	-0.7	1.4	6.6	12.4	15.2	15.0	12.1	7.2	2.7	-0.1	(24)
(25)		10%	DB	-0.1	-0.7	0.7	3.6	8.7	15.4	18.0	17.6	14.5	9.0	3.4	0.3	(25)
(26)			MCWB	-1.4	-2.1	-1.1	0.7	5.4	11.2	14.4	14.2	11.4	6.6	1.6	-1.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.2	0.8	1.0	4.8	9.9	15.6	18.2	18.3	15.9	10.1	5.7	3.4	(27)
(28)			MCDB	2.0	1.8	2.2	7.5	14.9	21.6	23.6	21.6	17.8	11.4	6.4	3.9	(28)
(29)		2%	WB	0.2	0.0	0.4	2.7	8.1	14.0	16.7	16.6	13.6	8.6	4.3	1.2	(29)
(30)			MCDB	1.2	1.3	1.6	5.6	12.0	18.4	20.6	19.5	16.0	10.0	5.1	2.0	(30)
(31)		5%	WB	-0.4	-1.0	-0.2	1.7	6.7	12.7	15.7	15.5	12.7	7.9	3.0	0.3	(31)
(32)			MCDB	0.8	0.2	1.0	4.0	10.1	17.0	19.3	18.2	14.9	9.2	4.1	1.2	(32)
(33)		10%	WB	-1.4	-2.1	-0.9	1.1	5.6	11.5	14.6	14.6	11.8	7.0	1.8	-1.1	(33)
(34)			MCDB	0.1	-0.7	0.5	3.0	8.2	14.9	17.6	17.0	14.0	8.5	3.2	0.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	4.3	4.5	4.5	5.2	5.8	5.5	5.1	5.5	4.3	3.7	3.6	(35)
(36)			MCDBR	3.7	3.6	4.3	5.9	8.2	9.0	8.5	7.6	7.2	5.4	3.9	3.9	(36)
(37)			MCWBR	3.4	3.0	3.1	3.8	4.9	4.8	4.6	4.3	4.1	3.6	3.6	3.7	(37)
(38)		5% WB	MCDBR	3.8	3.7	3.6	5.3	7.9	8.4	7.8	6.9	6.3	4.8	4.0	3.9	(38)
(39)			MCWBR	3.7	3.5	3.1	3.5	4.8	4.8	4.6	4.2	3.9	3.6	4.3	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.334	0.388	0.440	0.488	0.469	0.471	0.436	0.369	0.358	0.323	0.296	(40)	
(41)		taud	2.103	2.070	1.937	1.863	1.870	2.055	2.101	2.210	2.379	2.250	2.156	2.096	(41)	
(42)		Ebn at Noon	640	740	769	780	764	788	778	785	805	714	612	569	(42)	
(43)		Edh at Noon	73	103	146	179	187	157	148	126	94	86	69	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.79	1.54	2.73	4.14	4.73	5.05	4.80	4.08	3.28	2.00	1.04	0.65	(44)	
(45)		RadStd	0.10	0.22	0.28	0.47	0.46	0.62	0.45	0.40	0.30	0.20	0.10	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.72	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page