

BREST SHEBRIN, Belarus

WMO: 330080

Lat: 52.108N

Lon: 23.898E

Elev: 468

StdP: 14.45

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.3	7.9	-3.4	4.7	1.6	3.1	6.6	9.3	23.7	37.4	20.6	31.2	3.8	60	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	87.3	67.9	83.9	66.5	80.5	64.9	70.1	81.9	68.4	79.6	66.9	77.1	7.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	98.4	74.4	64.6	92.9	72.9	63.0	87.6	71.4	34.4	82.2	32.9	79.8	31.7	76.9	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.3	14.1	DB	-5.2	92.2	7.4	2.6	-10.5	94.1	-14.9	95.6	-19.1	97.0	-24.5	98.9	(4)
(5)			WB	-5.6	73.3	7.4	2.0	-10.9	74.8	-15.2	76.0	-19.3	77.1	-24.6	78.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	27.1	31.3	36.9	48.6	58.0	63.2	67.9	66.1	56.9	47.1	38.4	30.3		
	DBStd	16.10	10.30	8.57	8.34	7.87	7.25	6.19	5.81	5.89	6.32	7.53	8.29	9.47		
	HDD50	2899	711	522	411	117	13	0	0	0	14	146	355	610		
	HDD65	6600	1176	942	872	493	238	107	35	54	253	556	799	1075		
	CDD50	2075	0	0	4	75	262	397	556	500	220	55	6	0		
	CDD65	300	0	0	0	1	22	53	126	89	9	0	0	0		
	CDH74	2778	0	0	0	26	234	484	1155	802	76	1	0	0		
	CDH80	787	0	0	0	3	40	110	370	253	11	0	0	0		
(14) Wind	WSAvg	6.4	7.1	6.9	7.2	6.6	6.2	6.0	5.8	5.4	5.6	6.0	6.5	7.0		
(15) Precipitation	PrecAvg	23.1	1.4	1.3	1.3	1.5	2.5	2.5	3.2	2.5	2.2	1.6	1.6	1.5		
	PrecMax	30.9	3.2	2.5	2.6	3.3	4.7	6.5	6.5	10.0	5.2	3.9	3.9	3.0		
	PrecMin	16.2	0.2	0.2	0.5	0.1	0.5	0.6	0.2	0.2	0.4	0.1	0.3	0.5		
	PrecStd	3.2	0.7	0.6	0.6	0.7	0.9	1.2	1.7	1.7	1.5	1.1	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	52.0	62.8	77.4	84.4	87.5	91.8	91.6	80.8	71.0	59.9	50.0		
		MCWB	43.9	45.4	50.4	58.3	64.3	68.3	69.4	68.8	63.7	60.8	53.2	47.0		
	2%	DB	43.8	47.9	57.2	71.4	79.9	83.2	87.9	86.4	75.6	65.0	55.5	46.2		
		MCWB	41.3	43.2	47.1	55.3	62.5	66.4	68.2	67.9	62.0	57.0	50.7	44.1		
	5%	DB	41.2	44.9	52.9	66.4	76.2	79.6	84.3	82.2	71.8	61.3	52.0	43.6		
		MCWB	39.1	41.7	44.7	52.7	61.1	64.5	67.1	66.1	60.1	55.2	48.4	41.7		
	10%	DB	38.8	41.9	48.6	62.5	71.9	76.0	80.7	78.0	68.2	58.3	48.9	41.2		
		MCWB	37.2	39.2	43.0	51.0	58.8	62.7	65.7	64.0	58.8	53.3	46.5	39.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	46.5	51.3	59.5	67.4	70.4	72.9	72.5	66.3	61.5	53.9	47.6		
		MCDB	46.4	49.7	60.3	74.5	79.9	82.6	85.7	85.7	76.5	68.6	58.0	49.3		
	2%	WB	41.4	44.0	48.5	56.8	64.5	68.1	70.6	69.6	63.5	58.8	51.4	44.2		
		MCDB	43.2	47.2	55.7	68.4	76.0	80.0	82.1	81.5	72.3	63.7	55.0	45.7		
	5%	WB	39.2	41.8	45.9	54.5	62.3	66.3	68.9	67.5	61.6	56.2	49.0	41.8		
		MCDB	40.6	44.6	51.1	63.8	73.4	76.8	79.9	78.3	69.5	60.4	51.5	43.2		
	10%	WB	37.2	39.3	43.5	52.1	60.1	64.2	67.4	65.8	59.6	53.6	46.7	39.6		
		MCDB	38.5	41.6	47.9	60.3	69.8	72.7	77.5	74.9	66.4	57.6	48.8	41.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	9.0	13.0	17.4	18.7	17.9	18.6	18.6	16.6	13.2	8.2	7.5		
		MCDBR	8.0	11.8	20.4	24.3	24.4	23.2	24.3	24.5	22.9	18.0	12.2	8.9		
	5% WB	MCWBR	7.1	8.9	12.3	11.7	10.7	9.9	8.7	9.5	11.3	10.7	8.7	7.4		
		MCWBR	7.5	10.9	17.6	21.3	22.1	20.2	20.6	20.4	19.5	16.3	10.8	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.308	0.338	0.374	0.425	0.411	0.406	0.436	0.432	0.393	0.361	0.349	0.308		
	taud		2.216	2.188	2.213	2.151	2.255	2.296	2.226	2.231	2.303	2.371	2.285	2.257		
	Ebn at Noon		212	240	256	256	267	269	258	252	247	232	195	192		
	Edh at Noon		22	30	36	43	41	39	42	39	33	25	21	18		
(44) All-Sky Solar Radiation	RadAvg		235	471	866	1300	1656	1763	1668	1467	1012	567	233	157		
	RadStd		39	73	119	155	158	133	167	115	149	103	23	30		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (14 neighbors)		+0.85	N/A	N/A	N/A	+0.99	+1.01	N/A	-270	+144	+58

Nomenclature: See separate page