

BREST SHEBRIN, BelarusWMO: **330080**Lat: **52.108N**Lon: **23.898E**Elev: **143**StdP: **99.62**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.1	-13.4	-19.7	0.7	-16.9	-16.1	0.9	-12.6	10.6	3.0	9.2	-0.4	1.7	60	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	30.7	20.0	28.8	19.1	26.9	18.3	21.2	27.7	20.2	26.4	19.4	25.1	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.1	23.6	18.1	13.3	22.7	17.2	12.5	21.9	62.1	27.9	58.6	26.5	55.8	25.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.3	6.3	-20.7	33.5	4.1	1.4	-23.6	34.5	-26.1	35.3	-28.4	36.1	-31.4	37.1		
			-20.9	23.0	4.1	1.1	-23.8	23.8	-26.2	24.4	-28.5	25.1	-31.5	25.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-2.7	-0.4	2.7	9.2	14.5	17.3	20.0	19.0	13.8	8.4	3.5	-0.9
	DBStd	8.94	5.72	4.76	4.63	4.37	4.03	3.44	3.23	3.27	3.51	4.18	4.60	5.26
	HDD10.0	1611	395	290	228	65	7	0	0	0	8	81	197	339
	HDD18.3	3667	653	523	484	274	132	59	19	30	141	309	444	597
	CDD10.0	1153	0	0	2	42	146	221	309	278	122	31	3	0
	CDD18.3	167	0	0	0	1	12	29	70	49	5	0	0	0
	CDH23.3	1543	0	0	0	14	130	269	642	446	42	1	0	0
	CDH26.7	437	0	0	0	2	22	61	206	141	6	0	0	0
Wind	WSAvg	2.8	3.2	3.1	3.2	2.9	2.8	2.7	2.6	2.4	2.5	2.7	2.9	3.1
Precipitation	PrecAvg	586	35	33	34	39	63	64	81	64	56	40	40	37
	PrecMax	784	82	64	66	85	119	166	164	255	133	99	98	77
	PrecMin	412	4	4	13	3	13	16	6	6	9	3	7	12
	PrecStd	81	18	15	16	19	24	30	42	44	38	28	17	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	11.1	17.1	25.2	29.1	30.8	33.2	33.1	27.1	21.7	15.5	10.0
		MCWB	6.6	7.4	10.2	14.6	18.0	20.2	20.8	20.5	17.6	16.0	11.8	8.3
	2%	DB	6.5	8.8	14.0	21.9	26.6	28.4	31.0	30.2	24.2	18.3	13.0	7.9
		MCWB	5.2	6.2	8.4	12.9	17.0	19.1	20.1	19.9	16.6	13.9	10.4	6.7
	5%	DB	5.1	7.2	11.6	19.1	24.5	26.5	29.1	27.9	22.1	16.3	11.1	6.4
		MCWB	3.9	5.4	7.1	11.5	16.1	18.1	19.5	18.9	15.6	12.9	9.1	5.4
	10%	DB	3.8	5.5	9.2	16.9	22.2	24.4	27.0	25.6	20.1	14.6	9.4	5.1
		MCWB	2.9	4.0	6.1	10.5	14.9	17.1	18.7	17.8	14.9	11.8	8.1	4.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	8.0	10.7	15.3	19.7	21.3	22.7	22.5	19.1	16.4	12.1	8.7
		MCDB	8.0	9.8	15.7	23.6	26.6	28.1	29.8	29.8	24.7	20.3	14.5	9.6
	2%	WB	5.2	6.7	9.2	13.8	18.1	20.1	21.5	20.9	17.5	14.9	10.8	6.8
		MCDB	6.2	8.5	13.1	20.2	24.5	26.7	27.9	27.5	22.4	17.6	12.8	7.6
	5%	WB	4.0	5.4	7.7	12.5	16.8	19.1	20.5	19.7	16.4	13.5	9.4	5.5
		MCDB	4.8	7.0	10.6	17.7	23.0	24.9	26.6	25.7	20.8	15.8	10.8	6.2
	10%	WB	2.9	4.1	6.4	11.2	15.6	17.9	19.7	18.8	15.4	12.0	8.2	4.2
		MCDB	3.6	5.3	8.8	15.7	21.0	22.6	25.3	23.8	19.1	14.2	9.3	5.0
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.0	7.2	9.7	10.4	9.9	10.3	10.3	9.2	7.3	4.6	4.2
		MCDBR	4.5	6.6	11.3	13.5	13.5	12.9	13.5	13.6	12.7	10.0	6.8	4.9
		MCWBR	3.9	4.9	6.8	6.5	6.0	5.5	4.9	5.3	6.3	5.9	4.8	4.1
	5% WB	MCDBR	4.2	6.1	9.8	11.8	12.3	11.2	11.4	11.4	10.8	9.0	6.0	4.7
		MCWBR	3.9	4.9	6.4	6.1	5.7	5.3	5.0	5.0	5.9	5.8	4.6	4.2
Clear-Sky Solar Irradiance	taub	0.308	0.338	0.374	0.425	0.411	0.406	0.436	0.432	0.393	0.361	0.349	0.308	
	taud	2.216	2.188	2.213	2.151	2.255	2.296	2.226	2.231	2.303	2.371	2.285	2.257	
	Ebn at Noon	669	757	806	807	841	849	813	793	780	732	616	604	
	Edh at Noon	69	95	113	135	128	124	131	124	103	79	66	57	
All-Sky Solar Radiation	RadAvg	0.74	1.48	2.73	4.10	5.22	5.56	5.26	4.63	3.19	1.79	0.74	0.49	
	RadStd	0.12	0.23	0.38	0.49	0.50	0.42	0.53	0.36	0.47	0.33	0.07	0.09	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.47	N/A	N/A	N/A	+0.55	+0.56	N/A	-150	+80	+32

Nomenclature: See separate page