

PINSK, Belarus

WMO: 330190

Lat: 52.122N

Lon: 26.112E

Elev: 142

StdP: 99.63

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-14.8	-21.0	0.6	-17.6	-17.8	0.8	-14.4	7.3	3.2	6.5	1.9	1.5	10	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	30.0	20.6	28.3	20.0	26.6	19.1	22.0	28.2	20.9	26.7	19.9	25.2	2.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	14.9	25.3	18.7	13.7	24.0	17.7	12.9	23.0	65.1	28.2	60.9	26.6	57.4	25.2	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.0	5.0	4.3	DB	-22.0	32.2	3.1	1.6	-24.2	33.3	-26.0	34.3	-27.7	35.1	-30.0	36.3	
			WB	-22.2	23.5	3.0	1.4	-24.4	24.5	-26.2	25.3	-27.8	26.0	-30.0	27.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-3.4	-2.1	2.3	9.3	14.4	17.4	19.9	18.6	13.4	7.9	2.9	-1.7
	DBStd	9.28	5.78	5.54	4.60	4.40	4.21	3.47	3.27	3.08	3.40	4.14	4.66	5.38
	HDD10.0	1749	417	339	241	64	9	0	0	0	8	91	217	364
	HDD18.3	3826	675	572	498	272	135	59	22	33	151	323	464	622
	CDD10.0	1126	0	0	2	43	146	221	306	267	112	26	2	0
	CDD18.3	158	0	0	0	1	13	31	69	42	3	0	0	0
	CDH23.3	1355	0	0	0	12	142	263	584	328	26	1	0	0
CDH26.7	342	0	0	0	2	29	56	169	85	2	0	0	0	
Wind	WSAvg	2.1	2.3	2.4	2.5	2.3	2.1	2.0	1.9	1.8	1.8	2.0	2.2	2.2
Precipitation	PrecAvg	575	32	28	30	38	54	77	77	57	54	50	44	39
	PrecMax	740	104	80	73	116	116	173	169	151	137	136	116	78
	PrecMin	303	7	4	1	9	14	24	11	4	9	2	14	5
	PrecStd	82	20	15	17	20	24	36	41	33	28	35	21	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	10.2	16.4	25.0	29.6	30.7	32.4	31.8	26.2	21.5	15.0	9.2
		MCWB	5.8	7.1	9.9	15.4	19.3	21.1	22.3	22.3	18.7	16.3	11.7	8.1
	2%	DB	6.0	7.6	13.5	21.5	27.0	28.4	30.4	29.1	23.5	18.2	12.3	7.3
		MCWB	4.5	5.4	8.1	13.7	18.0	20.0	21.0	20.5	17.2	13.8	10.5	6.1
	5%	DB	4.6	5.9	11.0	19.0	24.6	26.6	28.6	26.7	21.5	16.0	10.4	5.8
		MCWB	3.4	4.2	6.9	12.1	16.8	18.7	20.4	19.6	15.7	12.7	8.9	4.9
	10%	DB	3.0	4.3	8.8	16.7	22.4	24.5	26.8	24.8	19.6	14.1	8.9	4.4
		MCWB	2.1	3.0	5.8	11.0	15.4	17.8	19.7	18.2	14.7	11.4	7.7	3.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	7.6	10.6	16.5	20.5	22.2	23.8	24.2	19.9	16.8	12.2	8.3
		MCDB	7.4	9.7	14.8	24.3	28.1	29.1	29.6	30.1	24.4	20.9	14.1	9.0
	2%	WB	4.7	5.8	8.7	14.3	18.7	20.7	22.3	21.7	17.6	14.7	10.7	6.3
		MCDB	5.7	7.2	12.5	20.1	25.0	26.9	28.5	27.5	22.4	17.3	12.3	7.1
	5%	WB	3.4	4.4	7.3	12.9	17.3	19.6	21.1	20.3	16.4	13.0	9.1	5.0
		MCDB	4.3	5.7	10.4	17.9	23.4	25.2	26.9	25.3	20.2	15.2	10.3	5.8
	10%	WB	2.2	3.1	6.0	11.5	16.1	18.4	20.2	19.0	15.3	11.6	7.8	3.7
		MCDB	3.0	4.3	8.6	15.9	21.4	23.1	25.6	23.5	18.7	14.0	8.8	4.3
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.2	7.0	9.3	10.3	9.7	9.8	9.9	9.0	7.3	4.5	4.2
		MCDBR	4.5	6.3	10.9	13.0	13.8	12.8	12.5	12.9	12.2	10.4	7.0	5.0
		MCWBR	3.9	5.0	6.7	6.7	6.4	6.0	5.3	6.1	6.6	6.5	5.2	4.4
	5% WB	MCDBR	4.3	6.0	9.8	11.5	12.3	11.4	11.2	11.6	10.3	9.2	6.3	4.8
		MCWBR	3.8	5.0	6.3	6.2	6.2	5.9	5.5	6.4	6.4	6.2	5.0	4.4
Clear-Sky Solar Irradiance	taub	0.304	0.340	0.372	0.423	0.412	0.401	0.431	0.429	0.396	0.359	0.344	0.306	
	taud	2.198	2.154	2.196	2.165	2.264	2.318	2.243	2.243	2.292	2.375	2.289	2.246	
	Ebn at Noon	672	751	807	809	841	853	817	795	777	735	622	604	
	Edh at Noon	70	98	114	134	127	122	129	123	104	79	65	57	
All-Sky Solar Radiation	RadAvg	0.76	1.53	2.81	4.16	5.28	5.68	5.38	4.72	3.21	1.78	0.72	0.51	
	RadStd	0.12	0.26	0.39	0.44	0.49	0.40	0.47	0.37	0.43	0.33	0.07	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+1.14	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.53	N/A	N/A	N/A	+0.59	+0.57	N/A	-158	+95	+38

Nomenclature: See separate page