

SHEPETIVKA, Ukraine

WMO: 333170

Lat: 50.1614N

Lon: 27.0369E

Elev: 278

StdP: 98.03

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-14.9	-20.4	0.6	-17.8	-17.4	0.8	-14.5	14.7	0.4	10.5	-0.9	2.1	90	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	29.7	21.0	28.1	19.9	26.6	19.0	21.9	27.8	20.9	26.5	19.9	25.0	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	15.1	24.8	19.0	14.3	23.5	18.1	13.5	22.3	65.2	27.7	61.6	26.5	58.3	25.1	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.7	7.4	6.2	DB	-21.6	32.1	3.6	1.7	-24.1	33.3	-26.2	34.3	-28.2	35.2	-30.8	36.4
			WB	-21.8	23.3	3.5	1.4	-24.3	24.3	-26.4	25.1	-28.4	25.8	-30.9	26.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-3.9	-2.6	1.9	9.1	14.6	17.6	19.4	18.7	13.8	8.2	2.9	-2.1	(6)
(7)		DBStd	9.46	5.62	5.63	4.77	4.32	4.07	3.44	3.12	3.35	3.92	4.40	4.76	5.20	(7)
(8)		HDD10.0	1802	431	353	253	66	8	0	0	0	10	88	218	375	(8)
(9)		HDD18.3	3863	689	587	510	277	128	55	25	36	143	315	464	633	(9)
(10)		CDD10.0	1142	0	0	1	39	150	229	292	271	125	32	3	0	(10)
(11)		CDD18.3	161	0	0	0	1	12	33	59	48	8	0	0	0	(11)
(12)		CDH23.3	1375	0	0	0	10	123	257	487	425	72	1	0	0	(12)
(13)		CDH26.7	319	0	0	0	1	18	43	125	119	13	0	0	0	(13)
(14)	Wind	WSAvg	2.7	3.2	3.3	3.3	3.0	2.6	2.3	2.0	2.3	2.7	3.1	3.1	(14)	
(15)	Precipitation	PrecAvg	712	42	34	34	54	68	99	112	73	60	42	45	49	(15)
(16)		PrecMax	1038	127	68	83	120	193	244	232	209	184	122	140	92	(16)
(17)		PrecMin	428	8	3	0	7	22	12	10	12	7	3	9	4	(17)
(18)		PrecStd	139	27	17	23	32	35	54	51	40	41	30	27	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	10.1	16.3	24.6	28.8	29.7	31.7	32.2	28.3	22.5	15.9	9.2	(19)
(20)		MCWB	5.8	7.4	10.3	15.4	19.0	21.1	22.1	21.8	18.5	15.8	11.8	7.7	(20)	
(21)		2%	DB	5.3	7.2	13.0	21.0	26.6	27.9	29.9	29.7	25.4	19.5	12.8	7.2	(21)
(22)		MCWB	4.1	5.3	8.3	13.5	17.6	19.8	21.5	20.8	17.2	14.3	10.5	6.1	(22)	
(23)		5%	DB	3.7	5.3	10.6	18.7	24.4	26.3	27.9	27.7	22.9	16.6	10.9	5.5	(23)
(24)		MCWB	2.8	4.0	6.9	12.2	16.6	19.0	20.3	19.6	16.5	12.7	9.4	4.6	(24)	
(25)		10%	DB	2.4	3.7	8.3	16.5	22.2	24.6	26.1	25.7	20.6	14.3	9.2	3.7	(25)
(26)		MCWB	1.6	2.5	5.6	10.9	15.5	18.2	19.5	18.7	15.3	11.5	8.0	2.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	7.9	10.7	17.3	20.1	22.3	23.2	23.5	19.9	16.7	12.3	8.2	(27)
(28)		MCDWB	7.2	9.9	15.2	22.7	27.1	27.9	30.1	28.6	26.8	21.4	14.8	8.9	(28)	
(29)		2%	WB	4.3	5.6	8.7	14.1	18.5	21.0	22.0	21.6	18.2	14.7	10.9	6.2	(29)
(30)		MCDWB	5.1	7.1	12.3	19.8	24.7	26.4	27.9	27.7	23.1	18.3	12.6	7.0	(30)	
(31)		5%	WB	2.8	4.1	7.2	12.7	17.4	19.9	21.1	20.5	17.0	13.3	9.4	4.7	(31)
(32)		MCDWB	3.5	5.2	10.0	17.8	22.9	24.6	26.5	26.0	21.3	16.1	10.7	5.4	(32)	
(33)		10%	WB	1.7	2.6	5.9	11.5	16.2	18.8	20.1	19.4	15.8	11.8	8.1	3.1	(33)
(34)		MCDWB	2.2	3.5	8.1	15.5	20.9	23.3	25.0	24.3	19.7	13.9	9.2	3.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.5	5.3	6.9	9.4	10.4	9.9	10.0	10.4	9.0	7.7	4.9	4.2	(35)	
(36)		5% DB	MCDBR	4.2	6.5	10.6	12.8	13.3	12.0	12.7	13.1	12.8	11.2	8.1	5.3	(36)
(37)		MCWBR	3.6	4.9	6.6	6.6	6.0	5.6	5.5	5.6	6.1	6.3	5.4	4.5	(37)	
(38)		5% WB	MCDWR	4.0	6.2	9.7	11.8	11.9	10.8	11.5	11.7	11.1	10.2	7.3	5.1	(38)
(39)		MCWBR	3.6	4.9	6.4	6.4	5.9	5.7	5.4	5.6	6.0	6.3	5.1	4.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.339	0.376	0.429	0.407	0.403	0.434	0.432	0.396	0.360	0.340	0.306	(40)	
(41)		taud	2.221	2.171	2.188	2.129	2.265	2.295	2.221	2.222	2.278	2.360	2.318	2.279	(41)	
(42)		Ebn at Noon	706	776	816	811	851	856	820	800	789	753	667	655	(42)	
(43)		Edh at Noon	74	100	119	141	128	126	133	127	108	83	68	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.89	1.72	2.90	4.28	5.46	5.80	5.52	4.90	3.38	2.02	0.86	0.61	(44)	
(45)		RadStd	0.16	0.27	0.42	0.45	0.49	0.43	0.43	0.33	0.51	0.32	0.09	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.65	N/A	N/A	+0.71	+0.60	N/A	N/A	-184	+104	+40
(47)	Regional (7 neighbors)	+0.71	N/A	N/A	+0.90	+0.56	+0.44	-139	-210	+123	+50

Nomenclature: See separate page