

LVIV, Ukraine

WMO: 333930

Lat: 49.8075N

Lon: 23.9650E

Elev: 1060

StdP: 14.14

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	7.4	-4.3	4.5	3.7	1.4	6.1	8.4	22.9	32.4	20.8	30.5	4.4	140	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	85.8	68.8	82.4	67.0	79.2	65.3	70.3	81.2	68.4	78.8	67.0	76.7	7.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	101.3	75.6	64.7	95.1	73.1	63.0	89.6	71.2	34.9	81.4	33.3	79.2	32.0	76.8	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.0	17.3	15.4	DB	-5.7	90.1	6.6	2.4	-10.4	91.7	-14.3	93.1	-17.9	94.4	-22.7	96.1	
			WB	-6.3	73.4	6.4	1.7	-10.8	74.6	-14.6	75.6	-18.1	76.6	-22.8	77.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.3	26.5	29.3	36.7	48.6	57.2	63.1	66.5	65.6	56.8	47.6	38.6	29.5
	DBStd	16.13	9.76	9.91	8.50	7.60	6.81	6.00	5.58	5.63	6.46	7.64	8.31	9.12
	HDD50	2991	728	579	416	113	15	0	0	0	14	140	350	636
	HDD65	6722	1193	999	878	493	253	107	50	61	256	541	791	1100
	CDD50	1992	0	0	3	70	240	393	512	484	217	64	9	0
	CDD65	250	0	0	0	1	12	50	96	81	10	0	0	0
	CDH74	2334	0	0	0	18	153	456	856	734	116	1	0	0
	CDH80	560	0	0	0	2	15	88	229	208	18	0	0	0
	WSAvg	6.8	7.7	7.9	8.1	7.3	6.3	6.0	5.6	5.2	5.8	6.9	7.8	7.6
	PrecAvg	29.3	1.7	1.7	1.8	2.0	3.3	3.6	4.0	2.9	2.4	2.0	1.9	2.1
Precipitation	PrecMax	37.1	6.4	4.1	5.5	4.1	8.5	7.1	8.1	6.7	5.7	7.0	4.3	4.2
	PrecMin	16.6	0.3	0.1	0.2	0.4	0.8	0.9	0.4	0.0	0.2	0.1	0.0	0.2
	PrecStd	4.4	1.0	0.9	1.1	0.9	1.5	1.6	1.8	1.5	1.5	1.4	1.0	0.9
	PrecStd	4.4	1.0	0.9	1.1	0.9	1.5	1.6	1.8	1.5	1.5	1.4	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	54.0	63.0	76.4	82.2	86.3	89.4	89.9	82.5	72.7	62.9	51.7
		MCWB	43.3	45.2	49.4	58.8	63.8	69.0	70.3	67.8	64.3	60.0	53.0	45.7
	2%	DB	44.7	48.4	57.6	70.9	78.4	82.5	85.9	85.7	77.1	68.2	57.6	46.4
		MCWB	41.2	43.0	46.7	55.1	61.9	67.3	69.5	68.1	62.9	57.8	50.5	42.9
	5%	DB	41.2	44.6	53.4	66.3	75.0	79.1	82.3	81.9	73.3	64.0	53.8	43.1
		MCWB	38.3	40.6	44.5	52.8	61.0	65.5	67.5	67.0	61.3	55.5	49.1	40.4
	10%	DB	38.6	41.2	48.7	62.4	70.8	75.8	78.9	77.7	69.3	59.2	50.1	40.6
		MCWB	36.2	38.4	42.6	51.0	58.9	63.8	66.1	65.0	59.2	53.4	46.9	38.5
	0.4%	WB	44.2	46.4	50.7	59.6	66.4	71.3	73.2	72.4	67.3	61.6	54.3	46.0
		MCDB	47.0	52.1	60.6	73.8	77.8	81.9	85.0	84.0	78.8	69.4	60.2	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.2	43.4	47.9	56.5	63.9	68.6	70.9	69.7	64.3	59.0	51.7	43.0
		MCDB	43.8	47.7	55.7	67.8	74.5	79.3	81.9	80.2	73.5	66.6	56.8	45.7
	5%	WB	38.5	40.7	45.5	54.1	62.0	66.9	69.0	67.8	62.2	56.5	49.4	40.6
		MCDB	40.8	43.5	51.3	63.7	72.0	76.7	79.5	78.2	70.6	62.7	53.3	42.7
	10%	WB	36.1	38.5	43.3	51.9	60.0	65.0	67.2	66.2	60.2	53.8	47.1	38.3
		MCDB	38.0	41.2	48.1	60.6	69.1	73.9	76.5	75.8	67.1	58.7	50.1	39.9
Mean Daily Temperature Range	5% DB	MDBR	9.9	11.8	14.3	18.1	19.0	18.9	18.7	19.6	17.4	15.7	11.0	9.7
		MCDBR	11.2	15.4	22.4	25.5	25.0	24.3	24.4	25.8	24.8	23.1	17.7	13.5
		MCWBR	8.9	10.9	13.3	12.7	12.2	11.8	10.7	11.4	12.5	13.6	11.5	10.3
	5% WB	MCDBR	10.4	14.2	19.0	22.5	22.6	21.6	21.5	22.6	22.0	21.1	15.6	12.4
		MCWBR	8.7	10.6	12.1	12.0	11.7	11.1	10.3	11.0	12.0	13.0	10.8	9.9
Clear-Sky Solar Irradiance	taub		0.308	0.336	0.379	0.429	0.415	0.415	0.441	0.439	0.399	0.364	0.341	0.306
	taud		2.259	2.221	2.210	2.134	2.237	2.259	2.199	2.204	2.273	2.350	2.343	2.319
	Ebn at Noon		227	250	259	258	268	268	259	252	250	238	214	212
	Edh at Noon		23	31	37	44	42	41	43	41	35	27	22	19
	RadAvg		281	527	885	1311	1626	1743	1683	1527	1056	650	307	206
All-Sky Solar Radiation	RadStd		44	80	113	138	180	132	149	127	158	98	36	31

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.15	N/A	N/A	+1.80	+0.81	N/A	-248	-376	+182	+72
Regional (15 neighbors)		+1.08	N/A	N/A	+1.82	+0.95	+0.88	N/A	-353	+189	+79

Nomenclature: See separate page