

UZHGOROD, Ukraine

WMO: 336310

Lat: 48.6333N

Lon: 22.2611E

Elev: 124

StdP: 99.84

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.2	-10.0	-17.1	0.8	-10.1	-14.4	1.1	-8.0	8.2	-1.2	7.3	-2.0	0.8	310	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	32.0	21.4	30.2	20.7	28.8	19.9	22.5	29.7	21.5	28.4	20.7	27.2	2.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	15.0	26.2	19.1	14.1	24.7	18.2	13.3	23.7	66.5	29.8	63.1	28.3	60.1	27.2	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.8	5.9	DB	-17.2	34.1	3.6	1.6	-19.8	35.2	-21.9	36.1	-24.0	37.0	-26.6	38.1	(4)
(5)			WB	-17.4	23.9	3.6	1.1	-20.0	24.7	-22.1	25.4	-24.1	26.0	-26.8	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-1.3	0.7	5.4	11.7	16.1	19.4	21.2	21.0	16.0	10.6	5.6	0.3		
	DBStd	8.90	4.81	4.69	4.23	4.02	3.60	3.32	3.22	3.08	3.64	4.07	4.39	4.55		
	HDD10.0	1277	349	260	149	28	2	0	0	0	1	43	144	301		
	HDD18.3	3105	608	493	399	201	87	27	10	10	89	241	382	559		
	CDD10.0	1506	0	0	8	78	192	283	348	342	181	61	12	1		
	CDD18.3	292	0	0	0	1	19	59	101	93	18	1	0	0		
	CDH23.3	2796	0	0	0	22	199	545	967	892	168	3	0	0		
	CDH26.7	882	0	0	0	2	35	150	343	315	37	0	0	0		
(14) Wind	WSAvg	2.3	2.1	2.4	2.8	2.9	2.6	2.4	2.2	2.0	2.0	2.0	2.1	2.1		
(15) Precipitation	PrecAvg	729	53	47	45	47	67	82	83	68	61	54	63	67		
	PrecMax	1126	131	117	119	112	144	229	198	159	147	295	186	133		
	PrecMin	438	8	2	0	13	19	8	18	5	2	0	18	4		
	PrecStd	144	25	24	29	23	35	46	38	34	35	52	32	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	13.1	19.0	25.9	29.5	32.0	34.2	34.6	30.2	23.8	18.3	11.9		
		MCWB	7.9	8.4	10.8	15.4	19.0	22.0	21.8	21.2	19.9	15.9	12.4	8.4		
	2%	DB	8.1	10.3	16.4	23.1	27.5	30.1	32.0	32.1	27.2	21.4	15.9	9.8		
		MCWB	6.4	6.8	9.6	13.8	18.2	20.9	21.6	21.2	18.1	15.2	11.4	7.6		
	5%	DB	6.6	8.8	14.2	21.0	25.7	28.2	30.2	30.1	25.1	19.2	13.9	7.8		
		MCWB	5.0	6.0	8.4	12.9	17.2	19.7	20.7	20.8	17.3	14.3	10.5	6.4		
	10%	DB	5.0	7.1	12.1	19.0	23.7	26.7	28.5	28.1	23.0	17.2	12.2	6.1		
		MCWB	3.9	5.0	7.5	11.6	16.3	19.1	19.9	19.6	16.4	13.4	9.5	4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	8.9	11.8	16.4	20.3	23.2	23.6	23.8	20.3	17.3	13.6	9.2		
		MCDB	9.3	11.7	16.6	24.2	27.6	30.3	31.1	30.5	28.1	21.4	16.5	10.7		
	2%	WB	6.8	7.5	10.3	14.8	18.8	21.8	22.5	22.4	19.1	15.9	12.2	7.6		
		MCDB	7.7	9.6	14.7	21.5	25.6	28.4	30.0	29.1	25.5	19.7	15.0	9.2		
	5%	WB	5.1	6.3	9.2	13.6	17.9	20.7	21.5	21.2	18.1	14.9	11.0	6.4		
		MCDB	5.9	8.1	13.2	19.6	24.4	26.9	28.5	28.1	23.5	18.7	13.5	7.6		
	10%	WB	3.8	5.1	8.0	12.5	16.9	19.7	20.7	20.3	17.1	13.7	9.8	5.0		
		MCDB	4.9	6.9	11.6	17.7	22.5	25.3	27.0	27.0	21.9	16.9	11.9	6.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.5	8.7	10.6	11.0	10.9	11.2	11.9	10.5	9.2	6.7	4.7		
		MCDBR	5.6	8.6	12.3	14.2	14.2	13.7	14.0	14.6	14.0	12.4	9.4	6.0		
	5% WB	MCWBR	4.4	5.8	6.9	6.7	6.5	6.1	5.5	5.7	6.3	6.9	5.9	4.6		
		MCWBR	4.6	7.5	10.5	12.7	12.8	12.1	12.7	13.2	12.0	10.6	7.5	5.4		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.348	0.390	0.442	0.430	0.432	0.452	0.448	0.410	0.381	0.358	0.323		
		taud	2.259	2.224	2.203	2.112	2.205	2.234	2.191	2.199	2.269	2.319	2.318	2.310		
	Edn at Noon		716	786	812	804	833	833	808	791	784	741	671	667		
		Edh at Noon	76	99	120	145	137	134	139	132	111	90	73	65		
(44) All-Sky Solar Radiation	RadAvg		0.91	1.70	2.86	4.24	5.16	5.57	5.40	5.01	3.48	2.14	1.12	0.68		
	RadStd		0.16	0.27	0.42	0.46	0.59	0.40	0.53	0.46	0.49	0.33	0.17	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	+0.90	+0.69	+0.67	-130	-194	+88	+41
(47) Regional (37 neighbors)		+0.62	N/A	N/A	+0.97	+0.51	+0.47	-127	-192	+96	+39

Nomenclature: See separate page