

CHERNIVTSI, Ukraine

WMO: 336580

Lat: 48.2664N

Lon: 25.9725E

Elev: 807

StdP: 14.27

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	7.7	-2.3	5.0	3.0	3.4	6.8	8.8	25.8	31.3	22.9	28.3	5.8	110	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.7	87.5	68.8	84.2	67.7	81.1	66.2	71.7	82.1	69.8	80.2	68.1	77.8	7.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	106.1	77.4	66.3	99.8	74.8	64.7	94.2	72.9	35.9	82.3	34.3	80.2	32.9	78.0	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	18.1	16.1	DB	-4.6	92.1	6.6	3.6	-9.3	94.6	-13.1	96.7	-16.8	98.7	-21.6	101.3	(4)
(5)			WB	-4.9	74.8	6.6	2.1	-9.7	76.4	-13.5	77.6	-17.2	78.8	-21.9	80.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.9	26.6	30.1	38.6	50.2	59.8	66.0	69.4	68.2	59.2	48.8	38.9	29.3		
	DBStd	17.02	9.96	10.35	8.89	7.50	6.46	5.68	5.10	5.46	6.39	7.62	8.17	9.49		
	HDD50	2840	725	556	363	85	6	0	0	0	5	115	342	643		
	HDD65	6304	1190	976	819	445	185	57	18	28	194	503	782	1107		
	CDD50	2422	0	0	8	92	309	480	600	564	281	78	10	0		
	CDD65	411	0	0	0	2	22	86	153	128	19	1	0	0		
	CDH74	3380	0	0	0	30	240	675	1189	1035	200	11	0	0		
	CDH80	914	0	0	0	5	34	151	348	336	40	0	0	0		
	WSAvg	7.0	7.0	7.6	8.2	8.2	7.2	6.9	6.5	5.9	6.2	6.5	7.0	6.9		
	PrecAvg	25.7	1.3	1.2	1.3	2.1	2.9	3.7	4.0	2.4	2.1	1.5	1.5	1.5		
(15) Precipitation	PrecMax	35.0	7.2	3.0	5.3	5.4	7.3	10.2	9.1	5.1	6.9	8.1	4.4	3.6		
	PrecMin	15.4	0.0	0.1	0.2	0.4	0.6	0.0	0.9	0.2	0.0	0.1	0.4	0.2		
	PrecStd	5.2	1.2	0.7	0.9	1.1	1.6	2.0	2.2	1.3	1.9	1.4	0.9	0.8		
	PrecStd	5.2	1.2	0.7	0.9	1.1	1.6	2.0	2.2	1.3	1.9	1.4	0.9	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	57.6	66.6	77.6	83.9	87.7	91.4	91.7	84.6	75.1	64.7	53.6		
		MCWB	44.7	46.5	51.3	58.6	64.7	68.7	70.0	68.8	65.3	61.5	53.8	45.3		
	2%	DB	45.9	51.5	60.6	71.6	80.1	84.1	87.5	87.6	79.2	69.3	58.6	48.3		
		MCWB	40.8	44.2	48.8	56.0	62.6	67.7	69.4	68.5	62.5	58.5	51.5	42.9		
	5%	DB	41.7	46.7	55.6	67.7	76.6	81.0	84.0	83.9	75.3	64.3	53.9	43.2		
		MCWB	37.6	41.1	46.3	54.0	61.7	66.4	68.6	67.7	62.0	55.6	49.1	39.9		
	10%	DB	39.0	42.7	51.5	63.4	72.6	78.0	80.6	80.0	71.1	60.2	50.4	40.3		
		MCWB	36.3	38.7	44.1	52.1	60.1	65.2	67.0	66.4	60.3	53.8	46.9	37.8		
	0.4%	WB	45.1	47.8	52.8	60.2	68.3	72.9	74.1	73.6	68.4	63.0	54.9	46.6		
		MCDB	49.8	55.9	63.1	73.7	79.9	81.7	86.6	85.2	80.2	72.9	62.7	52.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.2	44.7	49.7	57.8	64.8	70.0	71.8	71.3	65.0	59.1	52.2	43.2		
		MCDB	44.3	50.4	58.1	69.5	75.4	80.0	82.6	81.9	74.8	66.7	56.9	47.0		
	5%	WB	38.6	41.7	47.1	55.3	62.8	68.1	69.9	69.2	63.0	56.9	49.9	40.5		
		MCDB	41.1	46.0	54.4	64.8	72.9	77.8	80.1	79.7	71.8	62.9	53.4	43.1		
	10%	WB	36.2	39.0	44.7	53.1	61.0	66.5	68.2	67.4	61.2	54.5	47.4	37.9		
		MCDB	38.5	42.3	50.2	61.6	70.2	75.5	77.6	76.8	69.1	59.4	50.4	39.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	11.3	14.2	17.8	18.6	17.3	17.7	18.4	17.0	15.2	10.8	9.3		
		MCDBR	13.3	17.7	22.9	25.1	25.0	22.8	23.5	25.2	25.1	22.3	17.7	14.6		
		MCWBR	10.1	11.9	13.3	12.5	11.2	9.6	9.3	9.4	10.9	12.5	11.4	10.4		
		MCDBR	11.9	16.7	21.1	22.2	21.7	20.0	20.3	21.9	21.3	19.8	15.2	13.3		
	5% WB	MCWBR	9.5	11.8	13.0	12.0	10.9	9.6	9.3	9.8	10.7	11.8	10.5	10.0		
		MCWBR	9.5	11.8	13.0	12.0	10.9	9.6	9.3	9.8	10.7	11.8	10.5	10.0		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.343	0.382	0.440	0.415	0.413	0.442	0.448	0.404	0.368	0.339	0.310		
	taud		2.281	2.234	2.219	2.105	2.248	2.282	2.214	2.192	2.271	2.348	2.369	2.344		
	Ebn at Noon		234	252	261	256	269	270	259	252	252	242	224	221		
	Edh at Noon		24	31	37	46	42	41	43	42	36	28	22	20		
(44) All-Sky Solar Radiation	RadAvg		343	594	956	1357	1698	1797	1770	1596	1123	720	355	257		
	RadStd		49	83	113	135	155	143	140	134	159	98	41	36		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.21	N/A	N/A	+1.84	N/A	N/A	N/A	-410	+274	+112
(47) Regional (25 neighbors)		+1.30	N/A	N/A	+1.69	N/A	N/A	-275	-391	+193	+61

Nomenclature: See separate page