

BALTI, Moldova, Republic ofWMO: **337450**Lat: **47.783N**Lon: **27.950E**Elev: **335**StdP: **14.52**Time Zone: **2.00 (MDA)**Period: **82-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.6	(c) 7.9	(d) -1.6	(e) 5.1	(f) 3.5	(g) 3.2	(h) 6.5	(i) 9.4	(j) 27.8	(k) 31.5	(l) 24.7	(m) 34.2	(n) 5.5	(o) 330	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 22.3	(c) 89.1	(d) 68.3	(e) 86.5	(f) 67.3	(g) 84.0	(h) 67.0	(i) 71.8	(j) 83.1	(k) 70.2	(l) 81.6	(m) 68.9	(n) 79.8	(o) 6.5	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	105.1	75.9	66.6	99.1	74.5	65.1	94.0	73.6	35.7	82.8	34.3	82.0	33.2	79.9	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	19.4	16.3		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				0.4	74.7	10.3	1.6	-7.0	75.9	-13.0	76.8	-18.8	77.7	-26.3	78.9
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	27.7	29.1	38.9	51.2	60.4	67.5	69.7	70.7	61.3	50.2	38.7	31.6		
	DBStd	17.31	9.02	10.65	9.73	6.76	5.88	5.96	5.33	5.51	7.33	8.13	9.28	7.29		
	HDD50	2736	692	585	360	68	4	0	0	0	4	100	352	571		
	HDD65	6065	1157	1005	810	415	163	41	17	15	155	463	788	1036		
	CDD50	2684	0	0	14	103	327	526	610	641	344	105	14	0		
	CDD65	540	0	0	0	0	22	118	162	191	44	3	0	0		
	CDH74	5213	0	0	0	24	262	982	1461	1973	493	18	0	0		
	CDH80	1648	0	0	0	0	38	272	457	752	128	1	0	0		
(14) Wind	WSAvg	6.3	5.8	7.2	7.4	7.1	6.6	5.9	6.0	5.5	5.4	5.9	6.2	6.4		
(15) Precipitation	PrecAvg	21.7	1.0	1.0	1.2	1.8	2.3	2.9	3.1	2.0	2.0	1.7	1.4	1.3		
	PrecMax	29.6	2.5	2.3	3.3	4.3	6.4	6.2	6.7	4.3	7.5	6.8	2.9	4.1		
	PrecMin	14.2	0.4	0.2	0.2	0.1	0.3	0.6	0.8	0.6	0.2	0.1	0.0	0.0		
	PrecStd	4.4	0.6	0.6	0.7	0.9	1.4	1.3	1.8	1.1	1.8	1.4	0.7	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.7	58.5	69.5	77.1	84.1	88.9	91.5	94.9	87.0	76.1	66.3	50.8		
		MCWB	44.4	47.1	53.7	57.3	62.1	69.3	69.5	69.7	64.1	62.4	56.4	46.9		
	2%	DB	44.6	50.2	63.5	73.1	80.1	85.9	87.8	90.4	83.9	71.2	57.5	47.9		
		MCWB	41.4	43.4	51.6	56.2	61.7	68.8	68.6	67.9	64.3	59.2	52.8	45.5		
	5%	DB	41.7	45.2	58.0	68.8	76.7	83.4	85.1	87.6	80.2	67.2	53.9	44.5		
		MCWB	39.2	40.6	48.5	53.7	60.8	68.3	68.0	67.4	62.7	57.3	49.8	41.9		
	10%	DB	39.3	41.5	52.9	64.4	73.5	80.2	82.0	84.4	75.8	63.1	50.7	41.0		
		MCWB	37.3	38.2	45.8	52.2	59.0	67.1	66.7	66.8	62.0	55.8	47.7	38.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.0	48.2	54.7	59.7	67.6	73.7	74.7	72.9	69.1	65.7	57.2	47.9		
		MCDB	49.0	58.1	66.4	72.1	75.4	83.4	86.5	86.5	82.4	72.4	61.8	49.1		
	2%	WB	41.8	43.8	51.9	56.9	64.8	71.1	71.8	71.0	66.4	61.0	53.6	45.5		
		MCDB	44.2	49.0	62.0	69.7	73.9	80.9	82.1	84.7	77.3	68.5	58.1	47.8		
	5%	WB	39.4	40.9	49.3	54.9	62.8	69.6	69.9	69.8	64.5	58.7	50.4	42.1		
		MCDB	41.1	44.9	57.3	66.7	72.2	80.3	79.5	83.2	75.9	65.7	53.1	44.3		
	10%	WB	37.1	38.3	46.6	52.9	60.9	68.1	68.4	68.3	62.7	56.1	47.7	39.1		
		MCDB	39.0	41.3	52.2	63.2	70.5	77.6	78.3	80.4	73.2	62.2	50.4	40.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	12.3	15.3	18.7	19.7	18.7	20.1	22.3	20.7	16.7	11.8	9.3		
		MCDBR	13.1	17.4	24.3	26.0	25.1	22.5	24.8	27.4	26.9	24.2	17.2	13.7		
		MCWBR	10.3	11.5	14.0	12.4	10.7	8.5	9.4	9.3	11.0	12.9	11.3	10.5		
		MCDBR	12.5	16.5	22.6	23.8	21.2	20.0	20.2	24.0	23.5	21.3	14.4	13.2		
	5% WB	MCWBR	10.0	11.3	13.6	11.8	9.9	8.9	9.1	9.8	11.8	12.1	10.0	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.358	0.394	0.452	0.421	0.418	0.449	0.454	0.411	0.378	0.355	0.324		
	taud		2.238	2.197	2.199	2.077	2.242	2.279	2.197	2.174	2.255	2.326	2.317	2.297		
	Ebn at Noon		229	247	258	253	268	269	258	250	250	239	218	215		
	Edh at Noon		25	33	38	48	42	41	44	43	36	29	24	22		
(44) All-Sky Solar Radiation	RadAvg		347	588	981	1420	1818	1918	1890	1702	1185	747	354	264		
	RadStd		56	92	104	128	152	154	128	115	151	93	37	46		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+1.24	N/A	N/A	+1.39	N/A	N/A	-252	-360	+184	+68

Nomenclature: See separate page