

BALTI, Moldova, Republic of

WMO: 337450

Lat: 47.783N

Lon: 27.950E

Elev: 102

StdP: 100.11

Time Zone: 2.00 (MDA)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-13.4	-18.7	0.7	-15.8	-16.0	0.9	-12.6	12.4	-0.3	11.0	1.2	2.5	330	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	31.7	20.2	30.3	19.6	28.9	19.5	22.1	28.4	21.2	27.6	20.5	26.5	2.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	15.0	24.4	19.2	14.2	23.6	18.4	13.4	23.1	65.1	28.2	61.9	27.8	59.4	26.6	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 10.2	8.7	7.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-17.6	23.7	5.7	0.9	-21.7	24.4	-25.0	24.9	-28.2	25.4	-32.4	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-2.4	-1.6	3.8	10.7	15.8	19.7	20.9	21.5	16.3	10.1	3.7	-0.2		
	DBStd	9.62	5.01	5.92	5.41	3.76	3.27	3.31	2.96	3.06	4.07	4.52	5.15	4.05		
	HDD10.0	1520	384	325	200	38	2	0	0	0	2	56	196	317		
	HDD18.3	3369	643	558	450	231	91	23	9	8	86	257	438	576		
	CDD10.0	1491	0	0	8	57	182	292	339	356	191	58	8	0		
	CDD18.3	300	0	0	0	0	12	66	90	106	24	2	0	0		
	CDH23.3	2896	0	0	0	13	146	546	812	1096	274	10	0	0		
	CDH26.7	916	0	0	0	0	21	151	254	418	71	1	0	0		
(14) Wind	WSAvg	2.8	2.6	3.2	3.3	3.2	2.9	2.6	2.7	2.4	2.4	2.7	2.8	2.8		
(15) Precipitation	PrecAvg	551	26	25	31	45	58	74	79	51	51	44	35	32		
	PrecMax	753	63	59	83	109	162	157	170	108	191	172	73	103		
	PrecMin	360	9	5	6	2	7	15	20	14	6	2	1	1		
	PrecStd	113	14	14	18	23	36	34	45	29	46	35	19	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	14.7	20.8	25.1	29.0	31.6	33.1	35.0	30.6	24.5	19.1	10.5		
		MCWB	6.9	8.4	12.1	14.0	16.7	20.7	20.8	21.0	17.8	16.9	13.6	8.3		
	2%	DB	7.0	10.1	17.5	22.8	26.7	30.0	31.0	32.5	28.8	21.8	14.2	8.8		
		MCWB	5.2	6.3	10.9	13.4	16.5	20.4	20.3	20.0	17.9	15.1	11.5	7.5		
	5%	DB	5.4	7.4	14.4	20.4	24.9	28.6	29.5	30.9	26.8	19.6	12.1	6.9		
		MCWB	4.0	4.8	9.2	12.0	16.0	20.2	20.0	19.7	17.0	14.1	9.9	5.5		
	10%	DB	4.0	5.3	11.6	18.0	23.1	26.8	27.8	29.1	24.3	17.3	10.4	5.0		
		MCWB	2.9	3.4	7.7	11.2	15.0	19.5	19.3	19.3	16.7	13.2	8.7	3.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	9.0	12.6	15.4	19.8	23.1	23.7	22.7	20.6	18.7	14.0	8.9		
		MCDB	9.4	14.5	19.1	22.3	24.1	28.6	30.3	30.3	28.0	22.5	16.6	9.5		
	2%	WB	5.4	6.5	11.1	13.9	18.2	21.7	22.1	21.7	19.1	16.1	12.0	7.5		
		MCDB	6.8	9.4	16.7	21.0	23.3	27.2	27.8	29.3	25.2	20.3	14.5	8.8		
	5%	WB	4.1	5.0	9.6	12.7	17.1	20.9	21.1	21.0	18.1	14.8	10.2	5.6		
		MCDB	5.1	7.1	14.0	19.3	22.3	26.8	26.4	28.5	24.4	18.7	11.7	6.8		
	10%	WB	2.9	3.5	8.1	11.6	16.0	20.1	20.2	20.2	17.0	13.4	8.7	3.9		
		MCDB	3.9	5.1	11.2	17.3	21.4	25.3	25.7	26.9	22.9	16.8	10.2	4.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.8	8.5	10.4	10.9	10.4	11.2	12.4	11.5	9.3	6.6	5.2		
		MCDBR	7.3	9.7	13.5	14.4	14.0	12.5	13.8	15.2	14.9	13.4	9.5	7.6		
		MCWBR	5.7	6.4	7.8	6.9	5.9	4.7	5.2	5.2	6.1	7.2	6.3	5.9		
	5% WB	MCDBR	6.9	9.1	12.6	13.2	11.8	11.1	11.2	13.3	13.1	11.8	8.0	7.3		
		MCWBR	5.6	6.3	7.6	6.6	5.5	4.9	5.1	5.5	6.5	6.7	5.6	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.358	0.394	0.452	0.421	0.418	0.449	0.454	0.411	0.378	0.355	0.324		
	taud		2.238	2.197	2.199	2.077	2.242	2.279	2.197	2.174	2.255	2.326	2.317	2.297		
	Ebn at Noon		723	780	813	798	844	848	813	788	787	754	687	679		
	Edh at Noon		80	104	121	151	133	129	138	136	114	91	75	68		
(44) All-Sky Solar Radiation	RadAvg		1.09	1.85	3.09	4.48	5.73	6.05	5.96	5.37	3.73	2.35	1.12	0.83		
	RadStd		0.17	0.29	0.33	0.40	0.48	0.48	0.40	0.36	0.48	0.29	0.12	0.14		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.69	N/A	N/A	+0.77	N/A	N/A	-140	-200	+102	+38

Nomenclature: See separate page