

CHISINAU, Moldova, Republic of

WMO: 338150

Lat: 47.017N

Lon: 28.983E

Elev: 173

StdP: 99.26

Time Zone: 2.00 (MDA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-11.5	-18.1	0.8	-13.3	-15.3	1.0	-10.2	9.0	-3.5	8.0	-1.7	2.5	340	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	32.8	19.7	31.0	19.2	29.5	18.7	21.6	28.8	20.7	27.7	20.0	26.7	2.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.3	24.4	18.4	13.6	23.7	17.6	12.9	23.1	63.5	28.9	60.4	27.8	57.9	26.6	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.5	5.6	DB	-16.6	34.9	3.7	1.9	-19.2	36.2	-21.4	37.4	-23.5	38.4	-26.2	39.8	(4)
(5)			WB	-17.0	22.7	3.7	1.0	-19.7	23.4	-21.8	24.0	-23.9	24.5	-26.6	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-2.0	-0.3	4.7	11.4	17.0	20.9	23.0	22.7	17.2	10.9	5.4	-0.2	(6)	
	DBStd	9.87	5.22	5.37	4.71	3.95	3.74	3.21	3.02	3.41	3.96	4.50	4.88	5.07	(7)	
	HDD10.0	1377	372	289	171	29	1	0	0	0	1	44	153	316	(8)	
	HDD18.3	3138	630	522	422	211	69	13	2	4	67	234	389	574	(9)	
	CDD10.0	1721	0	0	8	71	219	326	402	393	216	71	14	1	(10)	
	CDD18.3	442	0	0	0	2	29	89	146	139	33	3	0	0	(11)	
	CDH23.3	3612	0	0	0	19	226	673	1231	1226	226	12	0	0	(12)	
	CDH26.7	1196	0	0	0	3	46	186	441	465	53	1	0	0	(13)	
(14) Wind	WSAvg	2.5	2.6	2.7	3.0	2.7	2.5	2.4	2.4	2.3	2.3	2.3	2.5	2.7	(14)	
(15) Precipitation	PrecAvg	543	39	34	33	41	51	67	70	49	52	31	42	39	(15)	
	PrecMax	768	152	86	86	118	142	199	166	201	215	172	111	97	(16)	
	PrecMin	354	4	2	5	2	2	4	4	4	2	0	2	1	(17)	
	PrecStd	102	28	22	22	21	30	39	40	38	47	31	30	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	14.2	19.3	26.0	30.5	32.2	35.0	35.5	30.8	25.0	18.9	12.2	(19)	
		MCWB	6.1	8.5	10.9	14.9	17.5	19.6	20.0	19.9	17.3	17.1	13.5	9.0	(20)	
	2%	DB	7.6	10.8	16.2	22.3	27.7	30.3	32.8	33.1	28.0	21.9	15.7	10.0	(21)	
		MCWB	5.0	6.9	9.4	13.0	17.0	19.1	20.0	19.7	16.4	14.9	11.9	8.0	(22)	
	5%	DB	6.0	8.3	13.8	20.2	25.9	28.8	30.9	31.1	25.9	19.5	13.6	8.2	(23)	
		MCWB	4.1	5.6	7.9	11.9	16.3	18.8	19.6	19.1	16.2	14.0	10.9	6.6	(24)	
	10%	DB	4.5	6.3	11.5	18.2	23.9	27.3	29.2	29.3	23.8	17.3	11.9	6.3	(25)	
		MCWB	3.1	4.3	6.7	11.2	15.6	18.3	19.2	18.6	15.7	12.9	9.9	4.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	9.5	11.4	15.3	19.3	22.1	22.5	23.0	19.8	18.1	14.0	10.1	(27)	
		MCDB	8.8	13.6	17.9	24.2	26.8	28.5	29.5	30.5	25.7	23.7	16.9	11.4	(28)	
	2%	WB	5.5	7.3	9.8	13.9	18.2	20.6	21.6	21.4	18.5	16.2	12.5	8.2	(29)	
		MCDB	7.1	9.9	15.4	20.8	25.2	27.2	29.0	28.9	24.5	20.1	14.7	9.5	(30)	
	5%	WB	4.4	5.9	8.6	12.8	17.2	19.8	20.9	20.4	17.5	14.6	11.4	6.7	(31)	
		MCDB	5.7	7.9	13.0	18.6	23.7	26.4	27.9	27.9	22.9	18.3	13.4	8.3	(32)	
	10%	WB	3.2	4.5	7.3	11.7	16.2	19.1	20.2	19.6	16.5	13.4	10.0	4.9	(33)	
		MCDB	4.5	6.2	10.8	16.8	22.5	25.6	26.7	26.8	21.9	16.8	11.8	6.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	7.4	8.9	9.3	9.3	9.3	9.5	8.4	7.2	5.4	4.7	(35)	
		MCDBR	6.2	8.3	11.5	12.1	11.9	11.4	11.8	11.7	11.4	10.5	7.8	6.6	(36)	
	5% WB	MCWBR	4.5	5.6	6.2	5.5	4.8	4.1	3.7	3.7	4.2	5.1	4.6	4.9	(37)	
		MCWBR	5.5	7.8	10.7	11.0	10.9	10.0	10.0	10.4	9.7	9.5	6.9	6.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.322	0.352	0.385	0.443	0.415	0.411	0.440	0.445	0.405	0.370	0.348	0.322	(40)	
		taud	2.263	2.246	2.239	2.097	2.253	2.291	2.220	2.197	2.272	2.361	2.358	2.323	(41)	
	Ebn at Noon		742	798	828	810	851	855	823	800	798	772	711	700	(42)	
		Edh at Noon	80	100	118	149	132	128	136	133	113	89	74	68	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.09	1.84	3.14	4.58	5.92	6.25	6.14	5.57	3.91	2.47	1.18	0.85	(44)	
	RadStd		0.20	0.29	0.29	0.40	0.51	0.47	0.39	0.33	0.46	0.27	0.15	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.71	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (21 neighbors)	+0.64	N/A	N/A	+0.73	N/A	N/A	N/A	-167	+104	+62	(47)

Nomenclature: See separate page