

COMRAT, Moldova, Republic of

WMO: 338830

Lat: 46.300N

Lon: 28.633E

Elev: 436

StdP: 14.47

Time Zone: 2.00 (MDA)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	11.6	-0.2	5.5	8.2	4.4	7.0	12.4	22.7	32.7	20.4	24.3	9.0	320	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.3	89.9	67.0	87.4	66.8	84.9	66.0	70.8	83.2	69.3	81.2	68.1	80.1	6.7	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	101.9	74.7	65.6	96.0	73.6	64.2	91.3	72.6	34.9	83.0	33.7	81.5	32.7	79.7	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.1	14.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	29.5	30.2	40.3	51.4	61.6	68.9	71.9	73.0	63.8	52.4	40.2	33.6
	DBStd	17.40	8.42	10.13	9.62	6.79	6.44	6.29	4.83	5.50	7.13	7.76	9.83	7.12
	HDD50	2468	634	555	322	64	3	0	0	0	2	65	316	507
	HDD65	5657	1099	975	766	409	143	32	7	8	107	394	745	972
	CDD50	3022	0	1	20	106	362	566	678	711	416	140	21	1
	CDD65	739	0	0	0	2	37	149	220	255	72	4	0	0
	CDH74	6514	0	0	1	20	351	1213	1842	2426	634	27	0	0
	CDH80	2135	0	0	0	2	52	372	600	934	172	3	0	0
Wind	WSAvg	6.5	6.5	7.1	7.0	7.3	6.8	6.3	6.2	5.9	6.0	6.3	6.4	6.8
Precipitation	PrecAvg	20.3	1.3	1.0	1.2	1.4	2.1	2.6	1.9	2.0	1.7	1.9	1.4	1.7
	PrecMax	26.2	3.0	2.4	2.6	2.7	6.6	5.3	5.4	5.1	6.1	6.1	4.0	5.0
	PrecMin	12.9	0.2	0.2	0.2	0.2	0.3	0.6	0.1	0.7	0.1	0.5	0.0	0.1
	PrecStd	3.8	0.8	0.6	0.7	0.6	1.4	1.3	1.1	1.1	1.5	1.3	1.1	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	57.4	70.7	76.3	84.0	90.4	92.6	94.3	88.0	77.7	67.0	53.5
		MCWB	43.8	47.2	53.9	57.0	64.2	70.3	68.6	69.3	63.7	63.2	57.1	48.9
	2%	DB	45.7	50.7	64.1	72.1	81.1	87.4	88.7	90.8	84.5	71.8	59.2	49.7
		MCWB	41.9	43.9	50.9	55.2	62.1	67.8	67.4	66.6	63.3	58.6	54.4	47.0
	5%	DB	42.7	45.7	59.2	68.1	78.0	84.7	85.8	88.2	81.3	67.9	55.2	47.3
		MCWB	39.3	41.1	48.4	53.4	60.6	67.5	66.7	66.6	62.5	57.2	51.2	44.4
	10%	DB	39.9	41.9	54.1	63.9	75.0	81.2	83.0	85.4	77.2	63.9	52.2	44.0
		MCWB	37.7	38.6	45.9	51.7	59.8	66.5	65.8	65.8	61.7	54.9	49.1	41.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.8	48.1	55.3	59.0	67.4	72.9	72.8	72.8	68.3	64.9	58.1	50.8
		MCDB	48.8	56.1	69.2	73.3	77.7	86.9	83.3	86.5	78.2	73.4	62.5	52.7
	2%	WB	42.6	44.7	51.3	56.3	64.5	70.5	70.4	70.2	66.2	61.0	55.2	47.7
		MCDB	45.4	49.4	62.0	69.3	74.4	82.3	81.6	83.9	77.2	69.1	59.1	49.3
	5%	WB	40.1	41.5	49.0	54.1	62.6	68.9	69.2	68.7	64.5	58.5	52.1	44.6
		MCDB	42.2	45.0	57.8	65.9	73.4	80.3	80.2	82.3	76.7	65.0	54.9	47.2
	10%	WB	38.0	39.0	46.6	52.3	60.8	67.5	67.9	67.5	62.9	56.1	49.3	41.3
		MCDB	39.7	42.1	53.6	62.8	71.9	78.4	79.0	80.8	74.2	62.3	51.5	43.8
Mean Daily Temperature Range	5% DB	MDBR	9.8	11.3	14.3	17.5	19.1	17.4	18.8	20.3	18.9	14.9	11.0	9.4
		MCDBR	13.6	16.3	23.3	24.9	24.3	22.0	23.3	24.1	24.3	20.8	14.8	13.9
		MCWBR	9.7	10.7	12.5	11.4	10.2	7.3	7.4	8.2	8.8	9.8	9.7	10.6
	5% WB	MCDBR	12.1	15.3	21.4	23.0	21.1	19.8	19.5	21.6	21.5	18.9	13.4	13.4
MCWBR		9.6	10.8	11.8	11.2	10.0	7.6	7.9	8.2	9.0	9.6	9.5	10.5	
Clear-Sky Solar Irradiance	taub	0.330	0.359	0.392	0.445	0.419	0.416	0.441	0.449	0.408	0.377	0.353	0.328	
	taud	2.280	2.246	2.217	2.088	2.243	2.281	2.219	2.187	2.267	2.342	2.347	2.320	
	Ebn at Noon	236	253	261	257	269	270	261	253	253	244	226	223	
	Edh at Noon	26	32	38	48	43	41	43	43	36	29	24	22	
All-Sky Solar Radiation	RadAvg	361	601	1022	1476	1902	2004	1981	1794	1279	811	399	292	
	RadStd	68	92	88	131	152	141	121	104	133	81	56	54	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+1.08	N/A	N/A	N/A	+1.28	N/A	N/A	N/A	-259	+176	+113

Nomenclature: See separate page