

COMRAT, Moldova, Republic of

WMO: 338830

Lat: 46.300N

Lon: 28.633E

Elev: 133

StdP: 99.74

Time Zone: 2.00 (MDA)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-11.3	-17.9	0.8	-13.2	-15.3	1.0	-10.9	10.1	0.4	9.1	-4.3	4.0	320	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	32.2	19.4	30.8	19.3	29.4	18.9	21.6	28.4	20.7	27.3	20.1	26.7	3.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.6	23.7	18.7	13.7	23.1	17.9	13.0	22.6	63.4	28.3	60.5	27.5	58.1	26.5	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.2	6.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-1.4	-1.0	4.6	10.8	16.4	20.5	22.2	22.8	17.7	11.3	4.5	0.9
	DBStd	9.67	4.68	5.63	5.34	3.77	3.58	3.49	2.68	3.05	3.96	4.31	5.46	3.95
	HDD10.0	1371	352	308	179	36	2	0	0	0	1	36	176	282
	HDD18.3	3143	611	542	426	227	79	18	4	4	59	219	414	540
	CDD10.0	1679	0	1	11	59	201	314	377	395	231	78	12	1
	CDD18.3	411	0	0	0	1	21	83	122	142	40	2	0	0
	CDH23.3	3619	0	0	1	11	195	674	1023	1348	352	15	0	0
	CDH26.7	1186	0	0	0	1	29	207	333	519	96	2	0	0
Wind	WSAvg	2.9	2.9	3.2	3.1	3.2	3.0	2.8	2.8	2.6	2.7	2.8	2.8	3.0
Precipitation	PrecAvg	516	34	26	30	35	54	66	48	52	43	47	36	44
	PrecMax	665	76	60	67	69	168	134	138	130	156	155	101	127
	PrecMin	327	4	5	4	5	8	16	2	17	2	12	0	2
	PrecStd	97	21	16	17	16	35	32	29	28	37	32	29	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	14.1	21.5	24.6	28.9	32.4	33.7	34.6	31.1	25.4	19.5	11.9
		MCWB	6.6	8.4	12.2	13.9	17.9	21.3	20.3	20.7	17.6	17.3	13.9	9.4
	2%	DB	7.6	10.4	17.8	22.3	27.3	30.8	31.5	32.7	29.2	22.1	15.1	9.8
		MCWB	5.5	6.6	10.5	12.9	16.7	19.9	19.7	19.2	17.4	14.8	12.4	8.4
	5%	DB	5.9	7.6	15.1	20.0	25.5	29.3	29.9	31.2	27.4	19.9	12.9	8.5
		MCWB	4.1	5.0	9.1	11.9	15.9	19.7	19.3	19.2	17.0	14.0	10.6	6.9
	10%	DB	4.4	5.5	12.3	17.7	23.9	27.3	28.3	29.6	25.1	17.7	11.2	6.6
		MCWB	3.1	3.7	7.7	10.9	15.5	19.1	18.8	18.8	16.5	12.7	9.5	5.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	8.9	12.9	15.0	19.6	22.7	22.7	22.7	20.2	18.3	14.5	10.4
		MCDB	9.4	13.4	20.7	22.9	25.4	30.5	28.5	30.3	25.7	23.0	16.9	11.5
	2%	WB	5.9	7.0	10.7	13.5	18.1	21.4	21.3	21.2	19.0	16.1	12.9	8.7
		MCDB	7.4	9.7	16.6	20.7	23.5	28.0	27.6	28.8	25.1	20.6	15.1	9.6
	5%	WB	4.5	5.3	9.5	12.3	17.0	20.5	20.6	20.4	18.0	14.7	11.2	7.0
		MCDB	5.7	7.2	14.3	18.8	23.0	26.9	26.8	27.9	24.8	18.3	12.7	8.5
	10%	WB	3.3	3.9	8.1	11.3	16.0	19.7	19.9	19.7	17.1	13.4	9.6	5.1
		MCDB	4.3	5.6	12.0	17.1	22.2	25.8	26.1	27.1	23.4	16.8	10.8	6.5
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.3	7.9	9.7	10.6	9.7	10.4	11.3	10.5	8.3	6.1	5.2
		MCDBR	7.5	9.0	13.0	13.8	13.5	12.2	12.9	13.4	13.5	11.5	8.2	7.7
		MCWBR	5.4	6.0	6.9	6.4	5.6	4.1	4.1	4.5	4.9	5.5	5.4	5.9
	5% WB	MCDBR	6.7	8.5	11.9	12.8	11.7	11.0	10.8	12.0	11.9	10.5	7.5	7.5
		MCWBR	5.4	6.0	6.6	6.2	5.6	4.2	4.4	4.6	5.0	5.3	5.3	5.8
Clear-Sky Solar Irradiance	taub	0.330	0.359	0.392	0.445	0.419	0.416	0.441	0.449	0.408	0.377	0.353	0.328	
	taud	2.280	2.246	2.217	2.088	2.243	2.281	2.219	2.187	2.267	2.342	2.347	2.320	
	Ebn at Noon	744	797	824	810	849	852	824	799	799	769	714	702	
	Edh at Noon	81	102	121	151	134	130	136	135	114	92	76	70	
All-Sky Solar Radiation	RadAvg	1.14	1.90	3.22	4.65	6.00	6.32	6.24	5.66	4.03	2.56	1.26	0.92	
	RadStd	0.21	0.29	0.28	0.41	0.48	0.45	0.38	0.33	0.42	0.26	0.18	0.17	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (30 neighbors)		+0.60	N/A	N/A	+0.71	N/A	N/A	N/A	-144	+98	+63	

Nomenclature: See separate page