

KURSK, Russian FederationWMO: **340090**Lat: **51.767N**Lon: **36.167E**Elev: **811**StdP: **14.27**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.5	-1.9	-13.3	2.8	-6.5	-7.8	3.7	-1.4	18.5	25.4	16.7	25.6	4.8	50	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	87.6	66.9	84.1	65.4	81.0	64.4	69.3	81.7	67.9	79.8	66.5	77.5	6.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	96.1	73.8	63.9	91.5	72.5	62.5	87.2	71.3	33.9	81.5	32.7	79.9	31.6	77.7	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.9	15.1	13.3	DB	-11.3	92.0	6.6	4.2	-16.0	95.0	-19.9	97.4	-23.6	99.8	-28.4	102.8
(5)				WB	-11.7	72.0	6.5	1.6	-16.4	73.2	-20.2	74.1	-23.9	75.1	-28.6	76.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.1	20.5	21.9	31.2	47.1	59.0	65.0	69.0	67.0	56.5	44.6	33.1	24.2	
	DBStd	19.59	10.82	11.31	8.49	8.55	8.69	6.96	6.17	6.92	7.74	8.40	8.99	10.59	
	HDD50	4006	913	788	584	155	22	1	0	0	26	209	508	800	
	HDD65	7697	1378	1208	1048	538	226	86	30	57	272	632	957	1265	
	CDD50	2200	0	0	1	68	301	452	588	527	220	42	1	0	
	CDD65	416	0	0	0	1	39	87	153	119	16	1	0	0	
	CDH74	3248	0	0	0	8	294	594	1179	1048	123	2	0	0	
	CDH80	913	0	0	0	0	52	122	364	360	15	0	0	0	
Wind	WSAvg	6.0	6.5	6.8	7.0	6.4	5.6	5.5	5.0	5.0	5.2	5.9	6.5	6.7	
Precipitation	PrecAvg	25.2	1.9	1.6	1.7	1.8	2.1	2.7	2.9	2.2	2.6	2.3	1.8	1.7	
	PrecMax	37.4	4.3	2.6	4.6	4.2	4.2	6.5	7.0	5.9	5.7	6.6	3.7	5.0	
	PrecMin	17.7	0.9	0.8	0.3	0.0	0.8	0.7	0.9	0.2	0.4	0.4	0.2	0.6	
	PrecStd	3.9	0.8	0.6	1.0	0.9	0.9	1.3	1.5	1.4	1.6	1.4	1.0	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.8	41.4	57.0	74.5	84.7	87.4	93.0	94.8	82.4	69.8	55.5	46.0	
		MCWB	38.6	38.7	45.4	54.9	63.0	65.4	67.7	66.9	61.4	56.3	52.0	44.4	
	2%	DB	36.9	38.1	50.0	68.8	80.9	83.3	87.6	88.1	77.7	64.6	50.4	41.9	
		MCWB	35.6	36.3	42.0	53.1	61.3	65.4	67.7	66.7	59.4	55.4	48.0	40.5	
	5%	DB	34.9	35.9	45.5	65.0	77.2	80.5	84.0	83.5	73.1	59.8	47.4	38.6	
		MCWB	33.7	34.4	39.7	51.3	60.7	64.6	66.9	65.2	58.3	53.3	45.5	37.5	
	10%	DB	33.3	34.3	41.7	60.8	73.3	77.3	80.5	79.7	68.7	55.9	44.5	35.6	
		MCWB	32.4	33.1	37.4	49.2	59.1	63.3	65.9	63.6	57.1	51.1	42.9	34.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.2	39.2	47.0	57.2	66.9	69.8	71.6	71.2	63.8	59.9	52.2	44.8
			MCDB	39.5	40.8	54.1	69.5	80.2	80.7	85.5	85.6	73.4	64.7	55.1	45.6
2%		WB	35.8	36.7	43.2	54.5	64.0	67.9	69.8	68.6	61.9	56.5	48.7	40.8	
		MCDB	36.4	37.7	48.6	64.5	76.2	79.1	82.1	82.5	71.3	62.4	50.2	41.8	
5%		WB	33.9	34.8	40.3	52.6	62.0	66.3	68.4	66.9	60.3	54.1	45.8	37.7	
		MCDB	34.6	35.6	44.4	62.0	73.2	76.9	80.0	79.6	69.9	59.0	47.0	38.5	
10%		WB	32.4	33.4	37.8	50.8	60.2	64.7	67.1	65.3	58.4	51.6	43.0	34.8	
		MCDB	33.1	34.1	41.1	59.4	70.6	74.5	77.7	76.7	67.1	55.3	44.3	35.4	
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.4	10.7	15.1	16.5	15.8	16.3	17.2	15.0	11.1	7.5	7.5	
		MCDBR	5.9	7.5	15.0	20.7	20.2	19.3	20.9	22.2	21.8	16.9	10.9	7.8	
		MCWBR	5.9	6.6	9.3	10.1	8.5	8.1	7.6	8.2	9.8	9.8	8.8	7.4	
	5% WB	MCDBR	5.7	7.0	13.1	18.0	18.1	17.4	18.3	19.6	18.3	14.9	9.4	7.6	
		MCWBR	5.9	6.8	9.3	9.7	8.5	8.3	7.6	8.4	9.5	10.0	8.6	7.4	
Clear-Sky Solar Irradiance	taub	0.299	0.332	0.358	0.436	0.395	0.384	0.418	0.425	0.390	0.356	0.334	0.302		
	taud	2.136	2.054	2.118	2.094	2.302	2.352	2.271	2.236	2.301	2.367	2.282	2.187		
	Ebn at Noon	215	240	260	252	272	276	263	254	249	235	203	193		
	Edh at Noon	23	34	39	46	39	37	40	39	33	25	21	19		
All-Sky Solar Radiation	RadAvg	295	610	1040	1324	1807	1903	1813	1591	1037	549	241	177		
	RadStd	56	78	161	122	146	167	128	145	131	84	50	43		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.49	N/A	N/A	+1.57	N/A	N/A	-288	-427	+227	+94
Regional (5 neighbors)		+1.35	N/A	N/A	+1.62	N/A	N/A	-265	-398	+207	+83