

REMONTNOYE, Russian Federation

WMO: 347590

Lat: 46.567N

Lon: 43.667E

Elev: 106

StdP: 100.05

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.6	-15.8	-22.4	0.5	-19.2	-18.6	0.7	-15.4	9.7	-3.6	8.5	-3.0	2.4	130	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	35.4	20.4	33.5	19.8	31.8	19.3	22.4	31.3	21.4	29.9	20.6	28.6	4.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.6	25.3	18.7	13.7	24.5	17.9	13.0	23.9	66.5	31.4	62.7	30.0	59.7	28.4	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	7.9	7.1	DB	-21.9	37.4	4.7	1.3	-25.3	38.4	-28.1	39.2	-30.7	39.9	-34.2	40.9	(4)
(5)			WB	-22.1	24.0	4.7	1.6	-25.5	25.2	-28.3	26.2	-30.9	27.1	-34.3	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-3.4	-2.2	2.9	10.4	16.9	21.2	24.5	23.2	16.8	9.7	2.8	-2.0	(6)	
	DBStd	10.92	5.78	5.86	4.13	4.36	4.22	3.56	2.82	3.36	4.05	5.16	5.15	5.60	(7)	
	HDD10.0	1688	415	343	222	46	3	0	0	0	3	69	217	371	(8)	
	HDD18.3	3501	673	576	478	239	79	13	0	3	74	272	464	629	(9)	
	CDD10.0	1739	0	0	2	58	216	336	449	410	207	59	2	0	(10)	
	CDD18.3	512	0	0	0	1	34	98	191	155	29	3	0	0	(11)	
	CDH23.3	5724	0	0	0	17	404	1047	2174	1753	299	30	0	0	(12)	
	CDH26.7	2456	0	0	0	2	111	424	1049	794	71	6	0	0	(13)	
(14) Wind	WSAvg	3.4	3.6	3.7	4.0	4.0	3.3	3.2	2.8	2.8	3.0	3.1	3.5	3.6	(14)	
(15) Precipitation	PrecAvg	407	29	24	32	29	51	50	35	28	32	34	32	31	(15)	
	PrecMax	558	47	54	74	111	122	112	79	122	88	105	78	80	(16)	
	PrecMin	239	2	10	7	2	14	10	4	2	0	3	6	6	(17)	
	PrecStd	79	11	12	17	22	31	30	21	28	23	24	20	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	10.8	17.5	25.7	31.7	35.9	37.5	37.0	30.8	26.8	15.8	9.8	(19)	
		MCWB	6.5	8.0	11.0	15.3	17.6	20.4	20.8	21.4	18.0	15.9	11.4	8.1	(20)	
	2%	DB	5.5	7.8	13.4	22.3	29.3	33.4	36.1	34.7	28.8	23.1	12.8	7.7	(21)	
		MCWB	4.4	5.3	8.2	14.3	17.2	19.4	20.8	20.2	17.4	14.9	10.3	6.3	(22)	
	5%	DB	3.9	5.6	11.2	20.3	27.6	31.2	34.1	32.9	26.9	19.9	10.8	6.1	(23)	
		MCWB	3.0	3.9	7.4	13.3	16.8	18.8	20.0	19.9	17.3	14.4	9.2	5.0	(24)	
	10%	DB	2.7	4.0	9.2	18.4	25.6	29.0	32.0	31.2	24.8	17.1	9.3	4.6	(25)	
		MCWB	1.9	2.8	6.1	12.0	16.4	18.1	19.5	19.5	16.3	13.3	8.1	3.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.4	8.3	11.2	16.8	20.1	23.9	24.1	23.2	21.1	18.3	12.2	8.2	(27)	
		MCDB	7.8	10.7	15.9	23.6	27.5	32.7	34.4	32.1	27.7	24.3	14.9	9.4	(28)	
	2%	WB	4.4	5.7	9.2	15.4	18.8	21.8	22.4	22.2	19.4	16.4	10.7	6.5	(29)	
		MCDB	5.2	7.4	12.6	21.3	25.9	29.7	31.9	30.8	25.8	20.2	12.4	7.5	(30)	
	5%	WB	3.1	4.1	7.7	13.9	18.0	20.5	21.2	21.4	18.4	14.9	9.4	5.1	(31)	
		MCDB	3.8	5.4	10.4	18.5	25.1	27.9	30.1	29.6	24.0	19.0	10.7	5.9	(32)	
	10%	WB	1.9	2.9	6.4	12.6	17.1	19.4	20.4	20.5	17.4	13.6	8.1	3.8	(33)	
		MCDB	2.6	3.9	8.9	17.1	23.8	26.1	28.8	28.3	22.4	16.8	9.3	4.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	6.3	7.7	10.9	11.6	11.5	12.3	12.7	12.1	9.3	6.2	5.1	(35)	
		MCDBR	5.5	7.9	11.6	13.5	15.0	15.1	15.4	15.0	15.2	13.3	8.5	5.8	(36)	
	5% WB	MCWBR	4.6	5.9	7.2	6.6	5.7	5.2	4.9	5.2	6.2	6.8	6.1	4.9	(37)	
		MCWBR	5.1	6.7	10.2	11.6	12.9	12.4	13.3	13.3	12.6	11.4	8.0	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.375	0.410	0.455	0.428	0.426	0.441	0.446	0.421	0.384	0.355	0.349	(40)	
		taud	2.190	2.116	2.113	2.034	2.200	2.251	2.216	2.181	2.203	2.267	2.265	2.195	(41)	
	Ebn at Noon		714	766	801	799	840	842	822	800	782	753	698	655	(42)	
		Edh at Noon	87	115	134	159	139	133	136	136	122	98	81	79	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.96	1.79	2.97	4.70	5.97	6.58	6.45	5.76	4.22	2.52	1.19	0.75	(44)	
	RadStd		0.23	0.30	0.33	0.42	0.54	0.40	0.31	0.36	0.38	0.34	0.18	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (4 neighbors)	+0.44	N/A	N/A	+1.01	-0.74	-0.70	N/A	N/A	+147	+93	(47)

Nomenclature: See separate page