

DIVNOYE, Russian Federation

WMO: 348580

Lat: 45.917N

Lon: 43.350E

Elev: 283

StdP: 14.55

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.1	6.6	-4.8	4.3	1.0	1.5	6.0	7.8	17.5	30.5	15.6	31.4	4.6	90	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.0	98.0	68.1	95.0	67.3	91.7	66.9	72.1	87.6	70.7	86.2	69.3	84.5	6.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	103.9	76.8	66.2	97.4	75.9	64.5	91.9	74.9	36.0	87.6	34.7	86.4	33.6	84.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.7	13.6	11.8	DB	-3.3	102.5	9.0	3.6	-9.8	105.2	-15.0	107.3	-20.1	109.3	-26.6	112.0	(4)
			WB	-3.9	75.4	8.8	3.3	-10.3	77.7	-15.4	79.6	-20.4	81.5	-26.8	83.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	27.8	29.6	39.4	52.2	63.9	73.3	78.0	76.5	65.2	52.4	39.6	31.5
	DBStd	19.68	10.35	10.59	7.56	7.32	7.01	6.51	5.32	6.15	7.34	8.76	8.78	9.38
	HDD50	2634	690	572	337	58	2	0	0	0	2	77	322	574
	HDD65	5730	1155	992	795	386	106	10	0	3	86	396	762	1039
	CDD50	3575	0	0	7	125	434	698	869	821	458	153	10	0
	CDD65	1196	0	0	0	3	73	258	404	359	92	7	0	0
	CDH74	13329	0	0	0	49	789	2762	4651	4181	840	57	0	0
	CDH80	6251	0	0	0	7	240	1259	2377	2102	254	12	0	0
Wind	WSAvg	5.4	6.0	6.4	6.6	6.1	5.1	4.9	4.4	4.4	4.8	4.7	5.5	6.1
Precipitation	PrecAvg	17.5	1.1	0.9	1.4	1.4	2.0	2.2	1.5	1.4	1.5	1.5	1.3	1.2
	PrecMax	22.8	2.1	1.9	2.8	4.8	4.6	4.9	3.8	3.1	3.5	4.0	2.9	4.1
	PrecMin	12.8	0.0	0.2	0.3	0.1	0.3	0.6	0.2	0.0	0.0	0.0	0.3	0.1
	PrecStd	2.9	0.6	0.5	0.8	1.0	1.1	1.1	1.0	0.9	0.9	1.1	0.8	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	55.1	66.4	79.7	91.0	98.1	101.8	102.5	92.0	80.9	63.3	52.1
		MCWB	44.2	46.6	52.1	59.6	64.7	67.5	69.1	67.8	66.7	61.2	54.4	47.5
	2%	DB	44.3	48.9	59.0	73.5	85.8	94.9	98.5	97.8	86.1	73.6	57.5	47.8
		MCWB	40.9	43.3	48.7	58.0	63.1	66.6	68.7	67.7	64.7	60.2	51.9	44.7
	5%	DB	41.3	44.4	54.5	69.3	82.2	91.4	95.3	94.4	82.5	68.9	53.7	44.8
		MCWB	39.1	40.8	46.6	55.9	63.0	66.3	67.8	67.3	63.3	58.9	50.1	42.4
	10%	DB	38.7	41.1	50.4	65.7	78.3	87.4	91.7	90.9	78.8	64.7	50.5	42.3
		MCWB	37.0	38.6	44.3	54.0	62.1	65.8	67.3	66.7	62.4	56.8	47.8	40.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.2	48.3	53.6	61.8	69.2	74.4	74.2	74.2	71.8	64.3	55.5	48.4
		MCDB	49.0	53.6	63.1	75.2	83.7	87.9	88.9	88.2	83.4	74.1	61.1	51.3
	2%	WB	41.4	43.9	49.9	59.4	66.6	71.1	71.9	71.8	68.1	61.9	52.8	45.0
		MCDB	43.8	47.8	56.6	71.3	79.6	86.5	88.0	87.9	80.2	70.1	56.9	47.3
	5%	WB	39.3	41.0	47.3	57.2	64.8	69.2	70.5	70.3	66.0	59.9	50.2	42.8
		MCDB	41.1	43.9	53.6	67.3	77.5	84.1	86.7	85.3	77.2	67.2	53.0	44.3
	10%	WB	37.1	38.7	44.8	55.0	63.0	67.5	69.2	69.0	64.3	57.7	48.1	40.9
		MCDB	38.6	40.9	49.8	63.9	74.6	82.4	85.2	83.9	75.2	63.9	50.3	42.3
Mean Daily Temperature Range	5% DB	MDBR	8.8	11.0	13.9	18.6	20.0	21.0	22.0	23.3	20.7	15.9	10.6	8.7
		MCDBR	10.9	15.1	21.5	24.0	27.2	26.6	27.9	28.6	26.0	22.0	15.2	11.3
		MCWBR	8.1	10.3	12.5	11.7	10.2	8.6	8.2	8.9	9.7	10.7	10.1	8.7
	5% WB	MCDBR	10.2	13.9	19.3	21.3	22.4	22.6	22.5	23.1	21.6	19.4	13.6	10.1
		MCWBR	8.0	9.8	12.2	11.1	9.7	9.1	8.2	8.8	9.4	10.4	9.6	8.2
Clear-Sky Solar Irradiance	taub	0.345	0.379	0.414	0.459	0.429	0.432	0.450	0.454	0.428	0.390	0.358	0.351	
	taud	2.210	2.139	2.113	2.032	2.209	2.247	2.206	2.176	2.202	2.270	2.283	2.214	
	Ebn at Noon	229	244	254	253	267	266	259	252	247	239	224	211	
	Edh at Noon	28	36	43	51	44	43	44	43	39	31	26	25	
All-Sky Solar Radiation	RadAvg	328	599	935	1479	1864	2065	2044	1837	1340	798	399	264	
	RadStd	83	100	100	137	181	119	107	98	126	106	57	36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.79	N/A	N/A	+1.66	-1.26	-1.15	N/A	N/A	+265	+167
Regional (8 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+243	N/A

Nomenclature: See separate page