

TURAN, Russian Federation

WMO: 360920

Lat: 52.1451N

Lon: 93.9159E

Elev: 852

StdP: 91.50

Time Zone: 7.00 (E07)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -41.1	(c) -38.7	(d) -44.8	(e) 0.0	(f) -40.9	(g) -42.3	(h) 0.1	(i) -38.7	(j) 4.2	(k) -16.0	(l) 3.1	(m) -22.0	(n) 0.1	(o) 250	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.5	(c) 30.7	(d) 15.1	(e) 28.4	(f) 14.8	(g) 26.4	(h) 14.4	(i) 17.1	(j) 25.1	(k) 16.3	(l) 24.3	(m) 15.6	(n) 23.5	(o) 2.3	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.6	11.5	19.3	13.7	10.8	18.5	12.9	10.3	17.7	51.6	25.0	49.2	24.0	46.9	23.8	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.9	(b) 4.9	(c) 4.1	(e) -42.6	(f) 33.8	(g) 2.1	(h) 2.2	(i) -44.1	(j) 35.4	(k) -45.4	(l) 36.7	(m) -46.6	(n) 37.9	(o) -48.1	(p) 39.5		
(a) 5.9	(b) 4.9	(c) 4.1	(e) -42.7	(f) 18.4	(g) 2.1	(h) 0.8	(i) -44.2	(j) 18.9	(k) -45.4	(l) 19.4	(m) -46.6	(n) 19.8	(o) -48.1	(p) 20.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.1	-28.5	-23.3	-8.4	3.8	9.1	17.0	18.3	15.9	8.8	-0.1	-14.4	-24.4		
	DBStd	17.20	5.35	6.15	7.08	4.59	4.84	4.20	2.91	3.28	4.53	4.91	7.27	5.61		
	HDD10.0	5158	1195	932	572	190	77	3	0	1	75	313	733	1067		
	HDD18.3	7533	1453	1166	830	436	288	72	36	88	285	571	983	1326		
	CDD10.0	749	0	0	0	4	48	213	257	186	40	1	0	0		
	CDD18.3	82	0	0	0	0	1	32	34	14	0	0	0	0		
	CDH23.3	1273	0	0	0	1	62	522	434	226	28	0	0	0		
	CDH26.7	392	0	0	0	0	11	178	138	61	4	0	0	0		
	WSAvg	1.6	0.8	1.1	1.6	2.3	2.4	2.1	1.9	1.8	1.7	1.5	1.1	0.8		
	PrecAvg	723	25	25	39	48	61	78	105	101	68	68	61	50		
	PrecMax	956	62	82	108	102	142	130	245	203	110	306	147	156		
	PrecMin	489	2	1	5	13	1	16	5	56	35	16	17	3		
	PrecStd	113	15	19	26	27	35	31	38	34	20	55	33	37		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-12.8	-6.3	10.1	21.9	28.0	33.6	33.7	31.6	26.4	17.3	2.9	-6.3		
		MCWB	-13.6	-7.4	3.3	8.8	13.0	15.2	16.0	15.3	13.0	8.1	-0.1	-7.1		
	2%	DB	-16.4	-9.6	6.4	18.2	25.1	30.8	30.5	28.3	23.1	13.3	0.3	-10.2		
		MCWB	-16.9	-10.4	1.3	7.6	11.4	14.8	15.8	15.6	12.7	6.3	-1.4	-10.8		
	5%	DB	-18.4	-11.7	3.6	15.5	21.9	28.7	27.9	25.8	20.4	10.0	-1.8	-13.7		
		MCWB	-18.8	-12.6	-0.2	6.2	10.4	14.3	15.4	15.1	11.6	4.9	-3.1	-14.2		
	10%	DB	-20.6	-13.8	1.1	12.7	19.1	26.4	25.6	23.6	17.3	7.1	-4.2	-16.6		
		MCWB	-21.0	-14.5	-1.3	5.1	8.8	14.0	15.1	14.4	10.1	3.1	-5.4	-17.1		
	0.4%	WB	-13.5	-7.5	3.5	9.7	13.2	17.2	18.2	18.4	14.2	8.8	0.3	-7.1		
		MCDB	-12.8	-6.3	9.2	19.3	25.4	26.4	25.8	25.1	22.7	15.0	2.2	-6.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-16.9	-10.5	1.6	8.1	12.1	16.3	17.3	17.1	13.0	6.9	-1.4	-10.6		
		MCDB	-16.4	-9.7	5.7	16.0	23.3	25.7	25.2	24.1	21.8	12.6	0.0	-10.1		
	5%	WB	-18.8	-12.6	0.1	6.6	11.0	15.6	16.6	15.9	11.9	5.2	-3.1	-14.1		
		MCDB	-18.4	-11.8	3.0	14.1	20.9	24.9	24.3	23.4	19.7	9.3	-1.9	-13.6		
	10%	WB	-20.9	-14.4	-1.3	5.4	9.5	14.9	15.9	15.0	10.6	3.7	-5.4	-17.0		
		MCDB	-20.6	-13.7	1.1	12.6	17.6	24.0	23.4	22.0	16.5	6.8	-4.3	-16.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	11.3	11.3	12.7	13.8	14.3	12.5	12.8	13.6	11.1	9.4	8.2		
		MCDBR	10.1	11.6	12.0	17.3	18.5	17.9	16.7	17.0	18.1	15.9	9.2	8.1		
		MCWBR	9.5	10.8	7.8	8.7	8.2	6.0	5.5	6.3	8.3	9.3	7.4	7.6		
		MCDBR	9.9	11.5	10.9	15.0	16.7	14.5	12.7	13.6	17.0	15.2	9.0	8.1		
	5% WB	MCWBR	9.4	10.7	7.4	7.9	7.7	5.5	5.1	5.7	8.1	9.1	7.3	7.6		
(40) Clear-Sky Solar Irradiance	taub		0.263	0.294	0.339	0.379	0.390	0.385	0.383	0.369	0.334	0.320	0.294	0.267		
	taud		2.105	2.068	2.017	2.169	2.230	2.350	2.388	2.397	2.434	2.348	2.170	2.060		
	Ebn at Noon		720	803	835	852	860	869	864	858	850	779	670	629		
	Edh at Noon		73	104	135	132	131	118	111	105	89	79	69	65		
(44) All-Sky Solar Radiation	RadAvg		1.27	2.37	3.92	4.88	5.49	6.07	5.53	4.76	3.58	2.18	1.18	0.88		
	RadStd		0.07	0.12	0.16	0.23	0.38	0.49	0.34	0.34	0.35	0.18	0.11	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page