

UST'- KOKSA, Russian Federation

WMO: 362290

Lat: 50.2716N

Lon: 85.6201E

Elev: 3207

StdP: 13.07

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.9	-27.8	-38.7	0.7	-32.6	-33.7	0.9	-27.8	15.2	12.1	13.9	14.6	0.0	80	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	82.5	58.9	79.2	57.8	76.0	57.2	62.1	74.8	60.6	72.9	59.3	71.0	5.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	81.8	64.1	56.5	76.6	63.2	54.9	72.3	62.2	29.5	75.2	28.4	72.9	27.4	71.5	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	14.1	12.1	10.6	DB	-33.2	87.9	6.2	2.5	-37.6	89.7	-41.2	91.1	-44.7	92.5	-49.2	94.2
(5)				WB	-33.4	64.9	6.1	3.0	-37.8	67.1	-41.4	68.8	-44.8	70.5	-49.2	72.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.8	-6.2	1.1	22.8	41.2	48.8	60.1	62.3	59.0	48.1	35.5	17.5	1.1
	DBStd	25.50	13.80	11.66	11.30	7.68	6.74	6.22	4.86	4.83	6.72	8.07	12.12	13.45
	HDD50	7392	1743	1369	842	272	107	6	0	1	112	450	974	1516
	HDD65	11818	2208	1789	1307	715	502	167	111	193	507	914	1424	1981
	CDD50	1102	0	0	0	7	70	309	380	280	55	1	0	0
	CDD65	53	0	0	0	0	0	20	26	7	0	0	0	0
	CDH74	1091	0	0	0	0	34	367	389	267	34	0	0	0
	CDH80	203	0	0	0	0	4	75	84	36	4	0	0	0
Wind	WSAvg	3.6	2.4	2.9	3.8	4.3	4.9	3.7	3.6	3.3	3.8	4.2	3.8	3.1
Precipitation	PrecAvg	18.2	0.5	0.4	0.4	1.2	2.1	3.0	3.1	2.7	1.8	1.3	0.9	0.7
	PrecMax	23.0	1.0	1.2	1.3	2.6	5.0	5.0	6.3	6.5	4.8	3.2	2.4	1.9
	PrecMin	12.9	0.0	0.1	0.0	0.0	0.5	1.3	1.5	0.7	0.3	0.3	0.3	0.1
	PrecStd	3.0	0.3	0.3	0.4	0.7	1.0	1.0	1.1	1.2	1.1	0.8	0.6	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	31.0	52.1	71.4	78.5	86.1	86.4	83.7	78.2	63.0	47.7	33.0
		MCWB	27.5	28.0	39.8	48.1	52.1	60.4	60.8	58.3	55.1	46.5	38.8	28.8
	2%	DB	24.1	27.2	46.4	66.1	72.7	82.2	82.4	80.2	72.8	57.8	40.5	28.7
		MCWB	21.2	23.0	36.9	46.1	51.0	59.0	60.2	57.4	52.5	43.6	35.6	25.3
	5%	DB	19.3	24.1	42.7	61.7	68.6	78.3	78.5	77.1	68.2	52.3	35.7	24.7
		MCWB	16.4	20.6	34.6	43.9	49.2	57.2	58.8	57.6	50.6	41.3	32.1	21.5
	10%	DB	14.6	20.2	39.1	57.4	64.4	74.6	74.7	73.1	63.6	47.7	32.9	20.4
		MCWB	12.4	17.5	33.0	42.2	47.8	57.0	58.6	56.4	48.7	39.9	29.9	17.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	29.9	41.2	50.4	55.4	64.2	65.8	62.2	57.0	48.4	40.6	29.2
		MCDB	32.5	30.8	50.0	66.1	68.5	78.2	75.6	75.0	70.4	58.6	45.9	32.0
	2%	WB	21.7	23.3	37.8	47.6	53.2	61.9	62.5	60.4	54.1	44.7	36.0	25.5
		MCDB	24.2	26.9	45.0	61.8	67.0	75.1	74.8	73.2	68.0	54.5	39.9	28.7
	5%	WB	16.4	20.6	35.1	45.5	51.5	60.0	61.0	59.0	52.2	42.6	32.7	21.6
		MCDB	19.1	23.9	41.2	57.8	64.4	72.7	72.8	71.4	64.7	50.2	35.2	24.4
	10%	WB	12.5	17.7	32.9	43.4	49.4	58.4	59.7	57.5	50.1	40.6	30.0	17.6
		MCDB	14.7	20.4	39.0	55.1	61.1	70.3	71.0	69.1	60.8	46.8	33.1	20.5
Mean Daily Temperature Range	5% DB	MDBR	17.2	19.9	20.3	23.4	22.7	22.9	21.9	24.7	25.4	18.3	13.6	14.7
		MCDBR	19.1	19.9	20.8	35.1	33.0	31.1	29.9	33.3	35.9	29.4	15.7	15.3
		MCWBR	16.7	17.1	12.8	16.8	14.2	11.1	10.8	12.8	16.4	16.1	11.5	13.4
	5% WB	MCDBR	18.8	19.4	19.7	29.4	26.2	24.3	23.3	26.9	31.1	24.5	14.7	15.6
		MCWBR	16.6	17.0	12.8	15.6	12.1	10.2	10.3	11.7	15.1	14.4	11.4	13.8
Clear-Sky Solar Irradiance	taub	0.249	0.278	0.326	0.375	0.368	0.371	0.382	0.360	0.323	0.311	0.276	0.251	
	taud	2.190	2.146	2.072	2.138	2.282	2.366	2.344	2.383	2.444	2.358	2.224	2.151	
	Ebn at Noon	251	271	275	274	281	281	275	277	277	257	235	227	
	Edh at Noon	23	32	42	44	40	37	37	34	29	26	22	21	
All-Sky Solar Radiation	RadAvg	458	808	1270	1598	1800	1904	1785	1639	1228	715	431	334	
	RadStd	38	47	91	114	151	175	118	118	121	85	33	36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page