

UST'- KOKSA, Russian Federation

WMO: 362290

Lat: 50.2716N

Lon: 85.6201E

Elev: 978

StdP: 90.12

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -36.1	(c) -33.2	(d) -39.3	(e) 0.1	(f) -35.9	(g) -36.5	(h) 0.1	(i) -33.2	(j) 6.8	(k) -11.1	(l) 6.2	(m) -9.6	(n) 0.0	(o) 80	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	28.0	15.0	26.2	14.3	24.5	14.0	16.7	23.8	15.9	22.7	15.1	21.7	2.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	11.7	17.8	13.6	10.9	17.3	12.7	10.3	16.8	50.8	24.0	48.2	22.7	45.9	21.9	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.3	(b) 5.4	(c) 4.7	(e) -36.2	(f) 31.1	(g) 3.4	(h) 1.4	(i) -38.7	(j) 32.0	(k) -40.7	(l) 32.8	(m) -42.6	(n) 33.6	(o) -45.1	(p) 34.6		
(a) 6.3	(b) 5.4	(c) 4.7	(e) -36.3	(f) 18.3	(g) 3.4	(h) 1.7	(i) -38.8	(j) 19.5	(k) -40.8	(l) 20.5	(m) -42.7	(n) 21.4	(o) -45.1	(p) 22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.4	-21.2	-17.2	-5.1	5.1	9.3	15.6	16.8	15.0	8.9	2.0	-8.0	-17.2
	DBStd	14.16	7.66	6.48	6.28	4.26	3.74	3.46	2.70	2.68	3.73	4.48	6.73	7.47
	HDD10.0	4107	968	761	468	151	59	3	0	1	62	250	541	842
	HDD18.3	6566	1227	994	726	397	279	93	62	107	282	508	791	1101
	CDD10.0	612	0	0	0	4	39	172	211	156	31	1	0	0
	CDD18.3	29	0	0	0	0	0	11	14	4	0	0	0	0
	CDH23.3	606	0	0	0	0	19	204	216	148	19	0	0	0
	CDH26.7	113	0	0	0	0	2	42	47	20	2	0	0	0
(14) Wind	WSAvg	1.6	1.1	1.3	1.7	1.9	2.2	1.7	1.6	1.5	1.7	1.9	1.7	1.4
(15) Precipitation	PrecAvg	463	12	11	11	30	54	76	80	68	45	32	24	18
	PrecMax	584	26	30	33	66	126	127	159	166	122	81	60	47
	PrecMin	328	1	3	1	1	13	34	38	18	7	8	3	3
	PrecStd	77	7	7	9	17	26	25	28	31	29	20	15	11
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.2	-0.5	11.2	21.9	25.8	30.1	30.2	28.7	25.6	17.2	8.7	0.6
		MCWB	-2.5	-2.2	4.3	9.0	11.2	15.8	16.0	14.6	12.8	8.0	3.8	-1.8
	2%	DB	-4.4	-2.7	8.0	19.0	22.6	27.9	28.0	26.8	22.7	14.3	4.7	-1.8
		MCWB	-6.0	-5.0	2.7	7.8	10.5	15.0	15.6	14.1	11.4	6.4	2.0	-3.7
	5%	DB	-7.1	-4.4	5.9	16.5	20.3	25.7	25.8	25.1	20.1	11.3	2.1	-4.1
		MCWB	-8.7	-6.4	1.4	6.6	9.5	14.0	14.9	14.2	10.3	5.1	0.0	-5.8
	10%	DB	-9.7	-6.6	4.0	14.1	18.0	23.7	23.7	22.9	17.5	8.7	0.5	-6.4
		MCWB	-10.9	-8.0	0.6	5.7	8.8	13.9	14.8	13.6	9.3	4.4	-1.1	-7.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.5	-1.2	5.1	10.2	13.0	17.9	18.8	16.8	13.9	9.1	4.8	-1.6
		MCDB	0.3	-0.7	10.0	18.9	20.3	25.7	24.2	23.9	21.3	14.8	7.7	0.0
	2%	WB	-5.7	-4.9	3.2	8.7	11.8	16.6	16.9	15.8	12.3	7.1	2.2	-3.6
		MCDB	-4.3	-2.8	7.2	16.6	19.4	24.0	23.8	22.9	20.0	12.5	4.4	-1.8
	5%	WB	-8.6	-6.3	1.7	7.5	10.8	15.6	16.1	15.0	11.2	5.9	0.4	-5.8
		MCDB	-7.2	-4.5	5.1	14.3	18.0	22.6	22.7	21.9	18.2	10.1	1.8	-4.2
	10%	WB	-10.8	-8.0	0.5	6.4	9.7	14.7	15.4	14.2	10.1	4.8	-1.1	-8.0
		MCDB	-9.6	-6.4	3.9	12.8	16.2	21.3	21.7	20.6	16.0	8.2	0.6	-6.4
(35) Mean Daily Temperature Range	MDBR		9.6	11.1	11.3	13.0	12.6	12.7	12.2	13.7	14.1	10.2	7.6	8.2
	5% DB	MCDBR	10.6	11.0	11.6	19.5	18.4	17.3	16.6	18.5	19.9	16.3	8.7	8.5
		MCWBR	9.3	9.5	7.1	9.3	7.9	6.2	6.0	7.1	9.1	8.9	6.4	7.4
	5% WB	MCDBR	10.5	10.8	10.9	16.3	14.6	13.5	12.9	15.0	17.3	13.6	8.2	8.7
		MCWBR	9.2	9.4	7.1	8.7	6.7	5.7	5.7	6.5	8.4	8.0	6.3	7.7
(40) Clear-Sky Solar Irradiance	taub		0.249	0.278	0.326	0.375	0.368	0.371	0.382	0.360	0.323	0.311	0.276	0.251
	taud		2.190	2.146	2.072	2.138	2.282	2.366	2.344	2.383	2.444	2.358	2.224	2.151
	Ebn at Noon		790	853	866	863	887	886	868	873	874	811	741	717
	Edh at Noon		73	100	131	138	126	117	118	108	91	81	70	65
(44) All-Sky Solar Radiation	RadAvg		1.44	2.55	4.00	5.04	5.68	6.00	5.63	5.17	3.87	2.25	1.36	1.05
	RadStd		0.12	0.15	0.29	0.36	0.48	0.55	0.37	0.37	0.38	0.27	0.10	0.11

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page