

ALMATY, Kazakhstan

WMO: 368700

Lat: 43.2394N

Lon: 76.9328E

Elev: 851

StdP: 91.51

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.8	-16.8	-21.2	0.6	-19.1	-18.8	0.8	-16.5	6.4	-1.2	5.3	-2.2	1.1	170	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	34.4	18.5	32.9	18.1	31.2	17.8	20.5	30.1	19.6	29.3	18.8	28.7	2.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	13.6	24.3	16.2	12.7	23.7	15.2	11.9	23.0	63.2	30.4	59.8	29.3	57.1	29.0	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.2	5.0	4.2		-22.3	37.7	4.3	1.9	-25.4	39.0	-27.9	40.1	-30.3	41.2	-33.4	42.6	
				-22.4	22.5	4.3	1.8	-25.5	23.8	-28.1	24.9	-30.5	26.0	-33.6	27.3	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	-5.3	-3.1	4.8	11.7	17.0	21.7	24.0	23.1	17.8	10.6	3.0	-3.2	(6)
(7)		DBStd	11.30	5.51	5.57	5.87	4.80	3.78	3.20	2.95	3.37	4.32	4.73	5.38	5.16	(7)
(8)		HDD10.0	1733	474	367	177	37	2	0	0	2	50	216	410		(8)
(9)		HDD18.3	3472	732	599	419	202	71	8	1	4	62	243	461	668	(9)
(10)		CDD10.0	1821	0	0	16	88	217	352	435	406	234	68	5	0	(10)
(11)		CDD18.3	518	0	0	0	3	28	110	178	151	45	3	0	0	(11)
(12)		CDH23.3	5749	0	0	2	59	291	1154	1993	1694	514	42	1	0	(12)
(13)		CDH26.7	2272	0	0	0	10	64	416	874	737	164	6	0	0	(13)
(14)	Wind	WSAvg	1.6	1.3	1.4	1.7	2.0	2.0	1.9	1.9	1.8	1.6	1.4	1.4	1.3	(14)
(15)	Precipitation	PrecAvg	649	34	38	71	104	105	61	38	29	28	57	55	38	(15)
(16)		PrecMax	1013	70	68	154	222	214	193	128	74	98	148	126	83	(16)
(17)		PrecMin	359	8	5	27	1	24	8	2	0	0	4	8	6	(17)
(18)		PrecStd	123	15	15	32	53	46	34	28	20	21	36	26	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	12.1	21.9	28.0	31.0	34.2	36.9	36.1	32.9	27.2	20.0	9.9	(19)
(20)			MCWB	3.4	6.5	11.4	14.7	17.4	18.2	19.9	18.9	17.0	14.0	10.4	4.9	(20)
(21)		2%	DB	5.5	8.7	19.1	24.9	28.2	32.2	34.8	34.2	30.4	24.0	16.3	7.2	(21)
(22)			MCWB	2.0	4.5	10.1	14.1	16.9	18.3	18.7	18.4	16.2	12.9	9.3	3.5	(22)
(23)		5%	DB	3.5	6.2	16.4	22.5	26.5	30.8	33.0	32.6	28.5	21.2	13.1	5.1	(23)
(24)			MCWB	1.0	3.0	9.2	12.9	16.3	18.0	18.4	17.9	15.4	11.7	7.9	2.2	(24)
(25)		10%	DB	1.8	4.0	13.8	20.1	24.8	29.1	31.2	30.9	26.4	18.8	10.7	3.2	(25)
(26)			MCWB	0.1	1.6	8.2	11.9	15.5	17.5	18.1	17.4	14.6	10.8	6.7	1.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	6.8	12.6	17.0	19.2	21.2	22.2	21.7	19.0	14.7	12.0	6.1	(27)
(28)			MCDWB	6.6	10.4	19.4	25.0	27.4	29.9	31.6	31.2	30.8	25.1	16.9	8.6	(28)
(29)		2%	WB	2.6	4.8	11.0	15.2	18.0	19.9	20.6	19.9	17.1	13.4	9.7	3.9	(29)
(30)			MCDWB	4.9	8.2	17.7	22.1	26.1	28.8	30.6	30.3	28.1	21.9	14.8	6.3	(30)
(31)		5%	WB	1.3	3.2	9.6	13.7	17.0	18.9	19.7	18.9	16.0	12.5	8.3	2.5	(31)
(32)			MCDWB	3.0	5.8	15.4	20.7	25.0	28.3	29.5	29.8	26.6	19.7	12.4	4.7	(32)
(33)		10%	WB	0.1	1.8	8.4	12.6	16.1	18.2	18.9	18.1	15.0	11.4	6.9	1.2	(33)
(34)			MCDWB	1.7	3.6	13.4	18.9	23.4	27.2	28.9	28.7	25.3	17.8	10.2	3.0	(34)
(35)	Mean Daily Temperature Range	MDBR	9.7	9.7	10.4	11.5	11.9	12.5	12.9	13.6	13.4	12.3	9.6	9.0	(35)	
(36)		5% DB	MCDBR	11.6	12.1	14.8	15.7	14.7	14.9	15.3	15.7	15.9	16.2	14.4	11.1	(36)
(37)			MCWBR	8.4	8.5	8.1	7.9	7.3	6.5	6.1	6.2	6.8	7.7	8.6	7.9	(37)
(38)		5% WB	MCDBR	10.4	11.0	13.3	13.9	13.5	13.3	13.7	14.9	14.7	14.2	13.0	10.3	(38)
(39)			MCWBR	7.7	7.8	7.6	7.5	7.2	6.6	6.4	6.5	6.8	7.2	8.1	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.318	0.362	0.422	0.459	0.435	0.437	0.431	0.404	0.388	0.391	0.357	0.312	(40)	
(41)		taud	2.163	2.055	1.969	1.955	2.103	2.158	2.201	2.268	2.253	2.132	2.139	2.188	(41)	
(42)		Ebn at Noon	787	807	802	806	840	838	839	851	834	766	727	754	(42)	
(43)		Edh at Noon	97	129	160	176	156	148	140	127	119	118	99	86	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.02	2.91	3.82	4.93	6.16	6.54	6.48	6.05	4.86	3.19	1.97	1.57	(44)	
(45)		RadStd	0.15	0.24	0.29	0.42	0.41	0.27	0.38	0.30	0.26	0.27	0.19	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.91	+2.33	N/A	N/A	-0.88	-1.40	-203	-252	+139	+72
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	-0.52	-0.89	N/A	N/A	N/A	N/A

Nomenclature: See separate page