

NARYN, Kyrgyzstan

WMO: 369740

Lat: 41.433N

Lon: 76.000E

Elev: 6696

StdP: 11.47

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-9.1	-17.7	2.7	-11.2	-14.5	3.2	-8.1	11.4	11.2	9.2	11.3	2.2	90	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.8	84.0	57.4	80.9	55.9	78.2	54.5	60.2	78.2	58.3	75.6	56.6	73.3	4.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.8	79.3	65.4	51.8	73.4	64.1	50.0	68.6	62.3	30.0	78.2	28.4	75.5	27.2	73.2	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	10.6	9.0	DB	-17.1	88.9	3.6	2.8	-19.7	91.0	-21.7	92.6	-23.7	94.2	-26.3	96.2	(4)
(5)			WB	-17.0	63.5	3.6	2.6	-19.6	65.4	-21.7	66.9	-23.8	68.4	-26.4	70.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.6	6.9	13.2	31.0	46.7	54.2	60.0	64.1	64.2	57.5	44.9	30.7	12.7	(6)	
	DBStd	21.35	8.16	9.28	9.69	7.43	5.64	4.48	5.10	4.62	5.33	6.63	7.91	8.86	(7)	
	HDD50	5054	1338	1031	589	145	24	2	0	0	7	184	579	1155	(8)	
	HDD65	8996	1803	1451	1053	549	335	160	76	70	228	622	1029	1620	(9)	
	CDD50	1635	0	0	0	46	154	300	437	440	232	26	0	0	(10)	
	CDD65	106	0	0	0	0	1	9	48	45	3	0	0	0	(11)	
	CDH74	1840	0	0	0	6	34	193	739	733	134	1	0	0	(12)	
	CDH80	370	0	0	0	0	0	24	186	152	8	0	0	0	(13)	
(14) Wind	WSAvg	3.6	2.7	2.9	3.3	4.1	4.4	4.2	4.2	4.2	4.2	3.3	2.8	2.6	(14)	
(15) Precipitation	PrecAvg	11.7	0.4	0.5	0.8	1.4	2.0	2.2	1.5	0.9	0.6	0.6	0.5	0.4	(15)	
	PrecMax	21.6	1.8	1.8	1.8	3.7	4.3	5.4	3.6	3.3	2.4	3.3	2.4	0.9	(16)	
	PrecMin	5.9	0.0	0.0	0.1	0.1	0.4	0.4	0.3	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.3	0.3	0.4	0.4	0.9	0.8	1.1	0.8	0.7	0.5	0.6	0.5	0.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.6	38.9	60.1	74.0	77.7	83.1	89.3	87.2	80.9	71.2	55.2	35.2	(19)	
		MCWB	25.0	29.1	42.4	50.1	52.5	57.2	59.5	58.5	53.4	48.2	41.0	27.8	(20)	
	2%	DB	25.2	32.9	53.9	69.0	74.0	78.9	84.6	84.0	77.8	65.6	49.8	30.4	(21)	
		MCWB	22.1	27.0	39.5	47.6	51.2	55.0	58.4	56.7	53.0	46.4	37.0	25.7	(22)	
	5%	DB	21.7	28.9	49.1	64.8	70.7	75.6	81.1	81.2	75.1	60.9	45.3	27.6	(23)	
		MCWB	19.2	24.9	37.8	45.7	50.3	53.7	56.5	55.9	51.9	44.2	34.8	23.9	(24)	
	10%	DB	18.7	25.8	44.5	60.3	67.1	72.4	77.9	78.2	72.0	57.1	41.5	25.0	(25)	
		MCWB	16.7	22.8	35.7	44.0	48.9	52.8	55.1	54.5	50.5	42.3	33.5	22.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	30.3	44.1	52.3	55.9	61.0	63.9	62.9	58.1	49.8	42.2	29.5	(27)	
		MCDB	29.1	36.7	56.1	69.3	72.3	78.2	84.0	82.1	76.7	65.1	51.9	32.6	(28)	
	2%	WB	22.4	27.6	41.0	49.3	53.3	57.3	60.6	60.0	55.1	47.3	39.0	26.6	(29)	
		MCDB	25.1	32.1	51.8	64.2	68.5	72.5	78.0	78.7	73.8	62.0	46.5	29.8	(30)	
	5%	WB	19.5	25.3	38.7	47.2	51.7	55.6	58.5	57.9	52.9	45.6	36.5	24.4	(31)	
		MCDB	21.5	28.6	47.1	60.7	66.1	70.5	76.1	75.5	71.5	58.2	43.1	27.1	(32)	
	10%	WB	16.6	22.8	36.5	45.3	50.3	54.2	56.9	56.1	51.1	43.9	34.0	21.8	(33)	
		MCDB	18.7	26.0	43.7	57.7	63.9	68.3	73.6	73.2	69.2	54.3	40.5	24.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	15.9	15.6	19.4	20.4	22.1	24.0	24.8	24.3	20.4	17.0	15.7	(35)	
		MCDBR	17.0	16.1	20.5	25.9	26.5	27.9	29.3	29.3	29.0	25.8	21.0	16.7	(36)	
	5% WB	MCWBR	13.6	12.0	11.0	12.3	11.3	11.0	11.2	11.8	13.1	13.2	11.9	12.3	(37)	
		MCWBR	16.4	15.4	18.2	22.7	22.6	23.4	26.0	25.6	26.5	22.3	18.3	14.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.278	0.317	0.397	0.445	0.429	0.415	0.397	0.384	0.366	0.362	0.320	0.270	(40)	
		taud	2.219	2.110	1.950	1.897	2.022	2.125	2.203	2.235	2.224	2.120	2.172	2.274	(41)	
	Ebn at Noon		275	278	265	261	269	273	277	277	274	257	253	269	(42)	
		Edh at Noon	30	39	52	60	54	49	45	42	39	39	31	26	(43)	
(44) All-Sky Solar Radiation	RadAvg		730	1030	1472	1789	1938	2022	2049	1903	1564	1081	764	627	(44)	
	RadStd		33	47	66	99	104	96	104	93	94	103	55	42	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page