

NARYN, Kyrgyzstan

WMO: 369740

Lat: 41.433N

Lon: 76.000E

Elev: 2041

StdP: 79.09

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-22.8	-27.6	0.4	-24.0	-25.8	0.5	-22.3	5.1	-11.5	4.1	-11.5	1.0	90	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	28.9	14.1	27.2	13.3	25.7	12.5	15.7	25.7	14.6	24.2	13.7	22.9	2.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.1	11.3	18.6	11.0	10.5	17.8	10.0	9.8	16.8	51.8	25.7	48.2	24.2	45.3	22.9	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.0	4.7	4.0	-27.3	31.6	2.0	1.6	-28.7	32.8	-29.9	33.7	-31.0	34.6	-32.4	35.7		
(5)			-27.2	17.5	2.0	1.5	-28.7	18.6	-29.9	19.4	-31.0	20.2	-32.4	21.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-14.0	-10.5	-0.5	8.2	12.3	15.5	17.8	17.9	14.2	7.2	-0.7	-10.7		
	DBStd	11.86	4.53	5.15	5.39	4.13	3.13	2.49	2.84	2.57	2.96	3.68	4.40	4.92		
	HDD10.0	2808	743	573	327	81	13	1	0	0	4	102	322	642		
	HDD18.3	4998	1002	806	585	305	186	89	42	39	127	346	572	900		
	CDD10.0	908	0	0	0	26	86	167	243	244	129	14	0	0		
	CDD18.3	59	0	0	0	0	1	5	27	25	2	0	0	0		
	CDH23.3	1022	0	0	0	3	19	107	411	407	74	1	0	0		
	CDH26.7	206	0	0	0	0	0	13	103	84	4	0	0	0		
(14) Wind	WSAvg	1.6	1.2	1.3	1.5	1.8	2.0	1.9	1.9	1.9	1.9	1.5	1.2	1.2		
(15) Precipitation	PrecAvg	297	9	13	21	35	50	57	38	23	16	14	13	10		
	PrecMax	549	46	45	46	95	110	136	92	84	61	85	61	24		
	PrecMin	151	0	0	2	3	9	11	7	0	1	0	0	0		
	PrecStd	85	7	9	11	23	21	27	21	17	13	16	13	7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.8	3.8	15.6	23.3	25.4	28.4	31.8	30.7	27.2	21.8	12.9	1.8		
		MCWB	-3.9	-1.6	5.8	10.0	11.4	14.0	15.3	14.7	11.9	9.0	5.0	-2.4		
	2%	DB	-3.8	0.5	12.2	20.5	23.3	26.1	29.2	28.9	25.4	18.6	9.9	-0.9		
		MCWB	-5.5	-2.8	4.2	8.7	10.7	12.8	14.7	13.7	11.6	8.0	2.8	-3.5		
	5%	DB	-5.7	-1.7	9.5	18.2	21.5	24.2	27.3	27.3	23.9	16.0	7.4	-2.5		
		MCWB	-7.1	-4.0	3.2	7.6	10.1	12.1	13.6	13.3	11.1	6.8	1.5	-4.5		
	10%	DB	-7.4	-3.4	7.0	15.7	19.5	22.4	25.5	25.7	22.2	13.9	5.3	-3.9		
		MCWB	-8.5	-5.1	2.1	6.7	9.4	11.5	12.8	12.5	10.3	5.7	0.8	-5.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.2	-0.9	6.7	11.3	13.3	16.1	17.7	17.1	14.5	9.9	5.7	-1.4		
		MCDB	-1.6	2.6	13.4	20.7	22.4	25.7	28.9	27.8	24.8	18.4	11.1	0.3		
	2%	WB	-5.3	-2.5	5.0	9.6	11.8	14.1	15.9	15.5	12.8	8.5	3.9	-3.0		
		MCDB	-3.9	0.0	11.0	17.9	20.3	22.5	25.5	26.0	23.2	16.7	8.0	-1.2		
	5%	WB	-7.0	-3.7	3.7	8.5	11.0	13.1	14.7	14.4	11.6	7.6	2.5	-4.2		
		MCDB	-5.8	-1.9	8.4	15.9	19.0	21.4	24.5	24.2	22.0	14.6	6.2	-2.7		
	10%	WB	-8.5	-5.1	2.5	7.4	10.1	12.3	13.8	13.4	10.6	6.6	1.1	-5.7		
		MCDB	-7.4	-3.4	6.5	14.3	17.7	20.1	23.1	22.9	20.7	12.4	4.7	-3.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	8.8	8.7	10.8	11.4	12.3	13.3	13.8	13.5	11.4	9.4	8.7		
		MCDBR	9.4	8.9	11.4	14.4	14.7	15.5	16.3	16.3	16.1	14.4	11.7	9.3		
	5% WB	MCWBR	7.6	6.6	6.1	6.9	6.3	6.1	6.2	6.6	7.3	7.3	6.6	6.9		
		MCWBR	9.1	8.6	10.1	12.6	12.5	13.0	14.5	14.2	14.7	12.4	10.2	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.278	0.317	0.397	0.445	0.429	0.415	0.397	0.384	0.366	0.362	0.320	0.270		
		taud	2.219	2.110	1.950	1.897	2.022	2.125	2.203	2.235	2.224	2.120	2.172	2.274		
	Ebn at Noon		866	877	836	824	849	860	872	873	863	810	797	847		
		Edh at Noon	94	124	165	188	170	154	141	132	124	122	99	82		
(44) All-Sky Solar Radiation	RadAvg		2.30	3.25	4.64	5.64	6.11	6.38	6.46	6.00	4.93	3.41	2.41	1.98		
	RadStd		0.10	0.15	0.21	0.31	0.33	0.30	0.33	0.29	0.29	0.33	0.17	0.13		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page