

SOKHUMI BABUSHARA, Georgia

WMO: 372600

Lat: 42.867N

Lon: 41.133E

Elev: 43

StdP: 14.67

Time Zone: 4.00 (E04)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	31.1	21.6	16.2	34.5	24.2	18.4	35.7	26.5	41.4	18.9	44.0	6.5	50	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	84.0	72.9	82.1	72.8	80.4	72.2	75.9	81.2	74.7	79.7	73.7	78.5	8.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	128.2	79.0	73.0	122.7	77.9	72.0	118.4	77.1	39.5	81.4	38.3	80.1	37.3	78.9	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.7	14.5	12.6	DB	25.6	90.7	4.1	2.5	22.6	92.6	20.2	94.0	17.9	95.5	14.9	97.3	(4)
(5)			WB	24.0	77.7	3.8	1.5	21.2	78.8	19.0	79.7	16.8	80.5	14.1	81.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.0	42.0	42.8	46.6	55.1	61.0	68.1	72.7	72.6	67.0	59.2	51.5	44.8	(6)	
	DBStd	12.22	5.56	6.52	6.80	6.00	5.82	3.88	3.57	3.71	4.20	5.01	6.06	5.57	(7)	
	HDD50	876	253	220	150	15	1	0	0	0	0	2	55	180	(8)	
	HDD65	3622	711	623	571	302	150	15	1	1	25	191	404	628	(9)	
	CDD50	3442	7	17	44	169	341	544	703	701	510	287	102	17	(10)	
	CDD65	712	0	0	0	6	26	109	239	236	85	11	0	0	(11)	
	CDH74	3582	0	0	3	50	186	366	1187	1386	346	57	1	0	(12)	
	CDH80	458	0	0	0	7	51	33	128	203	33	3	0	0	(13)	
(14) Wind	WSAvg	6.4	6.6	6.5	6.5	6.4	6.3	6.6	6.3	6.3	6.1	6.1	6.2	6.5	(14)	
(15) Precipitation	PrecAvg	58.9	5.3	4.1	4.9	5.0	4.5	5.3	4.0	4.9	4.7	5.1	5.3	6.3	(15)	
	PrecMax	79.2	17.0	7.7	9.8	10.1	10.4	10.2	11.9	13.3	10.7	10.9	14.4	12.5	(16)	
	PrecMin	43.9	0.7	0.2	0.7	2.0	0.6	1.3	0.7	0.0	0.0	0.0	0.9	0.9	(17)	
	PrecStd	10.0	3.9	2.0	1.8	1.9	2.3	2.4	2.6	3.3	2.9	2.9	3.1	3.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.7	65.6	71.0	81.5	86.2	83.4	85.9	86.5	84.1	79.0	71.6	62.7	(19)	
		MCWB	48.6	51.4	54.4	61.7	67.6	67.5	75.8	74.4	70.8	64.5	58.8	52.8	(20)	
	2%	DB	56.0	60.7	65.7	73.9	79.0	80.1	82.7	84.1	80.2	75.2	66.7	58.9	(21)	
		MCWB	48.0	50.2	52.4	59.2	64.9	69.5	74.4	74.5	70.9	64.4	56.5	50.9	(22)	
	5%	DB	53.2	56.4	61.5	69.8	74.3	77.8	81.1	82.4	77.9	72.1	63.6	55.3	(23)	
		MCWB	46.4	48.2	50.7	57.5	64.0	69.3	73.7	74.2	69.5	62.9	55.6	49.0	(24)	
	10%	DB	50.2	52.6	57.7	65.6	70.7	75.7	79.6	80.6	75.8	68.8	60.5	52.8	(25)	
		MCWB	45.1	46.0	49.3	55.6	62.8	68.4	73.0	73.2	67.9	60.7	54.7	47.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	53.1	55.7	64.4	68.9	72.9	77.6	77.4	74.5	67.1	61.7	54.3	(27)	
		MCDB	55.7	62.8	69.1	78.8	79.0	78.2	82.5	82.4	80.5	74.1	68.2	59.7	(28)	
	2%	WB	48.6	50.8	53.0	60.5	66.8	71.6	76.0	76.2	72.3	65.5	58.6	52.2	(29)	
		MCDB	54.4	58.9	63.8	70.8	75.5	76.7	80.9	81.6	77.9	72.6	63.6	57.0	(30)	
	5%	WB	47.2	48.7	51.3	58.5	65.2	70.4	74.7	75.1	70.6	63.6	56.8	50.3	(31)	
		MCDB	52.2	55.2	59.9	66.8	72.1	75.5	79.3	80.4	76.3	70.5	61.9	54.0	(32)	
	10%	WB	45.6	46.5	49.8	56.8	63.7	69.2	73.8	74.0	69.0	61.9	55.1	48.7	(33)	
		MCDB	49.7	51.9	56.5	63.8	69.4	74.3	78.3	79.2	74.6	67.8	60.0	52.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	12.5	13.0	13.3	12.3	12.1	10.9	12.8	14.9	15.8	13.7	12.3	(35)	
		MCDBR	16.3	19.1	21.0	21.6	21.2	15.8	12.6	15.1	17.5	20.6	18.6	16.0	(36)	
	5% WB	MCWBR	10.2	10.8	10.7	10.9	10.6	8.0	6.7	7.7	10.0	11.6	10.9	10.2	(37)	
		MCWBR	13.9	16.5	18.7	18.3	16.5	12.5	11.4	13.4	14.6	18.1	15.5	13.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.356	0.393	0.448	0.495	0.460	0.449	0.473	0.477	0.423	0.410	0.366	0.348	(40)	
		taud	2.238	2.122	2.023	1.975	2.171	2.272	2.228	2.206	2.336	2.300	2.355	2.305	(41)	
	Ebn at Noon		238	247	248	246	260	263	255	249	255	241	235	230	(42)	
		Edh at Noon	30	39	49	55	46	42	43	43	35	32	26	25	(43)	
(44) All-Sky Solar Radiation	RadAvg		476	732	1004	1437	1753	1977	1949	1756	1386	935	618	433	(44)	
	RadStd		64	86	84	181	164	134	151	117	141	98	77	48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+274	N/A

Nomenclature: See separate page