

SOKHUMI BABUSHARA, Georgia

WMO: 372600

Lat: 42.867N

Lon: 41.133E

Elev: 13

StdP: 101.17

Time Zone: 4.00 (E04)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.4	-0.5	-5.8	2.3	1.4	-4.3	2.6	2.0	11.8	5.2	8.4	6.7	2.9	50	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	28.9	22.7	27.8	22.6	26.9	22.3	24.4	27.3	23.7	26.5	23.1	25.9	3.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.3	26.1	22.8	17.5	25.5	22.2	16.9	25.1	73.9	27.5	71.3	26.7	68.9	26.0	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.5	5.6	-3.6	32.6	2.3	1.4	-5.2	33.6	-6.6	34.5	-7.9	35.3	-9.5	36.3		
(5)			-4.4	25.4	2.1	0.9	-6.0	26.0	-7.2	26.5	-8.4	27.0	-10.0	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	5.6	6.0	8.1	12.8	16.1	20.1	22.6	22.6	19.4	15.1	10.9	7.1		
	DBStd	6.79	3.09	3.62	3.78	3.33	3.23	2.15	1.99	2.06	2.33	2.78	3.37	3.09		
	HDD10.0	487	141	122	83	8	1	0	0	0	0	1	31	100		
	HDD18.3	2012	395	346	317	168	83	8	1	1	14	106	224	349		
	CDD10.0	1912	4	9	24	94	189	302	391	389	283	159	57	9		
	CDD18.3	396	0	0	0	3	14	61	133	131	47	6	0	0		
	CDH23.3	1990	0	0	2	28	103	203	659	770	192	32	1	0		
	CDH26.7	254	0	0	0	4	28	18	71	113	18	2	0	0		
(14) Wind	WSAvg	2.8	2.9	2.9	2.9	2.9	2.8	3.0	2.8	2.8	2.7	2.7	2.8	2.9		
(15) Precipitation	PrecAvg	1497	134	105	124	128	115	134	102	124	119	129	135	159		
	PrecMax	2011	432	196	250	257	265	260	301	337	272	278	365	318		
	PrecMin	1115	19	6	18	51	15	33	17	0	1	1	24	24		
	PrecStd	255	99	51	45	47	58	61	66	84	73	73	78	83		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	18.7	21.7	27.5	30.1	28.6	30.0	30.3	28.9	26.1	22.0	17.0		
		MCWB	9.2	10.8	12.4	16.5	19.8	19.7	24.3	23.5	21.6	18.1	14.9	11.5		
	2%	DB	13.3	15.9	18.7	23.3	26.1	26.7	28.2	28.9	26.8	24.0	19.3	15.0		
		MCWB	8.9	10.1	11.3	15.1	18.3	20.8	23.5	23.6	21.6	18.0	13.6	10.5		
	5%	DB	11.8	13.5	16.4	21.0	23.5	25.4	27.3	28.0	25.5	22.3	17.6	13.0		
		MCWB	8.0	9.0	10.4	14.2	17.8	20.7	23.2	23.4	20.8	17.2	13.1	9.5		
	10%	DB	10.1	11.4	14.3	18.7	21.5	24.3	26.5	27.0	24.3	20.5	15.8	11.6		
		MCWB	7.3	7.8	9.6	13.1	17.1	20.2	22.8	22.9	19.9	16.0	12.6	8.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	11.7	13.2	18.0	20.5	22.7	25.3	25.2	23.6	19.5	16.5	12.4		
		MCDB	13.2	17.1	20.6	26.0	26.1	25.7	28.0	28.0	26.9	23.4	20.1	15.4		
	2%	WB	9.2	10.4	11.7	15.8	19.3	22.0	24.4	24.6	22.4	18.6	14.8	11.2		
		MCDB	12.5	15.0	17.7	21.6	24.1	24.8	27.2	27.6	25.5	22.6	17.5	13.9		
	5%	WB	8.4	9.3	10.7	14.7	18.5	21.3	23.7	24.0	21.4	17.6	13.8	10.2		
		MCDB	11.2	12.9	15.5	19.3	22.3	24.1	26.3	26.9	24.6	21.4	16.6	12.2		
	10%	WB	7.6	8.1	9.9	13.8	17.6	20.7	23.2	23.3	20.5	16.6	12.8	9.3		
		MCDB	9.9	11.1	13.6	17.7	20.8	23.5	25.7	26.2	23.7	19.9	15.5	11.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.0	7.2	7.4	6.8	6.7	6.0	7.1	8.3	8.8	7.6	6.8		
		MCDBR	9.0	10.6	11.6	12.0	11.8	8.8	7.0	8.4	9.7	11.4	10.3	8.9		
	5% WB	MCWBR	5.7	6.0	5.9	6.0	5.9	4.4	3.7	4.3	5.6	6.4	6.0	5.7		
		MCWBR	7.7	9.2	10.4	10.2	9.2	6.9	6.3	7.5	8.1	10.0	8.6	7.4		
(40) Clear-Sky Solar Irradiance	taub	taub	0.356	0.393	0.448	0.495	0.460	0.449	0.473	0.477	0.423	0.410	0.366	0.348		
		taud	2.238	2.122	2.023	1.975	2.171	2.272	2.228	2.206	2.336	2.300	2.355	2.305		
	Ebn at Noon	Ebn at Noon	751	780	781	776	820	829	804	786	805	759	742	726		
		Edh at Noon	93	122	153	173	146	132	137	136	111	102	83	80		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.50	2.31	3.17	4.53	5.53	6.23	6.14	5.54	4.37	2.95	1.95	1.36		
	RadStd	RadStd	0.20	0.27	0.26	0.57	0.52	0.42	0.48	0.37	0.44	0.31	0.24	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.53	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+152	N/A

Nomenclature: See separate page