

AMBROLAURI, Georgia

WMO: 373080

Lat: 42.527N

Lon: 43.139E

Elev: 544

StdP: 94.96

Time Zone: 4.00 (E04)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.6	-5.9	-12.2	1.4	-2.0	-10.5	1.6	-1.7	9.6	5.0	8.6	5.1	0.7	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	34.2	20.0	32.3	19.9	30.5	19.7	22.7	29.8	21.7	28.5	20.8	27.2	4.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	16.3	26.2	19.6	15.4	24.6	18.8	14.6	23.5	70.0	29.9	66.1	28.5	62.6	27.2	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
9.4	8.0	6.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-10.2	37.2	3.4	1.8	-12.7	38.5	-14.7	39.6	-16.6	40.6	-19.1	42.0
			-9.8	23.9	2.1	1.2	-11.4	24.7	-12.6	25.4	-13.8	26.0	-15.4	26.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	1.4	4.2	7.6	12.6	16.9	21.2	23.4	23.8	19.5	14.2	7.5	2.7		
	DBStd	8.48	3.09	3.73	3.82	3.77	2.99	2.66	2.75	2.78	3.54	3.05	3.48	3.82		
	HDD10.0	862	268	164	93	17	1	0	0	0	1	3	87	228		
	HDD18.3	2472	526	396	332	176	62	6	1	2	29	132	326	486		
	CDD10.0	1940	0	2	19	94	215	337	416	427	284	133	12	1		
	CDD18.3	509	0	0	0	3	18	92	159	171	63	3	0	0		
	CDH23.3	4386	0	0	1	54	224	748	1294	1539	489	37	0	0		
	CDH26.7	1711	0	0	0	6	54	265	533	702	148	3	0	0		
(14) Wind	WSAvg	2.4	1.5	2.4	2.8	2.9	2.8	2.9	2.7	2.9	2.6	2.1	1.7	1.5		
(15) Precipitation	PrecAvg	1241	99	74	98	104	114	108	102	95	107	128	104	103		
	PrecMax	1530	198	122	267	161	185	228	209	183	192	273	248	369		
	PrecMin	959	31	32	28	52	44	33	35	25	9	38	27	26		
	PrecStd	152	41	26	53	31	39	40	41	35	45	64	55	64		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	17.9	22.3	27.3	30.7	33.7	36.1	36.6	33.1	26.6	19.6	15.8		
		MCWB	5.4	7.5	11.1	14.5	18.3	20.2	21.7	20.3	18.2	16.4	10.5	8.5		
	2%	DB	9.1	14.6	19.1	24.8	28.1	31.6	33.8	34.7	30.1	24.1	17.2	11.6		
		MCWB	4.6	6.6	9.8	13.3	17.0	19.8	20.8	19.6	18.2	15.4	9.4	6.3		
	5%	DB	7.3	12.1	16.7	22.6	25.8	29.8	31.8	32.9	28.2	22.2	15.1	9.7		
		MCWB	3.7	5.5	8.5	12.1	16.2	19.3	20.7	19.5	17.4	14.4	8.7	5.6		
	10%	DB	5.6	9.7	14.3	20.2	23.6	27.8	29.7	30.7	26.2	20.0	12.9	7.8		
		MCWB	3.0	4.6	7.6	11.3	15.4	18.6	20.0	19.7	16.9	13.4	7.7	4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	8.6	11.9	16.5	19.6	22.9	24.4	23.7	20.9	17.6	11.6	8.9		
		MCDB	9.6	14.7	20.1	24.1	28.8	30.4	31.9	31.1	29.0	24.0	16.3	13.2		
	2%	WB	5.5	7.3	10.3	14.3	18.1	21.2	23.1	22.4	19.4	16.2	10.4	7.3		
		MCDB	7.8	12.6	16.8	21.8	25.7	28.6	29.9	29.7	26.2	22.0	14.9	10.4		
	5%	WB	4.3	6.2	9.2	13.1	16.9	20.3	22.0	21.5	18.6	15.1	9.5	6.1		
		MCDB	6.7	10.8	15.0	19.9	23.8	27.5	28.8	28.3	25.2	20.5	13.4	8.7		
	10%	WB	3.3	5.3	8.2	12.0	15.9	19.3	21.0	20.5	17.9	14.2	8.6	5.1		
		MCDB	5.2	8.9	12.9	19.1	21.9	25.9	27.0	27.2	23.8	18.8	12.0	7.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	9.2	9.7	12.0	11.4	11.7	11.0	12.9	11.7	11.6	10.7	8.0		
		MCDBR	10.1	14.2	15.5	17.0	16.2	15.4	15.1	16.6	15.7	15.4	15.0	10.7		
	5% WB	MCWBR	6.2	7.4	7.4	7.4	7.0	6.0	5.5	5.3	5.3	7.2	8.0	6.2		
		MCWBR	8.5	12.3	12.9	15.0	14.2	13.6	13.0	13.7	13.0	14.2	12.5	8.8		
(40) Clear-Sky Solar Irradiance	taub		0.311	0.347	0.406	0.461	0.429	0.417	0.447	0.447	0.389	0.377	0.331	0.306		
		taud	2.259	2.144	2.045	2.009	2.201	2.298	2.237	2.235	2.379	2.356	2.412	2.339		
	Ebn at Noon		813	834	824	808	848	857	827	814	841	800	793	789		
		Edh at Noon	90	119	149	167	142	129	136	132	106	96	78	76		
(44) All-Sky Solar Radiation	RadAvg		1.57	2.40	3.20	4.28	5.25	5.80	5.82	5.45	4.35	2.94	1.96	1.40		
	RadStd		0.24	0.34	0.32	0.56	0.55	0.43	0.53	0.42	0.43	0.34	0.26	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page