

MTA-SABUETI, Georgia

WMO: 374090

Lat: 42.034N

Lon: 43.475E

Elev: 4087

StdP: 12.65

Time Zone: 4.00 (E04)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	16.4	9.8	10.5	18.9	13.4	12.6	20.1	42.7	17.0	36.8	22.4	19.6	90	0.766

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.4	80.6	67.4	77.8	66.2	74.8	65.3	70.1	76.7	68.3	74.4	66.6	72.4	17.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	120.3	73.6	66.3	112.9	71.7	64.6	106.5	69.7	36.9	76.5	35.2	74.5	33.7	72.3	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.5	32.8	29.7	DB	10.8	84.4	5.6	2.9	6.8	86.5	3.5	88.2	0.3	89.8	-3.8	91.8	(4)
(5)			WB	10.6	74.5	5.9	2.4	6.3	76.2	2.9	77.7	-0.4	79.0	-4.7	80.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	28.3	29.4	34.6	44.2	53.4	60.2	63.5	66.1	58.5	48.7	38.8	32.2		
	DBStd	14.68	6.21	7.47	7.09	7.68	5.69	4.81	5.35	5.25	6.04	6.54	7.84	6.67		
	HDD50	2971	674	576	477	204	33	1	0	0	9	102	341	554		
	HDD65	6877	1139	996	942	626	360	156	93	51	206	505	785	1018		
	CDD50	1722	0	0	0	29	138	306	418	498	264	62	6	1		
	CDD65	152	0	0	0	0	0	11	46	84	11	0	0	0		
	CDH74	786	0	0	0	1	6	45	230	454	50	0	0	0		
	CDH80	111	0	0	0	0	0	1	21	88	1	0	0	0		
(14) Wind	WSAvg	14.2	13.6	15.5	15.4	14.8	13.7	12.9	13.2	14.5	14.7	14.9	14.6	13.3		
(15) Precipitation	PrecAvg	42.5	4.5	3.7	3.9	3.3	3.5	3.4	2.4	2.4	3.0	3.8	4.3	4.3		
	PrecMax	54.3	9.7	8.3	7.5	5.7	6.4	7.2	5.0	4.4	5.7	7.4	9.4	8.7		
	PrecMin	31.9	1.2	1.6	1.5	1.5	1.5	1.2	0.9	0.6	0.1	1.4	0.6	1.4		
	PrecStd	5.1	2.2	1.7	1.5	0.9	1.1	1.2	1.0	0.9	1.3	1.5	2.5	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	51.0	55.8	68.2	73.8	78.9	82.4	86.9	79.1	68.1	60.8	55.3		
		MCWB	37.9	43.0	45.9	55.1	61.5	67.6	70.7	66.4	66.4	60.1	48.6	44.7		
	2%	DB	40.9	46.9	51.5	63.9	69.1	74.8	79.5	82.3	75.2	63.8	56.0	48.1		
		MCWB	35.8	40.7	43.6	53.5	59.2	65.4	67.8	66.8	64.6	56.9	46.2	41.7		
	5%	DB	38.5	43.1	48.5	60.3	66.3	72.2	76.5	79.0	70.9	60.8	52.5	44.3		
		MCWB	34.5	37.2	42.3	51.1	58.1	64.1	66.1	66.3	62.8	54.8	44.6	38.5		
	10%	DB	36.0	39.5	45.4	56.7	63.4	69.4	73.2	75.8	67.8	57.8	49.0	41.4		
		MCWB	33.3	35.4	40.4	49.1	56.2	62.7	65.3	65.6	60.8	53.0	43.4	37.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.2	44.8	47.4	57.3	64.0	69.7	72.7	72.6	69.7	61.3	51.5	46.2		
		MCDB	42.7	49.2	52.4	66.1	70.1	75.6	80.1	80.6	77.2	66.3	56.3	50.6		
	2%	WB	37.2	41.5	44.9	54.0	61.2	67.2	69.9	70.2	66.2	58.0	48.6	42.5		
		MCDB	39.5	45.9	50.4	62.6	67.0	72.8	76.2	77.1	72.2	62.4	51.8	46.9		
	5%	WB	35.5	38.2	43.0	51.9	59.0	65.2	67.9	68.5	63.7	55.7	46.3	40.0		
		MCDB	37.4	41.6	47.1	59.5	64.6	70.4	73.6	75.1	69.1	59.3	49.8	43.2		
	10%	WB	33.7	36.0	41.1	49.5	57.0	63.5	66.3	66.7	61.5	53.9	44.3	37.8		
		MCDB	35.7	38.8	44.7	55.4	62.0	68.2	71.6	73.0	66.3	56.9	48.2	40.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	9.4	10.9	14.3	13.9	14.4	14.1	16.4	14.5	12.0	9.9	8.5		
		MCDBR	12.5	15.7	16.5	20.7	19.1	18.9	19.9	21.4	19.3	16.7	15.7	13.1		
		MCWBR	9.0	10.9	10.5	12.0	12.0	11.9	11.4	11.4	11.2	10.3	9.7	8.7		
	5% WB	MCDBR	10.6	13.8	14.1	19.9	17.4	17.7	17.9	19.3	18.3	15.6	12.9	11.0		
		MCWBR	8.3	10.2	9.7	12.4	11.9	12.2	11.7	12.7	11.9	10.2	9.2	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.283	0.313	0.361	0.408	0.381	0.371	0.398	0.399	0.351	0.341	0.300	0.279		
	taud		2.375	2.297	2.223	2.154	2.317	2.394	2.342	2.335	2.455	2.440	2.500	2.437		
	Ebn at Noon		275	281	279	273	283	286	277	273	280	269	268	267		
	Edh at Noon		25	33	40	46	40	37	39	38	31	28	23	22		
(44) All-Sky Solar Radiation	RadAvg		559	883	1135	1407	1654	1868	1904	1775	1421	954	637	476		
	RadStd		69	120	135	157	164	129	159	135	133	101	84	51		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page